




3A-E-335B CONDENSATE/GLYCOL EXCHANGER			
CODE	ASME SEC. VIII DIV.1 2010 ED.+ 2011 ADD. & TEMA CLASS "R" 9TH ED.-2007 + API 660 8TH ED.		
	SHELL	TUBE	
DESIGN PRESS.	1950/F.V kPag	1500/F.V kPag	
DESIGN TEMP.	214 °C	214 °C	
M.A.W.P	2653 kPag	1681 kPag	
HYDRO.TEST PRESS.	3448 kPag	2186 kPag	
M.D.M.T	-29 °C	-29 °C	
P.W.H.T	NO	NO	
RADIOGRAPHY (S/H)	SPOT/-	FULL/-	
YEAR BUILT	2015	MFR. SERIAL NO.	E0351-025
EFF. SURFACE AREA/SHELL	61.9 m²	W'T (BUNDLE)	- KG
PURCHASE ORDER NO.	P-5310-01	TEMA TYPE	H-NEN
FABRICATOR	 SEWON CELLONTECH CO., LTD.		
 SNC • LAVALIN SNC ♦ LAVALIN INC.			
 MEG ENERGY CORP.			

SQS
VERIFIED REVIEWED
S.G. Joo

12/31-11

SEWON
리온테크(주)
SEWON-QC J.S. LEE

12/30-25

CRN		W9818.2		A NO.	
NB 1248					
CERTIFIED BY					
		 SEWON CELLONTECH CO., LTD.			
  RT3-S/RT1-T -	SHELL	2653	kPag	AT	214 °C
	TUBE	1681	kPag	AT	214 °C
	(M.A.W.P)				
	SHELL	F.V	kPag	AT	214 °C
	TUBE	F.V	kPag	AT	214 °C
	(M.A.E.W.P)				
SHELL	-29	°C	AT	2653/F.V	kPag
TUBE	-29	°C	AT	1681/F.V	kPag
		(M.D.M.T)		(INT./EXT.)	
MFR. SERIAL NO.			E0351-025		
YEAR BUILT			2015		
CAUTION : FIXED TUBESHEET H/E YES					
THE CODE REQUIRED PRESSURES AND TEMPERATURES MARKED ON THE HEAT EXCHANGER RELATE TO THE BASIC DESIGN CONDITIONS. THE HEAT EXCHANGER DESIGN HAS BEEN EVALUATED FOR SPECIFIC OPERATING CONDITIONS AND SHALL BE RE-EVALUATED BEFORE IT IS OPERATED AT DIFFERENT OPERATING CONDITIONS.					

SQS
VERIFIED & REVIEWED
S. G. HAN

SEWON
세원셀론테크(주)
SEWON GOO LEE
12/30/2015