

CRN

W9330.2


A NO.

1245

CERTIFIED BY



SEWON CELLONTECH CO., LTD.



U

W

RT4

HT-T

SHELL

1554

kPag

AT

214

°C

TUBE

2007

kPag

AT

214

°C

(M.A.W.P)

SHELL

F.V

kPag

AT

214

°C

TUBE

F.V

kPag

AT

214

°C

(M.A.E.W.P)

SHELL

-29

°C

AT

1554/F.V

kPag

TUBE

-29

°C

AT

2007/F.V

kPag

(M.D.M.T)



(INT./EXT.)

MFR. SERIAL NO.

E0351-022

YEAR BUILT


2015




3A-E-325B BLOWDOWN DISPOSAL/GLYCOL EXCHANGER

CODE ASME SEC. VIII DIV.1 2010 ED.+ 2011 ADD. & TEMA CLASS 'R' 9TH ED.-2007 + API 660 8TH ED.

	SHELL	TUBE
DESIGN PRESS.	1500/F.V kPag	1950/F.V kPag
DESIGN TEMP.	214 °C	214 °C
M.A.W.P	1554 kPag	2007 kPag
HYDRO.TEST PRESS.	2020 kPag	2609 kPag
M.D.M.T	-29 °C	-29 °C
P.W.H.T	NO	YES
RADIOGRAPHY (S/H)	SPOT/FULL	SPOT/-
YEAR BUILT	2015	MFR. SERIAL NO. E0351-022
EFF. SURFACE AREA/SHELL	301.3 m <sup>2</sup>	W'T (BUNDLE) 6590 KG
PURCHASE ORDER NO.	P-5310-01	TEMA TYPE H-AFU
FABRICATOR	SEWON CELLONTECH CO., LTD.	

 **SNC ♦ LAVALIN**

 **MEG ENERGY CORP.**

**SQS**  
☐ VERIFIED  
☒ REVIEWED  
S.G. JONES

☒ REVIEW  
☒ MITTNESS  
SEWON QC & LEE

12/31/11