



GENERAL NOTES:

- ① CUSTOMER TO FURNISH FUSED OR CIRCUIT BREAKER DISCONNECT PRIOR TO STARTER AS REQUIRED BY LOCAL WIRING CODES.
 - ② SEE TRANSFORMER NAME PLATE FOR CORRECT PRIMARY VOLTAGE CONNECTION.
 - ③ COMMON FAULT MAY BE USED TO PROVIDE REMOTE INDICATION OF ANY PRE-ALARM, MAINTENANCE OR FAULT SHUTDOWN CONDITION.
 - ④ SUPERVISOR II MICROCONTROLLER
 - Ⓐ P1 & P2 PRESSURE TRANSDUCERS ARE INTEGRAL TO THE AIR COMPRESSOR LOCALLY MOUNTED CONTROL PANELS.
- ABOVE WIRING DIAGRAM IS FOR ONE AIR COMPRESSOR, THIS PACKAGE HAS TWO AIR COMPRESSORS.
 - SUPERVISOR II INCLUDES AUTOMATIC RESET AFTER POWER FAILURE. COMPRESSOR WILL START IN AUTO IF AIR DEMAND IS PRESENT. ALL OPERATING PARAMETERS WILL REMAIN STORED IN MEMORY DURING POWER OUTAGE.
 - REFER TO OPERATORS MANUAL FOR SUPERVISOR II DESCRIPTION OF OPERATING DETAILS, PARAMETERS, MESSAGES, SET-UP AND READOUTS.
 - CSA APPROVED.

THIS PRINT IS THE PROPERTY OF CHAMCO INDUSTRIES LTD., IS CONFIDENTIAL, IS LENT ONLY FOR REFERENCE IN EQUIPMENT MAINTENANCE OR IN DEALING WITH CHAMCO INDUSTRIES LTD. AND IS NOT TO BE COPIED OR REPRODUCED WITHOUT OUR EXPRESS WRITTEN PERMISSION			
REV.	DATE	BY	DESCRIPTION
0	02.01.06	J.Y.	PRELIMINARY DRAWING RELEASED FOR CUSTOMER APPROVAL
CHAMCO CHAMCO INDUSTRIES LTD. VANCOUVER - CALGARY - EDMONTON - PRINCE GEORGE			

DEVON CANADA CORPORATION c/o VISTA PROJECTS LTD PROJECT: NORTH COLEMAN COMPRESSOR STATION PURCHASE ORDER No. 1195-0		DESIGNED BY M.R.
INSTRUMENT AIR COMPRESSOR PACKAGE SULLAIR ES8-15H AC/AC AIR COMPRESSOR DOMNICK HUNTER DME025 AIR DRYER AIR COMPRESSOR ELECTRICAL WIRING DIAGRAM		DRAWN BY J.Y.
DATE JAN. 02, 2006		CHECKED BY M.R.
SCALE N.T.S.		JOB No. 1012296ABS
DWG No. C1012314-30		REV. 0