


 <b>MEG ENERGY</b>	<b>CHRISTINA LAKE REGIONAL PROJECT</b> <b>Phase 3A EPC for Central Plant Facilities</b>	 <b>SNC-LAVALIN</b>
	<b>SLI Project No. 511036</b>	



 <b>SNC-LAVALIN</b>	<input type="checkbox"/> A1 Not suitable to initiate fabrication, modify as noted, resubmit for review.
	<input type="checkbox"/> B1 Suitable to initiate fabrication as noted, modify as noted, resubmit for review.
Vendor's drawing review for conformity with specifications and design drawing.	<input type="checkbox"/> C1 Suitable to fabricate to completion as noted, submit final documents including as-builts as required.
This review does not relieve the vendor of his responsibility for errors in design and detailing as detailed in his contract.	<input type="checkbox"/> D1 Suitable to fabricate to completion, submit final documents including as-built documents as required.
	<input type="checkbox"/> E1 Not suitable as final documents as noted, modify as noted and resubmit.
	<input checked="" type="checkbox"/> F1 Suitable as final documents, no further resubmittal required (unless revised by vendor).
Vendor: Sewon Cellontech Co. Ltd. - P00007      No.: E0351-3AE111-P-02      Rev: 1      Date Rec'd 2013/09/04	
Doc. Title: L53.51, L53.53 - THERMAL DESIGN CALCULATION - Tag:3A-E-111A-H	
Client Code:	Project: MEG Phase 3A EPC
Reviewed by: <i>SS</i>	Document No: P-5310-01-0035
Date: <i>11-Sept-2013</i>	Submittal 02



 <b>SEWON CELLONTECH</b>	<b>DOCUMENT FOR EQUIPMENT</b>	SWC JOB NO	E-0351
		ITEM NO.	3A-E-111 A TO H
		SWC DOC. NO.	E0351-3AE111 A TO H- P-02

ASME-U

FOR APPROVAL

 <b>MEG Energy Corp.</b>		 <b>SNC-LAVALIN</b>	
P.O NO.		P-5310-01	
PROJECT NAME	CLRP Phase 3A Central Plant Facility: EPC		
PROJECT NO.	511036		
DOCUMENT TITLE	THERMAL DESIGN CALCULATION		
ITEM NO.	ITEM DESCRIPTION		
3A-E-111 A TO H	SALES OIL / GLYCOL EXCHANGER		



- Total Sheet 11 Sheet (Including This Cover)

1	M.K.PARK 8/16/2013	T.W.KIM 8/19/13	Y.S.JI 8/21/2013	SECOND ISSUE
0	M.K.PARK	T.W.KIM	Y.S.JI	FIRST ISSUED
REV	PREPARED BY	REVIEWED BY	APPROVED BY	DESCRIPTION

**SEWON CELLONTECH CO.,LTD.**

**SEWON CELLONTECH****TUBULAR HEAT EXCHANGER**

SHEET 2 OF 47

CUSTOMER	MEG Energy Corp.			REV	MADE BY	CHECKED BY	APPROVED BY	DATE	
LOCATION	CANADA			0	-	-	-	07-01-2013	
JOB NO.	511036			1	-	-	-	08-14-2013	
SERVICE	Sales Oil / Glycol Exchanger								
ITEM NO.	3A-E-111 A to H (Max UA Case)								
Total	8	Shells, Connected in	2 Parallel 4 Series Shells	Install	<input checked="" type="checkbox"/> Hor. <input type="checkbox"/> Vert.	Size	1,143.0 ID - 8,534.0 L		
Code	ASME Sec.VIII Div.1 (STAMP), TEMA, API680 TEMA Type BEU			TEMA Class	R	Effective Area	556.41	m <sup>2</sup> /Shell	
PERFORMANCE OF ONE BATTERY									
		SHELL SIDE			TUBE SIDE				
		INLET			OUTLET			INLET	OUTLET
Fluid Circulated		BP Frac Dilbit			TEG/Water (60%/40% wt)				
Total Fluid kg/hr		444696			527296				
Vapor kg/hr									
Liquid kg/hr		444696			444696			527298	527298
Steam kg/hr									
Water kg/hr									
Noncondensable kg/hr									
Operating Temperature °C		117.90			49.70			40.00	75.00
Operating Pressure kPa.a		984.014			994.015				
Density kg/m <sup>3</sup>		L / v	875	921	1078.00		1052.00		
Viscosity cP		L / v	13.580	195.68	4.6600		2.0900		
Thermal Conductivity W/m·°C		L / v	0.1031	0.1167	0.3281		0.3371		
Specific Heat kJ/kg·°C		L / v	2.1040	1.8400	3.2231		3.3481		
Latent Heat kJ/kg									
Bubble / Dew Point °C									
Critical Press. / Temp. kPa.a / °C									
Velocity m/sec		0.31			0.98				
Pressure Drop kPa.		Allow.	250.000	Calc.	217.538	Allow.	200.000	Calc.	174.675
Fouling Resistance m <sup>2</sup> ·°C/kW		0.616			0.18				
Film Coefficient W/m <sup>2</sup> ·K		318.71			1,446.38				
Overall Coefficient W/m <sup>2</sup> ·K		Clean	249.85	Calc.	206.70	Design	175.27		
Heat Duty KW		12,630.00			LMTD	°C	MTD	21.6 °C	
CONSTRUCTION									
Design Pressure	Design Temperature	1450.0 / FV	kPa.G	-29 / 178 °C	1500.0 / FV	kPa.G	-29 / 178 °C		
No. of Passes		1			4				
Tubes No.	396U / Shell, Size	25.40 mm	Thickness	2.11 (Min.) mm (BWG: 14)	Length	8,534.0 mm			
Shell	1143 mm ID	Tube Pitch	31.75 mm	Layout angle	45 °	Effective	- mm		
Baffles	Cross Baffle 16 ea / Shell, Type Single Seg. (Hori.)	Cut	24.5 % Dia.	Spacing c/c	486.0 mm	End	- mm		
pv <sup>2</sup>	Inlet Nozzle 2,031.69	Entrance 2,509.52	Outlet Nozzle 1,928.73	kg/m·sec <sup>2</sup>	Impingement plate	Circular plate			
Material	Tube SA 179 Seamless	Shell & Cover SA 516 GR. 70N	Channel & Cover SA 516 GR. 70N	Expansion Joint	N/A				
	Tube Sheet SA 266 GR.2	Baffle Carbon Steel							
Estimated Weight	Empty Weight	kg	Bundle Weight	- kg	Full Water Weight	kg			
Corrosion Allowance	Shell side 3.2 mm	Tube side 3.2 mm	Tube Joints:	Rolled (two grooves) and Expanded					
Insulation	Shell side 64 mm	Tube side 64 mm							
MEAN METAL TEMPERATURE	Temperature, °C		Pressure, kPa.G		a) Each process nozzle shall be provided with one 1" 300# RFLWN (complete with blind flange, gasket, bolts & nuts).				
	Shell	Tube	Shell	Tube	b) Exchanger is to be designed for future field hydrotest in the fully corroded condition.				
Normal Operating	-	-	-	-	c) Seller is to design and install electrical heat tracing for hold temperature of 10°C.				
Startup	-	-	-	-	d) CSA approval is required for electric components and installation. The heat exchanger is located in hazardous area class 1, Zone 2.				
NOZZLE	SHELL SIDE			TUBE SIDE			e) Seller is to supply and install 64mm thick mineral fiber insulation.		
	Tag	No	NPS	Remarks	Tag	No	NPS	Remarks	
Inlet	S1	1	10		T1	1	8		
Outlet	S2	1	10		T2	1	8		
Vent				(Note 5)				(Note 5)	
Drain				(Note 5)				(Note 5)	
Thermowell									
Util. Con.									
RATING	RFLWN 300#			RFLWN 300#			f) Exchangers that are to be stacked shall be hydrotested stacked.		
Remarks	g) Concentration of CO2 and H2S in the liquid phase is 73 ppmw and 6 ppmw respectively.								
h) delete									
i) All category D welds shall be spot ultrasonic examined.									
j) Baffle to shell clearance shall be 4.8mm or less.									
k) EHT design shall use voltage of 277 VAC.									
l) Seller shall verify and guarantee thermal rating of the unit.									
m) Mass flow and duty will be split into two parallel trains.									
n) Exchangers shall be stacked two high.									
o) Minimum 20 pass lane seal rods.									



CUSTOMER	MEG Energy Corp.	REV	MADE BY	CHECKED BY	APPROVED BY	DATE
LOCATION	CANADA	0	-	-	-	07-01-2013
JOB NO.	511036	1	-	-	-	08-14-2013
SERVICE	Sales Oil / Glycol Exchanger					
ITEM NO.	3A-E-111 A to H (Max Duty Case)					

Total	8	Shells, Connected in	2	Parallel	4	Series Shells	Install	<input checked="" type="checkbox"/> Hor.	<input type="checkbox"/> Vert.	Size	1,143.0 ID - 8,534.0 L
Code	ASME Sec.VIII Div.1 (STAMP), TEMA, API680 TEMA Type BEU						TEMA Class	R		Effective Area	556.41 m <sup>2</sup> /Shell

### PERFORMANCE OF ONE BATTERY

				SHELL SIDE				TUBE SIDE			
				INLET		OUTLET		INLET		OUTLET	
Fluid Circulated				BP Frac Dilbit				TEG/Water (60%/40% wt)			
Total Fluid kg/hr				457483				589132			
Vapor	kg/hr	MW									
Liquid	kg/hr	MW		457483		457483		589132		589132	
Steam	kg/hr										
Water	kg/hr										
Noncondensable	kg/hr	MW									
Operating Temperature °C				126.00		52.70		40.00		75.00	
Operating Pressure kPaa				984.014				994.015			
Density	kg/m3	L / v		870.0		920		1078.00		1052.00	
Viscosity	cP	L / v		9.4400		127.91		4.6600		2.0900	
Thermal Conductivity	W/m·°C	L / v		0.1058		0.1193		0.3281		0.3371	
Specific Heat	kJ/kg·°C	L / v		2.1330		1.8500		3.2231		3.3481	
Latent Heat	kJ/kg										
Bubble / Dew Point °C				/		/		/		/	
Critical Press. / Temp. kPaa / °C				/		/		/		/	
Velocity m/sec				0.33				1.10			
Pressure Drop kPa.				Allow.	250.000	Calc.	175.705	Allow.	225.000	Calc.	212.167
Fouling Resistance m2·°C/kW				0.616				0.18			
Film Coefficient W/m2·K				339.86				1,678.93			
Overall Coefficient W/m2·K				Clean	270.88	Calc.		220.83	Design	155.44	
Heat Duty KW				14,112.00				LMTD	°C	MTD	27.2 °C


## CONSTRUCTION

Design Pressure		Design Temperature		kPa.G		°C		kPa.G		°C	
No. of Passes											
Tubes No.		/ Shell, Size		mm		Thickness (Min.) mm		( BWG : )		Length mm	
Shell		mm ID		Tube Pitch		mm		Layout angle °		Leffective - mm	
Baffles		Cross Baffle		ea / Shell, Type		Cut		% Dia.		Spacing c/c mm, End - mm	
pv²		Inlet Nozzle		2,162.91		Entrance		2,670.48		Outlet Nozzle	
								2,044.30		kg/m-sec2	
										Impingement plate	
Material		Tube		Shell & Cover						Channel & Cover	
		Tube Sheet		Baffle						Expansion Joint	
Estimated Weight		Empty Weight		kg		Bundle Weight		- kg		Full Water Weight	
Corrosion Allowance		Shell side		mm		Tube side		mm		Tube Joints :	
Insulation		Shell side		mm		Tube side		mm			
MEAN METAL		Temperature, °C		Pressure, kPa.G							
TEMPERATURE		Shell		Tube		Shell		Tube			
Normal Operating		-		-		-		-			
Startup		-		-		-		-			

[illegible]

CUSTOMER	MEG Energy Corp.				REV	MADE BY	CHECKED BY	APPROVED BY	DATE	
LOCATION	CANADA				0	-	-	-	07-01-2013	
JOB NO.	511036				1	-	-	-	08-14-2013	
SERVICE	Sales Oil / Glycol Exchanger									
ITEM NO.	3A-E-111 A to H (Min Duty Case)									
Total	8	Shells, Connected in	2	Parallel	4	Series Shells	Install	■ Hor. □ Vert.	Size	1,143.0 ID - 8,534.0 L
Code	ASME Sec.VIII Div.1 (STAMP), TEMA, API660 TEMA Type				BEU	TEMA Class	R	Effective Area	556.41	m²/Shell
PERFORMANCE OF ONE BATTERY										
		SHELL SIDE				TUBE SIDE				
		INLET		OUTLET		INLET		OUTLET		
Fluid Circulated		BP Frac Dilbit				TEG/Water (60%/40% wt)				
Total Fluid		kg/hr				404707				
Vapor		kg/hr				MW				
Liquid		kg/hr				MW				
Steam		kg/hr				404707				
Water		kg/hr				478370				
Noncondensable		kg/hr				MW				
Operating Temperature		°C				131.10				
Operating Pressure		kPaa				984.014				
Density		kg/m3				L / v				
Viscosity		cP				L / v				
Thermal Conductivity		W/m·°C				L / v				
Specific Heat		kJ/kg·°C				L / v				
Latent Heat		kJ/kg								
Bubble / Dew Point		°C				/				
Critical Press. / Temp.		kPaa / °C				/				
Velocity		m/sec				0.29				
Pressure Drop		kPa.				Allow. 250.000 Calc. 106.688				
Fouling Resistance		m2·°C/kW				0.616				
Film Coefficient		W/m2·K				349.98				
Overall Coefficient		W/m2·K				Clean 263.80 Calc. 215.96 Design 89.89				
Heat Duty		KW				11,459.00 LMTD °C MTD 38.2 °C				
CONSTRUCTION										
Design Pressure		Design Temperature				kPa.G		°C		
No. of Passes								kPa.G °C		
Tubes No.		/ Shell, Size		mm		Thickness (Min.) mm		( BWG : )		Length mm
Shell		mm ID		Tube Pitch		mm		Layout angle °		Effective - mm
Baffles Cross Baffle		ea / Shell, Type		Cut		% Dia.		Spacing c/c		mm End - mm
pv²		Inlet Nozzle 1,665.51		Entrance 2,057.22		Outlet Nozzle 1,587.74		kg/m-sec²		Impingement plate
Material		Tube		Shell & Cover		Baffle		Channel & Cover		Expansion Joint
Estimated Weight		Empty Weight		kg		Bundle Weight		kg		Full Water Weight kg
Corrosion Allowance		Shell side		mm		Tube side		mm		Tube Joints :
Insulation		Shell side		mm		Tube side		mm		
MEAN METAL		Temperature, °C				Pressure, kPa.G				
TEMPERATURE		Shell		Tube		Shell		Tube		
Normal Operating		-		-		-		-		
Startup		-		-		-		-		
NOZZLE		SHELL SIDE				TUBE SIDE				
		Tag		No		NPS		Remarks		
Inlet										
Outlet										
Vent										
Drain										
Thermowell										
Util. Con.										
RATING										
Remarks										

CUSTOMER	MEG Energy Corp.	REV	MADE BY	CHECKED BY	APPROVED BY	DATE
LOCATION	CANADA	0	-	-	-	07-01-2013
JOB NO.	511036	1	-	-	-	08-14-2013
SERVICE	Sales Oil / Glycol Exchanger					
ITEM NO.	3A-E-111 A to H					









## TUBULAR HEAT EXCHANGER

SHEET 6 OF 47

CUSTOMER	MEG Energy Corp.	REV	MADE BY	CHECKED BY	APPROVED BY	DATE
LOCATION	CANADA	0	-	-	-	07-01-2013
JOB NO.	511036	1	-	-	-	08-14-2013
SERVICE	Sales Oil / Glycol Exchanger					
ITEM NO.	3A-E-111 A to H					






**SEWON CELLONTECH****TUBULAR HEAT EXCHANGER**

SHEET 7 OF 47

CUSTOMER	MEG Energy Corp.	REV	MADE BY	CHECKED BY	APPROVED BY	DATE
LOCATION	CANADA	0	-	-	-	07-01-2013
JOB NO.	511036	1	-	-	-	08-14-2013
SERVICE	Sales Oil / Glycol Exchanger					
ITEM NO.	3A-E-111 A to H					

**3A-E-111**

1/5

I.D.-SHELL	1,143.0 ID	(BEU)
ALLOWABLE O.T.L	1105.8	mm
ACTUAL O.T.L	1121.3	mm
SEAL STRIP	N/A	Pairs
SEAL Rod	20 (Note 4)	ea

TOTAL 396U HOLES FOR 25.4 OD TUBES ON 31.75 SQUARE PITCH.  
4 PASSES. BAFFLE CUT SINGLE SEGM. 25.4% DIA.

Remarks

8/47

# **Thermal/Hydraulic/ Vibration** **Verification Report**

(Rev.1)

**3A-E-111 A to H**

**Client :** MEG Energy Corp.

**Project :** MEG Energy Christina Lake Regional Project  
Phase 3A-Central Plant Facilities

**Date :** 08-14-2013

## 3A-E-111 A to H (Max UA Case)

The Thermal/Hydraulic/Vibration calculations are performed by using HTRI Xist Ver. 6.00 SP3.

The process condition and the physical properties are based on Buyer data sheet.

For the design result ( the geometry data), please refer to the Equipment data sheet and Fabrication drawing.

### 1. Thermal and Hydraulic performance

- Thermal performance :	<u>17.93</u>	% Over - Design Case	-----	O.K.
- Pressure drop :				
Shell-side	<u>217.538</u>	<	250.000 kPa	----- O.K.
tube-side	<u>174.675</u>	<	200.000 kPa	----- O.K.

### 2. Vibration Analysis

- Fluidelastic instability :	characteristic values	<<	criteria	-----	O.K.
- Acoustic vibration :	characteristic values	<<	criteria	-----	O.K.
- Tube vibration check:	characteristic values	<<	criteria	-----	O.K.
- Bundle Entrance/Exit :	characteristic values	<<	criteria	-----	O.K.
- Shell Entrance /Exit:	characteristic values	<<	criteria	-----	O.K.

## 3A-E-111 A to H (Max UA Case) - Shell 1

Used Program : HTRI Xist Ver.6.00 SP.3 Vibration Analysis

VALUE TO BE CHECKED	Inlet	Center	U-Bend	RECOMMEND LIMIT	CONCLUSION
Unsupported span (mm)	1574.	972.	1401.	1881 (By TEMA)	O.K
Length / TEMA maximum span	0.837	0.517	0.579	< 1.0 TEMA	O.K
Fluidelastic Instability Check					
Baffle tip cross velocity ratio	0.0758	0.0659	0.0873	< 0.8	O.K
Ave. crossflow velocity ratio	0.0692	0.0601	0.0796	< 0.8	O.K
Acoustic Vibration Check					
Vortex shedding ratio	-	-	-	-	-
Tubulent buffeting ratio	-	-	-	-	-
Tube Vibration Check					
Vortex shedding ratio	0.062	0.140	0.135	< 0.5	O.K
Tubulent buffeting ratio	-	-	-	-	-
Bundle Entrance / Exit		Entrance	Exit		
Fluidelastic Instability ratio		0.108	0.214	< 0.8	O.K.
Vortex shedding ratio		0.311	0.292	< 0.5	O.K
Shell Entrance / Exit					
Velocity (m/sec)		1.69	1.06	< If velocity is exceed 2.07 / 2.05	O.K.
pv2 (kg/m-s <sup>2</sup> )		2509.52	0.00	< 5953 by TEMA	O.K.



11/49

Vibration Analysis				
Released to the following HTRI Member Company:				
sewon				
M.K.Park				
Xist Ver. 6.00 SP3 2013/08/16 9:55 SN: 1500213869				MEG Energy Units
Max.UA Case : Shell 1				
Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles				
1	Shellside condition	Sens. Liquid	(Level 2.3)	
2	Axial stress loading (MPa)	0.000	Added mass factor 1.517	
3	Beta	3.745		
4	Position In The Bundle	Inlet	Center	U-Bend
5	Length for natural frequency (mm)	1574.	972.	1401.
6	Length/TEMA maximum span (--)	0.837 *	0.517	0.579
7	Number of spans (--)	9	9	2
8	Tube natural frequency (Hz)	34.4	52.5	18.0 +
9	Shell acoustic frequency (Hz)			
10	Flow Velocities	Inlet	Center	U-Bend
11	Window parallel velocity (m/s)	0.55	0.54	0.54
12	Bundle crossflow velocity (m/s)	9.321e-2	0.21	0.11
13	Bundle/shell velocity (m/s)	0.12	0.27	0.14
14	Fluidelastic Instability Check	Inlet	Center	U-Bend
15	Log decrement HTRI	0.100	0.100	0.100
16	Critical velocity (m/s)	2.07	5.40	2.05
17	Baffle tip cross velocity ratio (--)	0.0758	0.0659	0.0873
18	Average crossflow velocity ratio (--)	0.0692	0.0601	0.0796
19	Acoustic Vibration Check	Inlet	Center	U-Bend
20	Vortex shedding ratio (--)			
21	Chen number (--)			
22	Turbulent buffeting ratio (--)			
23	Tube Vibration Check	Inlet	Center	U-Bend
24	Vortex shedding ratio (--)	0.062	0.140	0.135
25	Parallel flow amplitude (mm)	0.001	0.001	0.005
26	Crossflow amplitude (mm)	0.004	0.003	0.003
27	Tube gap (mm)	6.350	6.350	6.350
28	Crossflow RHO-V-SQ (kg/m-s2)	17.91	93.34	23.88
29	Bundle Entrance/Exit			
30	(analysis at first tube row)		Entrance	Exit
31	Fluidelastic instability ratio (--)		0.108	0.214
32	Vortex shedding ratio (--)		0.311	0.292
33	Crossflow amplitude (mm)		0.02362	0.05740
34	Crossflow velocity (m/s)		0.47	0.44
35	Tubesheet to inlet/outlet support (mm)		None	None
36	Shell Entrance/Exit Parameters		Entrance	Exit
37	Impingement plate		Yes	
38	Flow area (m2)		0.042	0.065
39	Velocity (m/s)		1.69	1.06
40	RHO-V-SQ (kg/m-s2)		2509.52	0.00
41	Shell type BEU	Baffle type	Single-Seg.	
42	Tube type Plain	Baffle layout	Perpend.	
43	Pitch ratio 1.2500	Tube diameter, (mm)	25.400	
44	Layout angle 45	Tube material	Carbon steel	
45	Number U-Bend supports 1	Supports/baffle space		
46	Program Messages			
47	+ Frequency ratios are based upon lowest natural or acoustic frequency			
48	* Items with asterisk exceed a conservative lower limit for vibration-free design. Review your case			
49	using the procedure described in Online Help; You may find that a vibration problem is unlikely.			
50				
51				
52				
53				

12/41

## 3A-E-111 A to H (Max UA Case) - Shell 2

Used Program : HTRI Xist Ver.6.00 SP.3 Vibration Analysis

VALUE TO BE CHECKED	U-Bend	Center	Outlet	RECOMMEND LIMIT	CONCLUSION
Unsupported span (mm)	1401.	972.	1574.	2420 (By TEMA)	O.K
Length / TEMA maximum span	0.579	0.517	0.837	< 1.0 TEMA	O.K
Fluidelastic Instability Check					
Baffle tip cross velocity ratio	0.0874	0.0653	0.0741	< 0.8	O.K
Ave. crossflow velocity ratio	0.0797	0.0595	0.0676	< 0.8	O.K
Acoustic Vibration Check					
Vortex shedding ratio	-	-	-	-	-
Tubulent buffeting ratio	-	-	-	-	-
Tube Vibration Check					
Vortex shedding ratio	0.135	0.138	0.060	< 0.5	O.K
Tubulent buffeting ratio	-	-	-	-	-
Bundle Entrance / Exit		Entrance	Exit		
Fluidelastic Instability ratio		0.000	0.096	< 0.8	O.K.
Vortex shedding ratio		0.555	0.272	> 0.5	Check Below
				Tube OD = 25.400	
				Tube gap = 6.350	
Crossflow amplitude (mm)		0.05698	0.01805	< 0.1 X Tube gap = 0.635 < 0.02 X Tube OD = 0.508	O.K.
Crossflow RHO-V-SQ (kg/m-s <sup>2</sup> )		23.83	17.24	< 5953 by TEMA	O.K.
Shell Entrance / Exit					
Velocity (m/sec)		6.735e-2	1.24	< If velocity is exceed 2.05 / 2.04	O.K.
pv2 (kg/m-s <sup>2</sup> )		0.00	1401.33	< 5953 by TEMA	O.K.

13/49

<b>Vibration Analysis</b> Released to the following HTRI Member Company: sewon M.K.Park				
Xist Ver. 6.00 SP3 2013/08/16 9:55 SN: 1500213869			MEG Energy Units	
Max.UA Case : Shell 2				
Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles				
1	Shellside condition	Sens. Liquid	(Level 2.3)	
2	Axial stress loading (MPa)	0.000	Added mass factor	1.517
3	Beta	3.745		
4	Position In The Bundle	U-Bend	Center	Outlet
5	Length for natural frequency (mm)	1401.	972.	1574.
6	Length/TEMA maximum span (---)	0.579	0.517	0.837 *
7	Number of spans (---)	2	9	9
8	Tube natural frequency (Hz)	18.1 +	52.5	34.3
9	Shell acoustic frequency (Hz)			
10	Flow Velocities	U-Bend	Center	Outlet
11	Window parallel velocity (m/s)	0.54	0.54	0.53
12	Bundle crossflow velocity (m/s)	0.11	0.21	8.982e-2
13	Bundle/shell velocity (m/s)	0.12	0.24	0.10
14	Fluidelastic Instability Check	U-Bend	Center	Outlet
15	Log decrement HTRI	0.100	0.100	0.100
16	Critical velocity (m/s)	2.05	5.36	2.04
17	Baffle tip cross velocity ratio (---)	0.0874	0.0653	0.0741
18	Average crossflow velocity ratio (---)	0.0797	0.0595	0.0676
19	Acoustic Vibration Check	U-Bend	Center	Outlet
20	Vortex shedding ratio (---)			
21	Chen number (---)			
22	Turbulent buffeting ratio (---)			
23	Tube Vibration Check	U-Bend	Center	Outlet
24	Vortex shedding ratio (---)	0.135	0.138	0.060
25	Parallel flow amplitude (mm)	0.005	0.001	0.001
26	Crossflow amplitude (mm)	0.003	0.003	0.004
27	Tube gap (mm)	6.350	6.350	6.350
28	Crossflow RHO-V-SQ (kg/m-s2)	23.83	91.66	17.24
29	Bundle Entrance/Exit		Entrance	Exit
30	(analysis at first tube row)			
31	Fluidelastic instability ratio (---)		0.000	0.096
32	Vortex shedding ratio (---)		0.555	0.272
33	Crossflow amplitude (mm)		0.05698	0.01805
34	Crossflow velocity (m/s)		0.44	0.41
35	Tubesheet to inlet/outlet support (mm)		None	None
36	Shell Entrance/Exit Parameters		Entrance	Exit
37	Impingement plate		No	
38	Flow area (m2)		1.026	0.055
39	Velocity (m/s)		6.735e-2	1.24
40	RHO-V-SQ (kg/m-s2)		0.00	1401.33
41	Shell type BEU	Baffle type	Single-Seg.	
42	Tube type Plain	Baffle layout	Perpend.	
43	Pitch ratio 1.2500	Tube diameter, (mm)	25.400	
44	Layout angle 45	Tube material	Carbon steel	
45	Number U-Bend supports 1	Supports/baffle space		
46	Program Messages			
47	+ Frequency ratios are based upon lowest natural or acoustic frequency			
48	* Items with asterisk exceed a conservative lower limit for vibration-free design. Review your case			
49	using the procedure described in Online Help; You may find that a vibration problem is unlikely.			
50				
51				
52				
53				



14/41

### 3A-E-111 A to H (Max UA Case) - Shell 3

Used Program : HTRI Xist Ver.6.00 SP.3 Vibration Analysis

VALUE TO BE CHECKED	Inlet	Center	U-Bend	RECOMMEND LIMIT	CONCLUSION
Unsupported span (mm)	1574.	972.	1401.	1881 (By TEMA)	O.K
Length / TEMA maximum span	0.837	0.517	0.579	< 1.0 TEMA	O.K
Fluidelastic Instability Check					
Baffle tip cross velocity ratio	0.0731	0.0638	0.0848	< 0.8	O.K
Ave. crossflow velocity ratio	0.0666	0.0582	0.0773	< 0.8	O.K
Acoustic Vibration Check					
Vortex shedding ratio	-	-	-	-	-
Tubulent buffeting ratio	-	-	-	-	-
Tube Vibration Check					
Vortex shedding ratio	0.059	0.135	0.130	< 0.5	O.K
Tubulent buffeting ratio	-	-	-	-	-
Bundle Entrance / Exit		Entrance	Exit		
Fluidelastic Instability ratio		0.106	0.210	< 0.8	O.K.
Vortex shedding ratio		0.301	0.285	< 0.5	O.K
Shell Entrance / Exit					
Velocity (m/sec)		1.63	1.03	< If velocity is exceed 2.05 / 2.04	O.K.
pv2 (kg/m-s2)		2420.99	0.00	< 5953 by TEMA	O.K.



15/47

Vibration Analysis				
Released to the following HTRI Member Company:				
sewon				
M.K.Park				
Xist Ver. 6.00 SP3 2013/08/16 9:55 SN: 1500213869			MEG Energy Units	
Max.UA Case : Shell 3				
Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles				
1	Shellside condition	Sens. Liquid	(Level 2.3)	
2	Axial stress loading (MPa)	0.000	Added mass factor	1.517
3	Beta	3.745		
4	Position In The Bundle	Inlet	Center	U-Bend
5	Length for natural frequency (mm)	1574.	972.	1401.
6	Length/TEMA maximum span (--)	0.837 *	0.517	0.579
7	Number of spans (--)	9	9	2
8	Tube natural frequency (Hz)	34.4	52.5	18.1 +
9	Shell acoustic frequency (Hz)			
10	Flow Velocities	Inlet	Center	U-Bend
11	Window parallel velocity (m/s)	0.53	0.53	0.53
12	Bundle crossflow velocity (m/s)	8.879e-2	0.20	0.10
13	Bundle/shell velocity (m/s)	7.785e-2	0.18	9.002e-2
14	Fluidelastic Instability Check	Inlet	Center	U-Bend
15	Log decrement HTRI	0.100	0.100	0.100
16	Critical velocity (m/s)	2.05	5.35	2.04
17	Baffle tip cross velocity ratio (--)	0.0731	0.0638	0.0848
18	Average crossflow velocity ratio (--)	0.0666	0.0582	0.0773
19	Acoustic Vibration Check	Inlet	Center	U-Bend
20	Vortex shedding ratio (--)			
21	Chen number (--)			
22	Turbulent buffeting ratio (--)			
23	Tube Vibration Check	Inlet	Center	U-Bend
24	Vortex shedding ratio (--)	0.059	0.135	0.130
25	Parallel flow amplitude (mm)	0.001	0.001	0.005
26	Crossflow amplitude (mm)	0.003	0.003	0.003
27	Tube gap (mm)	6.350	6.350	6.350
28	Crossflow RHO-V-SQ (kg/m-s2)	16.84	88.48	22.74
29	Bundle Entrance/Exit			
30	(analysis at first tube row)		Entrance	Exit
31	Fluidelastic instability ratio (--)		0.106	0.210
32	Vortex shedding ratio (--)		0.301	0.285
33	Crossflow amplitude (mm)		0.02233	0.05509
34	Crossflow velocity (m/s)		0.45	0.43
35	Tubesheet to inlet/outlet support (mm)		None	None
36	Shell Entrance/Exit Parameters		Entrance	Exit
37	Impingement plate		Yes	
38	Flow area (m2)		0.042	0.065
39	Velocity (m/s)		1.63	1.03
40	RHO-V-SQ (kg/m-s2)		2420.99	0.00
41	Shell type BEU	Baffle type		Single-Seg.
42	Tube type Plain	Baffle layout		Perpend.
43	Pitch ratio 1.2500	Tube diameter, (mm)		25.400
44	Layout angle 45	Tube material		Carbon steel
45	Number U-Bend supports 1	Supports/baffle space		
46	Program Messages			
47	+ Frequency ratios are based upon lowest natural or acoustic frequency			
48	* Items with asterisk exceed a conservative lower limit for vibration-free design. Review your case			
49	using the procedure described in Online Help; You may find that a vibration problem is unlikely.			
50				
51				
52				
53				

16/44

## 3A-E-111 A to H (Max UA Case) - Shell 4

Used Program : HTRI Xist Ver.6.00 SP.3 Vibration Analysis

VALUE TO BE CHECKED	U-Bend	Center	Outlet	RECOMMEND LIMIT	CONCLUSION
Unsupported span (mm)	1401.	972.	1574.	2420 (By TEMA)	O.K
Length / TEMA maximum span	0.579	0.517	0.837	< 1.0 TEMA	O.K
Fluidelastic Instability Check					
Baffle tip cross velocity ratio	0.0802	0.0601	0.0684	< 0.8	O.K
Ave. crossflow velocity ratio	0.0731	0.0548	0.0624	< 0.8	O.K
Acoustic Vibration Check					
Vortex shedding ratio	-	-	-	-	-
Tubulent buffeting ratio	-	-	-	-	-
Tube Vibration Check					
Vortex shedding ratio	0.123	0.127	0.055	< 0.5	O.K
Tubulent buffeting ratio	-	-	-	-	-
Bundle Entrance / Exit		Entrance	Exit		
Fluidelastic Instability ratio		0.000	0.095	< 0.8	O.K.
Vortex shedding ratio		0.542	0.268	> 0.5	Check Below
				Tube OD = 25.400	
				Tube gap = 6.350	
Crossflow amplitude (mm)		0.05491	0.01757	< 0.1 X Tube gap = 0.635 < 0.02 X Tube OD = 0.508	O.K.
Crossflow RHO-V-SQ (kg/m-s <sup>2</sup> )		20.31	14.81	< 5953 by TEMA	O.K.
Shell Entrance / Exit					
Velocity (m/sec)		6.575e-2	1.22	< If velocity is exceed 2.04 / 2.03	O.K.
pv2 (kg/m-s <sup>2</sup> )		0.00	1378.96	< 5953 by TEMA	O.K.

17/47

# Vibration Analysis

Released to the following HTRI Member Company:

sewon  
M.K.Park

Xist Ver. 6.00 SP3 2013/08/16 9:55 SN: 1500213869

MEG Energy Units

Max.UA Case : Shell 4

Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles

1	Shellside condition		Sens. Liquid	(Level 2.3)	
2	Axial stress loading	(MPa)	0.000	Added mass factor	1.517
3	Beta		3.745		
4	Position In The Bundle		U-Bend	Center	Outlet
5	Length for natural frequency	(mm)	1401.	972.	1574.
6	Length/TEMA maximum span	(--)	0.579	0.517	0.837 *
7	Number of spans	(--)	2	9	9
8	Tube natural frequency	(Hz)	18.1 +	52.5	34.4
9	Shell acoustic frequency	(Hz)			
10	Flow Velocities		U-Bend	Center	Outlet
11	Window parallel velocity	(m/s)	0.53	0.53	0.53
12	Bundle crossflow velocity	(m/s)	9.705e-2	0.19	8.259e-2
13	Bundle/shell velocity	(m/s)	8.063e-2	0.16	6.862e-2
14	Fluidelastic Instability Check		U-Bend	Center	Outlet
15	Log decrement	HTRI	0.100	0.100	0.100
16	Critical velocity	(m/s)	2.04	5.33	2.03
17	Baffle tip cross velocity ratio	(--)	0.0802	0.0601	0.0684
18	Average crossflow velocity ratio	(--)	0.0731	0.0548	0.0624
19	Acoustic Vibration Check		U-Bend	Center	Outlet
20	Vortex shedding ratio	(--)			
21	Chen number	(--)			
22	Turbulent buffeting ratio	(--)			
23	Tube Vibration Check		U-Bend	Center	Outlet
24	Vortex shedding ratio	(--)	0.123	0.127	0.055
25	Parallel flow amplitude	(mm)	0.005	0.001	0.001
26	Crossflow amplitude	(mm)	0.003	0.002	0.003
27	Tube gap	(mm)	6.350	6.350	6.350
28	Crossflow RHO-V-SQ	(kg/m-s2)	20.31	78.48	14.81
29	Bundle Entrance/Exit			Entrance	Exit
30	(analysis at first tube row)				
31	Fluidelastic instability ratio	(--)		0.000	0.095
32	Vortex shedding ratio	(--)		0.542	0.268
33	Crossflow amplitude	(mm)		0.05491	0.01757
34	Crossflow velocity	(m/s)		0.43	0.40
35	Tubesheet to inlet/outlet support	(mm)		None	None
36	Shell Entrance/Exit Parameters			Entrance	Exit
37	Impingement plate			No	
38	Flow area	(m2)		1.026	0.055
39	Velocity	(m/s)		6.575e-2	1.22
40	RHO-V-SQ	(kg/m-s2)		0.00	1378.96
41	Shell type	BEU	Baffle type		Single-Seg.
42	Tube type	Plain	Baffle layout		Perpend.
43	Pitch ratio	1.2500	Tube diameter, (mm)		25.400
44	Layout angle	45	Tube material		Carbon steel
45	Number U-Bend supports	1	Supports/baffle space		

## Program Messages

- 47 + Frequency ratios are based upon lowest natural or acoustic frequency
- 48 \* Items with asterisk exceed a conservative lower limit for vibration-free design. Review your case
- 49 using the procedure described in Online Help; You may find that a vibration problem is unlikely.

50  
51  
52  
53






18/41

Final Results									
Released to the following HTRI Member Company:									
sewon									
M.K.Park									
Xist Ver. 6.00 SP3 2013/08/16 9:55 SN: 1500213869					MEG Energy Units				
Max.UA Case : Shell 1									
Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles									
1	Process Data		Hot Shellside		Cold Tubeside		Shellside Performance		
2	Fluid name	BP Frac Dilbit		TEG/Water (60%/40% wt)		Nom vel, X-flow/window 0.41 / 0.55			
3	Fluid condition	Sens. Liquid		Sens. Liquid		Flow fractions for heat transfer 0.662			
4	Total flow rate	(kg/hr)	444696	527298		A=0.0028 B=0.6030 C=0.0402 E=0.1911 F=0.1628			
5	Weight fraction vapor, In/Out	(-)	0.000	0.000	0.000				
6	Temperature, In/Out	(Deg C)	117.90	90.09	60.26				
7	Temperature, Average/Skin	(Deg C)	104.00	79.60	67.63				
8	Wall temperature, Min/Max	(Deg C)	68.67	83.21	68.48				
9	Pressure, In/Average	(kPa)	984.014	968.540	860.223				
10	Pressure drop, Total/Allowed	(kPa)	30.949	250.000	40.873				
11	Velocity, Mid/Max allow	(m/s)	0.32		0.99				
12	Mole fraction inert	(-)							
13	Average film coef.	(W/m2-K)		340.88					
14	Heat transfer safety factor	(-)		1.000					
15	Fouling resistance	(m2-K/W)		0.000616					
16	Overall Performance Data								
17	Overall coef., Req'd/Clean/Actual	(W/m2-K)	190.69	/	279.40	/	226.71		
18	Heat duty, Calculated/Specified	(kW)	5379.	/					
19	Effective overall temperature difference	(Deg C)	33.8						
20	EMTD = (MTD) * (DELTA) * (F/G/H)	(Deg C)	34.16	*	0.9895	*	1.0000		
21									
22									
23	See Runtime Messages Report for warnings.								
24	Exchanger Fluid Volumes								
25	Approximate shellside (L)	5023.9							
26	Approximate tubeside (L)	4515.8							
27	Shell Construction Information								
28	TEMA shell type	BEU	Shell ID	(mm)	1143.00				
29	Shells Series	1 Parallel 2	Total area	(m2)	1125.71				
30	Passes Shell	1 Tube 4	Eff. area	(m2/shell)	556.411				
31	Shell orientation angle (deg)	0.00							
32	Impingement present	Circular plate	Impingement diameter/nozzle	1.1					
33	Pairs seal strips	0	Passlane seal rods (mm)	25.400	No. 20				
34	Shell expansion joint	No	Full support at U-Bend	No					
35	Weight estimation Wet/Dry/Bundle	26898.8 /	17365.6 /	10099.0 (kg/shell)					
36	Baffle Information								
37	Type	Perpend. Single-Seg.	Baffle cut (% dia)	24.50					
38	Crosspasses/shellpass	17	No. (Pct Area)	(mm) to C.L.					
39	Central spacing	(mm)	486.000	1	20.45	291.465			
40	Inlet spacing	(mm)	1088.00	2	0.00	0.000			
41	Outlet spacing	(mm)	932.000						
42	Baffle thickness	(mm)	12.700						
43	Tube Information								
44	Tube type	Plain	Tubecount per shell	792					
45	Length to tangent	(mm)	8534.	Pct tubes removed (both)	4.42				
46	Effective length	(mm)	8804.	Outside diameter	(mm)	25.400			
47	Total tubesheet	(mm)	102.000	Wall thickness	(mm)	2.110			
48	Area ratio	(out/in)	1.1992	Pitch (mm)	31.7500	Ratio	1.2500		
49	Tube metal	Carbon steel	Tube pattern (deg)	45					
50	Shellside Heat Transfer Corrections								
51	Total	Beta	Gamma	End	Fin				
52	0.919	0.919	1.000	0.954	1.000				
53	Pressure Drops (Percent of Total)								
54	Cross	Window	Ends	Nozzle	Shell	Tube			
55	65.29	16.63	5.79	Inlet	10.69	7.82			
56	MOMENTUM	0.00	Outlet	1.61	5.03				
57	Two-Phase Parameters								
58	Method	Inlet	Center	Outlet	Mix F				
59	H. T. Parameters								
60	Overall wall correction	Shell			Tube				
61	Midpoint	Prandtl no.	443.63	23.98					
62	Midpoint	Reynolds no.	347	9198					
63	Bundle inlet	Reynolds no.	260	7802					
64	Bundle outlet	Reynolds no.	126	10581					
65	Fouling layer	(mm)							
66	Thermal Resistance								
67	Shell	Tube	Fouling	Metal	Over Des				
68	66.51	13.72	18.86	0.92	18.89				
69	Total fouling resistance	8.313e-4							
70	Differential resistance	8.333e-4							
71	Shell Nozzles								
72	Inlet at channel end-Yes	Inlet			Outlet	Liquid			
73	Number at each position	1			1	0			
74	Diameter	(mm)	242.875	242.875					
75	Velocity	(m/s)	1.52	1.49					
76	Pressure drop	(kPa)	3.308	0.497					
77	Height under nozzle	(mm)	61.187	1143.00					
78	Nozzle R-V-SQ	(kg/m-s2)	2031.69	1988.43					
79	Shell ent.	(kg/m-s2)	2509.52	0.00					
80	Tube Nozzle								
81	Diameter	(mm)	193.675	193.675					
82	Velocity	(m/s)	2.34	2.36					
83	Pressure drop	(kPa)	3.198	2.066					
84	Nozzle R-V-SQ	(kg/m-s2)	5813.69	5874.22					
85	Annular Distributor								
86	Length	(mm)							
87	Height	(mm)							
88	Slot area	(mm2)							
89	Diametral Clearances (mm)								
90	Baffle-to-shell	Bundle-to-shell	Tube-to-baffle						
91	6.3500	21.7000	0.3969						



19/41


Final Results									
Released to the following HTRI Member Company:									
sewon									
M.K.Park									
Xist Ver. 6.00 SP3 2013/08/16 9:55 SN: 1500213869					MEG Energy Units				
Max.UA Case : Shell 2									
Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles									
Process Data		Hot Shellside		Cold Tubeside		Shellside Performance			
Fluid name		BP Frac Dilbit		TEG/Water (60%/40% wt)		Nom vel, X-flow/window 0.41 / 0.54			
Fluid condition		Sens. Liquid		Sens. Liquid		Flow fractions for heat transfer 0.658			
Total flow rate (kg/hr)		444696		527298		A=0.0018 B=0.6024 C=0.0352 E=0.2051 F=0.1554			
Weight fraction vapor, In/Out (--)		0.000		0.000					
Temperature, In/Out (Deg C)		90.09 71.17		50.62 60.26					
Temperature, Average/Skin (Deg C)		80.63 63.84		55.44 59.54					
Wall temperature, Min/Max (Deg C)		54.66 65.10		54.52 64.82					
Pressure, In/Average (kPa)		953.080 932.753		903.144 881.681					
Pressure drop, Total/Allowed (kPa)		40.653 250.000		42.927 200.000					
Velocity, Mid/Max allow (m/s)		0.32		0.98					
Mole fraction inert (--)									
Average film coef. (W/m2-K)		314.98		1555.75					
Heat transfer safety factor (--)		1.000		1.000					
Fouling resistance (m2-K/W)		0.000616		0.000180					
Overall Performance Data					Shellside Heat Transfer Corrections				
Overall coef., Req'd/Clean/Actual (W/m2-K) 177.51 / 251.23 / 207.80					Total 0.920 Beta 0.920 Gamma 1.000 End 0.957 Fin 1.000				
Heat duty, Calculated/Specified (kW) 3470. /									
Effective overall temperature difference (Deg C) 23.4									
EMTD = (MTD) * (DELTA) * (F/G/H) (Deg C) 23.71 * 0.9878 * 1.0000									
See Runtime Messages Report for warnings.					Pressure Drops (Percent of Total)				
					Cross 69.84 Window 16.12 Ends 6.60 Nozzle Inlet 2.45 Shell 7.40				
					MOMENTUM 0.00 Outlet 5.00 4.74				
Exchanger Fluid Volumes					Two-Phase Parameters				
Approximate shellside (L) 5023.9					Method Inlet Center Outlet Mix F				
Approximate tubeside (L) 4515.8									
Shell Construction Information					H. T. Parameters				
TEMA shell type BEU Shell ID (mm) 1143.00					Overall wall correction 0.876 1.004				
Shells Series 1 Parallel 2 Total area (m2) 1125.71					Midpoint Prandtl no. 863.31 31.39				
Passes Shell 1 Tube 4 Eff. area (m2/shell) 556.411					Midpoint Reynolds no. 165 6999				
Shell orientation angle (deg) 0.00					Bundle inlet Reynolds no. 125 6213				
Impingement present No					Bundle outlet Reynolds no. 51 7733				
Pairs seal strips 0 Passiane seal rods (mm) 25.400 No. 20					Fouling layer (mm)				
Shell expansion joint No Full support at U-Bend No									
Weight estimation Wet/Dry/Bundle 26909.4 / 17376.3 / 10109.7 (kg/shell)									
Baffle Information					Thermal Resistance				
Type Perpend. Single-Seg. Baffle cut (% dia) 24.50					Shell 65.97 Tube 15.92 Fouling 17.29 Metal 0.83 Over Des 17.07				
Crosspasses/shellpass 17 No. (Pct Area) (mm) to C.L					Total fouling resistance 8.313e-4				
Central spacing (mm) 486.000 1 20.35 291.465					Differential resistance 8.212e-4				
Inlet spacing (mm) 932.000 2 0.00 0.000									
Outlet spacing (mm) 1088.00									
Baffle thickness (mm) 12.700									
Tube Information					Shell Nozzles				
Tube type Plain Tubecount per shell 792					Inlet at channel end-No Inlet Outlet Outlet				
Length to tangent (mm) 8534. Pct tubes removed (both) 3.91					Number at each position 1 1 0				
Effective length (mm) 8804. Outside diameter (mm) 25.400					Diameter (mm) 242.875 242.875				
Total tubesheet (mm) 102.000 Wall thickness (mm) 2.110					Velocity (m/s) 1.49 1.47				
Area ratio (out/in) 1.1992 Pitch (mm) 31.7500 Ratio 1.2500					Pressure drop (kPa) 0.994 2.032				
Tube metal Carbon steel Tube pattern (deg) 45					Height under nozzle (mm) 1143.00 61.187				
					Nozzle R-V-SQ (kg/m-s2) 1988.44 1960.02				
					Shell ent. (kg/m-s2) 0.00 1401.33				
Annular Distributor					Tube Nozzle				
Length (mm)					Inlet Outlet Liquid				
Height (mm)					RADIAL RADIAL Outlet				
Slot area (mm2)					Diameter (mm) 193.675 193.675				
					Velocity (m/s) 2.32 2.34				
					Pressure drop (kPa) 3.177 2.035				
					Nozzle R-V-SQ (kg/m-s2) 5774.80 5813.70				
Diаметral Clearances (mm)					Annular Distributor Inlet Outlet				
Baffle-to-shell 6.3500 Bundle-to-shell 21.7000 Tube-to-baffle 0.3969					Length (mm)				
					Height (mm)				
					Slot area (mm2)				

20/47

Final Results									
Released to the following HTRI Member Company:									
sewon									
M.K.Park									
Xist Ver. 6.00 SP3 2013/08/16 9:55 SN: 1500213869					MEG Energy Units				
Max.UA Case : Shell 3									
Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles									
1	<b>Process Data</b>		<b>Hot Shellside</b>		<b>Cold Tubeside</b>		<b>Shellside Performance</b>		
2	Fluid name	BP Frac Dilbit		TEG/Water (60%/40% wt)		Nom vel, X-flow/window 0.40 / 0.53			
3	Fluid condition	Sens. Liquid		Sens. Liquid		Flow fractions for heat transfer 0.651			
4	Total flow rate	(kg/hr)	444696	527298		A=0.0014 B=0.5955 C=0.0270 E=0.2179 F=0.1582			
5	Weight fraction vapor, In/Out	(--)	0.000	0.000	0.000				
6	Temperature, In/Out	(Deg C)	71.17	58.47	44.30				
7	Temperature, Average/Skin	(Deg C)	64.82	53.48	47.46				
8	Wall temperature, Min/Max	(Deg C)	48.75	55.21	48.67				
9	Pressure, In/Average	(kPa)	912.440	881.711	947.899				
10	Pressure drop, Total/Allowed	(kPa)	61.459	250.000	44.759				
11	Velocity, Mid/Max allow	(m/s)	0.31		0.98				
12	Mole fraction inert	(--)							
13	Average film coef.	(W/m2-K)		305.59	1300.78				
14	Heat transfer safety factor	(--)		1.000	1.000				
15	Fouling resistance	(m2-K/W)		0.000616	0.000180				
16	<b>Overall Performance Data</b>								
17	Overall coef., Req'd/Clean/Actual	(W/m2-K)	166.89	/	236.21	/	197.42		
18	Heat duty, Calculated/Specified	(kW)	2254.	/					
19	Effective overall temperature difference	(Deg C)	16.2						
20	EMTD = (MTD) * (DELTA) * (F/G/H)	(Deg C)	16.44	*	0.9847	*	1.0000		
21									
22									
23	See Runtime Messages Report for								
24	warnings.								
25									
26	<b>Exchanger Fluid Volumes</b>								
27	Approximate shellside (L)	5023.9							
28	Approximate tubeside (L)	4515.8							
29	<b>Shell Construction Information</b>								
30	TEMA shell type	BEU	Shell ID	(mm)	1143.00				
31	Shells Series	1 Parallel 2	Total area	(m2)	1125.71				
32	Passes Shell	1 Tube 4	Eff. area	(m2/shell)	556.411				
33	Shell orientation angle (deg)	0.00							
34	Impingement present	Circular plate	Impingement diameter/nozzle	1.1					
35	Pairs seal strips	0	Passlane seal rods (mm)	25.400	No. 20				
36	Shell expansion joint	No	Full support at U-Bend	No					
37	Weight estimation Wet/Dry/Bundle	26916.5 / 17383.4 / 10116.8	(kg/shell)						
38									
39	<b>Baffle Information</b>								
40	Type	Perpend. Single-Seg.	Baffle cut (% dia)	24.50					
41	Crosspasses/shellpass	17	No. (Pct Area)	(mm) to C.L.					
42	Central spacing	(mm) 486.000	1	20.45	291.465				
43	Inlet spacing	(mm) 1088.00	2	0.00	0.000				
44	Outlet spacing	(mm) 932.000							
45	Baffle thickness	(mm) 12.700							
46									
47									
48	<b>Tube Information</b>								
49	Tube type	Plain	Tube count per shell	792					
50	Length to tangent	(mm) 8534.	Pct tubes removed (both)	4.42					
51	Effective length	(mm) 8604.	Outside diameter	(mm) 25.400					
52	Total tubesheet	(mm) 102.000	Wall thickness	(mm) 2.110					
53	Area ratio	(out/in) 1.1992	Pitch (mm)	31.7500	Ratio	1.2500			
54	Tube metal	Carbon steel	Tube pattern (deg)	45					
					<b>Shell Nozzles</b>				
					Inlet Outlet Liquid Outlet				
					Inlet at channel end-Yes 1 1 0				
					Number at each position				
					Diameter (mm) 242.875 242.875				
					Velocity (m/s) 1.47 1.46				
					Pressure drop (kPa) 4.188 0.485				
					Height under nozzle (mm) 61.187 1143.00				
					Nozzle R-V-SQ (kg/m-s2) 1960.02 1941.40				
					Shell ent. (kg/m-s2) 2420.99 0.00				
					<b>Tube Nozzle</b>				
					Inlet Outlet Liquid Outlet				
					Diameter (mm) 193.675 193.675				
					Velocity (m/s) 2.31 2.32				
					Pressure drop (kPa) 3.163 2.021				
					Nozzle R-V-SQ (kg/m-s2) 5749.59 5774.80				
					<b>Annular Distributor</b>				
					Inlet Outlet				
					Length (mm)				
					Height (mm)				
					Slot area (mm2)				
					<b>Diametral Clearances (mm)</b>				
					Baffle-to-shell Bundle-to-shell Tube-to-baffle				
					6.3500 21.7000 0.3969				



21/47

Final Results																		
Released to the following HTRI Member Company:																		
sewon																		
M.K.Park																		
Xist Ver. 6.00 SP3 2013/08/16 9:55 SN: 1500213869					MEG Energy Units													
Max.UA Case : Shell 4																		
Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles																		
1	Process Data			Hot Shellside		Cold Tubeside		Shellside Performance										
2	Fluid name	BP Frac Dilbit			TEG/Water (60%/40% wt)		Nom vel, X-flow/window 0.40 / 0.53											
3	Fluid condition	Sens. Liquid			Sens. Liquid		Flow fractions for heat transfer 0.623											
4	Total flow rate	(kg/hr)	444696		527298		A=0.0013 B=0.5629 C=0.0242 E=0.2380 F=0.1736											
5	Weight fraction vapor, In/Out	(--)	0.000	0.000	0.000	0.000												
6	Temperature, In/Out	(Deg C)	58.47	49.70	40.00	44.31												
7	Temperature, Average/Skin	(Deg C)	54.08	46.54	42.15	44.62												
8	Wall temperature, Min/Max	(Deg C)	42.35	47.21	42.29	47.09												
9	Pressure, In/Average	(kPa)	850.993	808.755	994.015	970.957												
10	Pressure drop, Total/Allowed	(kPa)	84.477	250.000	46.116	200.000												
11	Velocity, Mid/Max allow	(m/s)	0.29		0.98													
12	Mole fraction inert	(--)																
13	Average film coef.	(W/m2-K)		312.61		1129.15												
14	Heat transfer safety factor	(--)		1.000		1.000												
15	Fouling resistance	(m2-K/W)		0.000616		0.000180												
16	Overall Performance Data																	
17	Overall coef., Req'd/Clean/Actual	(W/m2-K)	165.98	/	232.57	/	194.87											
18	Heat duty, Calculated/Specified	(kW)	1527.	/														
19	Effective overall temperature difference	(Deg C)	11.0															
20	EMTD = (MTD) * (DELTA) * (F/G/H)	(Deg C)	11.27	*	0.9781	*	1.0000											
21																		
22																		
23	See Runtime Messages Report for																	
24	warnings.																	
25																		
26	Exchanger Fluid Volumes																	
27	Approximate shellside (L)		5023.9															
28	Approximate tubeside (L)		4515.8															
29	Shell Construction Information																	
30	TEMA shell type	BEU	Shell ID	(mm)	1143.00													
31	Shells Series	1 Parallel 2	Total area	(m2)	1125.71													
32	Passes Shell	1 Tube 4	Eff. area	(m2/shell)	556.411													
33	Shell orientation angle (deg)	0.00																
34	Impingement present	No																
35	Pairs seal strips	0	Passlane seal rods (mm)	25.400	No. 20													
36	Shell expansion joint	No	Full support at U-Bend	No														
37	Weight estimation Wet/Dry/Bundle		26921.2 /	17388.1 /	10121.5 (kg/shell)													
38																		
39	Baffle Information																	
40	Type	Perpend. Single-Seg.	Baffle cut (% dia)	24.50														
41	Crosspasses/shellpass	17	No. (Pct Area)	(mm) to C.L														
42	Central spacing	(mm)	486.000	1	20.35	291.465												
43	Inlet spacing	(mm)	932.000	2	0.00	0.000												
44	Outlet spacing	(mm)	1088.00															
45	Baffle thickness	(mm)	12.700															
46																		
47																		
48	Tube Information																	
49	Tube type	Plain	Tube count per shell	792														
50	Length to tangent	(mm)	8534.	Pct tubes removed (both)	3.91													
51	Effective length	(mm)	8804.	Outside diameter	(mm)	25.400												
52	Total tubesheet	(mm)	102.000	Wall thickness	(mm)	2.110												
53	Area ratio	(out/in)	1.1992	Pitch (mm)	31.7500	Ratio	1.2500											
54	Tube metal	Carbon steel	Tube pattern (deg)	45														
						Shellside Heat Transfer Corrections												
						Total	Beta	Gamma	End									
						0.917	0.920	0.997	0.966									
						Fin												
						1.000												
						Pressure Drops (Percent of Total)												
						Cross	Window	Ends	Nozzle									
						74.13	14.30	7.73	Inlet									
						MOMENTUM		0.00	Outlet									
								2.68	4.36									
						Two-Phase Parameters												
						Method	Inlet	Center	Outlet									
						Mix F												
						H. T. Parameters												
								Shell	Tube									
						Overall wall correction		0.937	1.003									
						Midpoint	Prandtl no.	2532.88	43.26									
						Midpoint	Reynolds no.	48	5057									
						Bundle inlet	Reynolds no.	32	4776									
						Bundle outlet	Reynolds no.	17	5310									
						Fouling layer (mm)												
						Thermal Resistance												
						Shell	Tube	Fouling	Metal									
						62.34	20.70	16.21	0.76									
						Over Des		17.40										
						Total fouling resistance		8.313e-4										
						Differential resistance		8.93e-4										
						Shell Nozzles												
						Inlet at channel end-No	Inlet	Outlet	Liquid									
						Number at each position	1	1	0									
						Diameter	(mm)	242.875	242.875									
						Velocity	(m/s)	1.46	1.45									
						Pressure drop	(kPa)	0.971	2.268									
						Height under nozzle	(mm)	1143.00	61.187									
						Nozzle R-V-SQ	(kg/m-s2)	1941.40	1928.73									
						Shell ent.	(kg/m-s2)	0.00	1378.96									
						Tube Nozzle												
						Diameter	(mm)	193.675	193.675									
						Velocity	(m/s)	2.31	2.31									
						Pressure drop	(kPa)	3.153	2.013									
						Nozzle R-V-SQ	(kg/m-s2)	5732.54	5749.60									
						Annular Distributor												
						Length	(mm)											
						Height	(mm)											
						Slot area	(mm2)											
						Diametral Clearances (mm)												
						Baffle-to-shell	Bundle-to-shell	Tube-to-baffle										
						6.3500	21.7000	0.3969										

## 3A-E-111 A to H (Max Duty Case)

The Thermal/Hydraulic/Vibration calculations are performed by using HTRI Xist Ver. 6.00 SP3.

The process condition and the physical properties are based on Buyer data sheet.

For the design result ( the geometry data), please refer to the Equipment data sheet and Fabrication drawing.

### 1. Thermal and Hydraulic performance

- Thermal performance :	<u>42.07</u>	% Over - Design Case	-----	O.K.
- Pressure drop :				
Shell-side	<u>175.705</u>	<	250.000 kPa	----- O.K
tube-side	<u>212.167</u>	<	225.000 kPa	----- O.K

### 2. Vibration Analysis

- Fluidelastic instability :	characteristic values	<<	criteria	-----	O.K.
- Acoustic vibration :	characteristic values	<<	criteria	-----	O.K.
- Tube vibration check:	characteristic values	<<	criteria	-----	O.K.
- Bundle Entrance/Exit :	characteristic values	<<	criteria	-----	O.K.
- Shell Entrance /Exit:	characteristic values	<<	criteria	-----	O.K.



23/41

### 3A-E-111 A to H (Max Duty Case) - Shell 1

Used Program : HTRI Xist Ver.6.00 SP.3 Vibration Analysis

VALUE TO BE CHECKED	Inlet	Center	U-Bend	RECOMMEND LIMIT	CONCLUSION
Unsupported span (mm)	1574.	972.	1401.	1881 (By TEMA)	O.K
Length / TEMA maximum span	0.837	0.517	0.579	< 1.0 TEMA	O.K
Fluidelastic Instability Check					
Baffle tip cross velocity ratio	0.0795	0.0690	0.0914	< 0.8	O.K
Ave. crossflow velocity ratio	0.0725	0.0629	0.0834	< 0.8	O.K
Acoustic Vibration Check					
Vortex shedding ratio	-	-	-	-	-
Turbulent buffeting ratio	-	-	-	-	-
Tube Vibration Check					
Vortex shedding ratio	0.065	0.147	0.142	< 0.5	O.K
Turbulent buffeting ratio	-	-	-	-	-
Bundle Entrance / Exit		Entrance	Exit		
Fluidelastic Instability ratio		0.112	0.221	< 0.8	O.K.
Vortex shedding ratio		0.322	0.301	< 0.5	O.K
Shell Entrance / Exit					
Velocity (m/sec)		1.75	1.09	< If velocity is exceed 2.07 / 2.06	O.K.
pv2 (kg/m-s2)		2670.48	0.00	< 5953 by TEMA	O.K.

24/47

Vibration Analysis				
Released to the following HTRI Member Company:				
sewon M.K.Park				
Xist Ver. 6.00 SP3 2013/08/16 10:00 SN: 1500213869			MEG Energy Units	
Max.Duty Case : Shell 1				
Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles				
1	Shellside condition	Sens. Liquid	(Level 2.3)	
2	Axial stress loading (MPa)	0.000	Added mass factor 1.517	
3	Beta	3.745		
4	Position in The Bundle	Inlet	Center	U-Bend
5	Length for natural frequency (mm)	1574.	972.	1401.
6	Length/TEMA maximum span (--)	0.837 *	0.517	0.579
7	Number of spans (--)	9	9	2
8	Tube natural frequency (Hz)	34.4	52.5	18.0 +
9	Shell acoustic frequency (Hz)			
10	Flow Velocities	Inlet	Center	U-Bend
11	Window parallel velocity (m/s)	0.57	0.56	0.56
12	Bundle crossflow velocity (m/s)	9.781e-2	0.22	0.11
13	Bundle/shell velocity (m/s)	0.13	0.29	0.15
14	Fluidelastic Instability Check	Inlet	Center	U-Bend
15	Log decrement HTRI	0.100	0.100	0.100
16	Critical velocity (m/s)	2.07	5.41	2.06
17	Baffle tip cross velocity ratio (--)	0.0795	0.0690	0.0914
18	Average crossflow velocity ratio (--)	0.0725	0.0629	0.0834
19	Acoustic Vibration Check	Inlet	Center	U-Bend
20	Vortex shedding ratio (--)			
21	Chen number (--)			
22	Turbulent buffeting ratio (--)			
23	Tube Vibration Check	Inlet	Center	U-Bend
24	Vortex shedding ratio (--)	0.065	0.147	0.142
25	Parallel flow amplitude (mm)	0.001	0.001	0.005
26	Crossflow amplitude (mm)	0.004	0.003	0.003
27	Tube gap (mm)	6.350	6.350	6.350
28	Crossflow RHO-V-SQ (kg/m-s2)	19.61	102.19	26.13
29	Bundle Entrance/Exit			
30	(analysis at first tube row)		Entrance	Exit
31	Fluidelastic instability ratio (--)		0.112	0.221
32	Vortex shedding ratio (--)		0.322	0.301
33	Crossflow amplitude (mm)		0.02538	0.06154
34	Crossflow velocity (m/s)		0.48	0.45
35	Tubesheet to inlet/outlet support (mm)		None	None
36	Shell Entrance/Exit Parameters		Entrance	Exit
37	Impingement plate		Yes	
38	Flow area (m2)		0.042	0.065
39	Velocity (m/s)		1.75	1.09
40	RHO-V-SQ (kg/m-s2)		2670.48	0.00
41	Shell type BEU	Baffle type	Single-Seg.	
42	Tube type Plain	Baffle layout	Perpend.	
43	Pitch ratio 1.2500	Tube diameter, (mm)	25.400	
44	Layout angle 45	Tube material	Carbon steel	
45	Number U-Bend supports 1	Supports/baffle space		
46	Program Messages			
47	+ Frequency ratios are based upon lowest natural or acoustic frequency			
48	* Items with asterisk exceed a conservative lower limit for vibration-free design. Review your case			
49	using the procedure described in Online Help; You may find that a vibration problem is unlikely.			
50				
51				
52				
53				

25/40

### 3A-E-111 A to H (Max Duty Case) - Shell 2

Used Program : HTRI Xist Ver.6.00 SP.3 Vibration Analysis

VALUE TO BE CHECKED	U-Bend	Center	Outlet	RECOMMEND LIMIT	CONCLUSION
Unsupported span (mm)	1401.	972.	1574.	2420 (By TEMA)	O.K.
Length / TEMA maximum span	0.579	0.517	0.837	< 1.0 TEMA	O.K.
Fluidelastic Instability Check					
Baffle tip cross velocity ratio	0.0900	0.0672	0.0763	< 0.8	O.K.
Ave. crossflow velocity ratio	0.0821	0.0613	0.0696	< 0.8	O.K.
Acoustic Vibration Check					
Vortex shedding ratio	-	-	-	-	-
Turbulent buffeting ratio	-	-	-	-	-
Tube Vibration Check					
Vortex shedding ratio	0.139	0.143	0.062	< 0.5	O.K.
Turbulent buffeting ratio	-	-	-	-	-
Bundle Entrance / Exit		Entrance	Exit		
Fluidelastic Instability ratio		0.000	0.099	< 0.8	O.K.
Vortex shedding ratio		0.574	0.281	> 0.5	Check Below
Crossflow amplitude (mm)		0.06107	0.01931	Tube OD = 25,400 Tube gap = 6.350 < 0.1 X Tube gap = 0.635 < 0.02 X Tube OD = 0.508	O.K.
Crossflow RHO-V-SQ (kg/m-s <sup>2</sup> )		25.25	18.24	< 5953 by TEMA	O.K.
Shell Entrance / Exit					
Velocity (m/sec)		6.958e-2	1.28	< If velocity is exceed 2.05 / 2.04	O.K.
pv2 (kg/m-s <sup>2</sup> )		0.00	1487.86	< 5953 by TEMA	O.K.



26/44

Vibration Analysis				
Released to the following HTRI Member Company:				
sewon M.K.Park				
Xist Ver. 6.00 SP3 2013/08/16 10:00 SN: 1500213869			MEG Energy Units	
Max.Duty Case : Shell 2				
Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles				
1	Shellside condition	Sens. Liquid	(Level 2.3)	
2	Axial stress loading (MPa)	0.000	Added mass factor	1.517
3	Beta	3.745		
4	Position In The Bundle	U-Bend	Center	Outlet
5	Length for natural frequency (mm)	1401.	972.	1574.
6	Length/TEMA maximum span (---)	0.579	0.517	0.837 *
7	Number of spans (---)	2	9	9
8	Tube natural frequency (Hz)	18.1 +	52.5	34.3
9	Shell acoustic frequency (Hz)			
10	Flow Velocities	U-Bend	Center	Outlet
11	Window parallel velocity (m/s)	0.56	0.56	0.55
12	Bundle crossflow velocity (m/s)	0.11	0.21	9.255e-2
13	Bundle/shell velocity (m/s)	0.14	0.27	0.12
14	Fluidelastic Instability Check	U-Bend	Center	Outlet
15	Log decrement HTRI	0.100	0.100	0.100
16	Critical velocity (m/s)	2.05	5.37	2.04
17	Baffle tip cross velocity ratio (---)	0.0900	0.0672	0.0763
18	Average crossflow velocity ratio (---)	0.0821	0.0613	0.0696
19	Acoustic Vibration Check	U-Bend	Center	Outlet
20	Vortex shedding ratio (---)			
21	Chen number (---)			
22	Turbulent buffeting ratio (---)			
23	Tube Vibration Check	U-Bend	Center	Outlet
24	Vortex shedding ratio (---)	0.139	0.143	0.062
25	Parallel flow amplitude (mm)	0.005	0.001	0.001
26	Crossflow amplitude (mm)	0.003	0.003	0.004
27	Tube gap (mm)	6.350	6.350	6.350
28	Crossflow RHO-V-SQ (kg/m-s2)	25.25	97.07	18.24
29	Bundle Entrance/Exit			
30	(analysis at first tube row)		Entrance	Exit
31	Fluidelastic instability ratio (---)		0.000	0.099
32	Vortex shedding ratio (---)		0.574	0.281
33	Crossflow amplitude (mm)		0.06107	0.01931
34	Crossflow velocity (m/s)		0.45	0.42
35	Tubesheet to inlet/outlet support (mm)		None	None
36	Shell Entrance/Exit Parameters		Entrance	Exit
37	Impingement plate		No	
38	Flow area (m2)		1.026	0.055
39	Velocity (m/s)		6.958e-2	1.28
40	RHO-V-SQ (kg/m-s2)		0.00	1487.86
41	Shell type BEU	Baffle type	Single-Seg.	
42	Tube type Plain	Baffle layout	Perpend.	
43	Pitch ratio 1.2500	Tube diameter, (mm)	25.400	
44	Layout angle 45	Tube material	Carbon steel	
45	Number U-Bend supports 1	Supports/baffle space		
46	Program Messages			
47	+ Frequency ratios are based upon lowest natural or acoustic frequency			
48	* Items with asterisk exceed a conservative lower limit for vibration-free design. Review your case			
49	using the procedure described in Online Help; You may find that a vibration problem is unlikely.			
50				
51				
52				
53				



27/4

### 3A-E-111 A to H (Max Duty Case) - Shell 3

Used Program : HTRI Xist Ver.6.00 SP.3 Vibration Analysis

VALUE TO BE CHECKED	Inlet	Center	U-Bend	RECOMMEND LIMIT	CONCLUSION
Unsupported span (mm)	1574.	972.	1401.	1881 (By TEMA)	O.K
Length / TEMA maximum span	0.837	0.517	0.579	< 1.0 TEMA	O.K
Fluidelastic Instability Check					
Baffle tip cross velocity ratio	0.0768	0.0670	0.0890	< 0.8	O.K
Ave. crossflow velocity ratio	0.0700	0.0611	0.0812	< 0.8	O.K
Acoustic Vibration Check					
Vortex shedding ratio	-	-	-	-	-
Tubulent buffeting ratio	-	-	-	-	-
Tube Vibration Check					
Vortex shedding ratio	0.062	0.142	0.137	< 0.5	O.K
Tubulent buffeting ratio	-	-	-	-	-
Bundle Entrance / Exit		Entrance	Exit		
Fluidelastic Instability ratio		0.109	0.217	< 0.8	O.K.
Vortex shedding ratio		0.310	0.294	< 0.5	O.K
Shell Entrance / Exit					
Velocity (m/sec)		1.69	1.07	< If velocity is exceed 2.05 / 2.04	O.K.
pv2 (kg/m-s <sup>2</sup> )		2570.48	0.00	< 5953 by TEMA	O.K.

2.8/41

Vibration Analysis				
Released to the following HTRI Member Company:				
sewon M.K.Park				
Xist Ver. 6.00 SP3 2013/08/16 10:00 SN: 1500213869			MEG Energy Units	
Max.Duty Case : Shell 3				
Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles				
1	Shellside condition	Sens. Liquid	(Level 2.3)	
2	Axial stress loading (MPa)	0.000	Added mass factor	1.517
3	Beta	3.745		
4	Position In The Bundle	Inlet	Center	U-Bend
5	Length for natural frequency (mm)	1574.	972.	1401.
6	Length/TEMA maximum span (---)	0.837 *	0.517	0.579
7	Number of spans (---)	9	9	2
8	Tube natural frequency (Hz)	34.4	52.5	18.1 +
9	Shell acoustic frequency (Hz)			
10	Flow Velocities	Inlet	Center	U-Bend
11	Window parallel velocity (m/s)	0.55	0.55	0.54
12	Bundle crossflow velocity (m/s)	9.334e-2	0.21	0.11
13	Bundle/shell velocity (m/s)	9.391e-2	0.21	0.11
14	Fluidelastic Instability Check	Inlet	Center	U-Bend
15	Log decrement HTRI	0.100	0.100	0.100
16	Critical velocity (m/s)	2.05	5.36	2.04
17	Baffle tip cross velocity ratio (---)	0.0768	0.0670	0.0890
18	Average crossflow velocity ratio (---)	0.0700	0.0611	0.0812
19	Acoustic Vibration Check	Inlet	Center	U-Bend
20	Vortex shedding ratio (---)			
21	Chen number (---)			
22	Turbulent buffeting ratio (---)			
23	Tube Vibration Check	Inlet	Center	U-Bend
24	Vortex shedding ratio (---)	0.062	0.142	0.137
25	Parallel flow amplitude (mm)	0.001	0.001	0.005
26	Crossflow amplitude (mm)	0.004	0.003	0.003
27	Tube gap (mm)	6.350	6.350	6.350
28	Crossflow RHO-V-SQ (kg/m-s2)	18.55	97.41	25.02
29	Bundle Entrance/Exit		Entrance	Exit
30	(analysis at first tube row)			
31	Fluidelastic instability ratio (---)		0.109	0.217
32	Vortex shedding ratio (---)		0.310	0.294
33	Crossflow amplitude (mm)		0.02390	0.05885
34	Crossflow velocity (m/s)		0.47	0.44
35	Tubesheet to inlet/outlet support (mm)		None	None
36	Shell Entrance/Exit Parameters		Entrance	Exit
37	Impingement plate		Yes	
38	Flow area (m2)		0.042	0.065
39	Velocity (m/s)		1.69	1.07
40	RHO-V-SQ (kg/m-s2)		2570.48	0.00
41	Shell type BEU	Baffle type	Single-Seg.	
42	Tube type Plain	Baffle layout	Perpend.	
43	Pitch ratio 1.2500	Tube diameter, (mm)	25.400	
44	Layout angle 45	Tube material	Carbon steel	
45	Number U-Bend supports 1	Supports/baffle space		
46	Program Messages			
47	+ Frequency ratios are based upon lowest natural or acoustic frequency			
48	* Items with asterisk exceed a conservative lower limit for vibration-free design. Review your case			
49	using the procedure described in Online Help; You may find that a vibration problem is unlikely.			
50				
51				
52				
53				

29/47

### 3A-E-111 A to H (Max Duty Case) - Shell 4

Used Program : HTRI Xist Ver.6.00 SP.3 Vibration Analysis

VALUE TO BE CHECKED	U-Bend	Center	Outlet	RECOMMEND LIMIT	CONCLUSION
Unsupported span (mm)	1401.	972.	1574.	2420 (By TEMA)	O.K
Length / TEMA maximum span	0.579	0.517	0.837	< 1.0 TEMA	O.K
Fluidelastic Instability Check					
Baffle tip cross velocity ratio	0.0872	0.0653	0.0743	< 0.8	O.K
Ave. crossflow velocity ratio	0.0795	0.0595	0.0678	< 0.8	O.K
Acoustic Vibration Check					
Vortex shedding ratio	-	-	-	-	-
Tubulent buffeting ratio	-	-	-	-	-
Tube Vibration Check					
Vortex shedding ratio	0.134	0.138	0.060	< 0.5	O.K
Tubulent buffeting ratio	-	-	-	-	-
Bundle Entrance / Exit		Entrance	Exit		
Fluidelastic Instability ratio		0.000	0.097	< 0.8	O.K.
Vortex shedding ratio		0.559	0.276	> 0.5	Check Below
				Tube OD = 25.400	
				Tube gap = 6.350	
Crossflow amplitude (mm)		0.05864	0.01873	< 0.1 X Tube gap = 0.635 < 0.02 X Tube OD = 0.508	O.K.
Crossflow RHO-V-SQ (kg/m-s <sup>2</sup> )		23.97	17.46	< 5953 by TEMA	O.K.
Shell Entrance / Exit					
Velocity (m/sec)		6.780e-2	1.26	< If velocity is exceed 2.04 / 2.03	O.K.
pv2 (kg/m-s <sup>2</sup> )		0.00	1461.59	< 5953 by TEMA	O.K.




30/49

Vibration Analysis				
Released to the following HTRI Member Company:				
sewon M.K.Park				
Xist Ver. 6.00 SP3 2013/08/16 10:00 SN: 1500213869			MEG Energy Units	
Max.Duty Case : Shell 4				
Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles				
1	Shellside condition	Sens. Liquid	(Level 2.3)	
2	Axial stress loading (MPa)	0.000	Added mass factor	1.517
3	Beta	3.745		
4	Position In The Bundle	U-Bend	Center	Outlet
5	Length for natural frequency (mm)	1401.	972.	1574.
6	Length/TEMA maximum span (--)	0.579	0.517	0.837 *
7	Number of spans (--)	2	9	9
8	Tube natural frequency (Hz)	18.1 +	52.5	34.4
9	Shell acoustic frequency (Hz)			
10	Flow Velocities	U-Bend	Center	Outlet
11	Window parallel velocity (m/s)	0.55	0.54	0.54
12	Bundle crossflow velocity (m/s)	0.11	0.21	8.975e-2
13	Bundle/shell velocity (m/s)	9.027e-2	0.18	7.676e-2
14	Fluidelastic Instability Check	U-Bend	Center	Outlet
15	Log decrement HTRI	0.100	0.100	0.100
16	Critical velocity (m/s)	2.04	5.34	2.03
17	Baffle tip cross velocity ratio (--)	0.0872	0.0653	0.0743
18	Average crossflow velocity ratio (--)	0.0795	0.0595	0.0678
19	Acoustic Vibration Check	U-Bend	Center	Outlet
20	Vortex shedding ratio (--)			
21	Chen number (--)			
22	Turbulent buffeting ratio (--)			
23	Tube Vibration Check	U-Bend	Center	Outlet
24	Vortex shedding ratio (--)	0.134	0.138	0.060
25	Parallel flow amplitude (mm)	0.005	0.001	0.001
26	Crossflow amplitude (mm)	0.003	0.003	0.004
27	Tube gap (mm)	6.350	6.350	6.350
28	Crossflow RHO-V-SQ (kg/m-s2)	23.97	92.59	17.46
29	Bundle Entrance/Exit			
30	(analysis at first tube row)		Entrance	Exit
31	Fluidelastic instability ratio (--)		0.000	0.097
32	Vortex shedding ratio (--)		0.559	0.276
33	Crossflow amplitude (mm)		0.05864	0.01873
34	Crossflow velocity (m/s)		0.44	0.41
35	Tubesheet to inlet/outlet support (mm)		None	None
36	Shell Entrance/Exit Parameters		Entrance	Exit
37	Impingement plate		No	
38	Flow area (m2)		1.026	0.055
39	Velocity (m/s)		6.780e-2	1.26
40	RHO-V-SQ (kg/m-s2)		0.00	1461.59
41	Shell type BEU	Baffle type	Single-Seg.	
42	Tube type Plain	Baffle layout	Perpend.	
43	Pitch ratio 1.2500	Tube diameter, (mm)	25.400	
44	Layout angle 45	Tube material	Carbon steel	
45	Number U-Bend supports 1	Supports/baffle space		
46	Program Messages			
47	+ Frequency ratios are based upon lowest natural or acoustic frequency			
48	* Items with asterisk exceed a conservative lower limit for vibration-free design. Review your case			
49	using the procedure described in Online Help; You may find that a vibration problem is unlikely.			
50				
51				
52				
53				



Final Results																		
Released to the following HTRI Member Company:																		
sewon																		
M.K.Park																		
Xist Ver. 6.00 SP3 2013/08/16 10:00 SN: 1500213869					MEG Energy Units													
Max.Duty Case : Shell 1																		
Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles																		
1	Process Data			Hot Shellside		Cold Tubeside		Shellside Performance										
2	Fluid name	BP Frac Dilbit			TEG/Water (60%/40% wt)		Nom vel, X-flow/window 0.43 / 0.56											
3	Fluid condition	Sens. Liquid			Sens. Liquid		Flow fractions for heat transfer 0.670											
4	Total flow rate	(kg/hr)	457483		589132		A=0.0035 B=0.6118 C=0.0416 E=0.1845 F=0.1586											
5	Weight fraction vapor, In/Out	(--)	0.000	0.000	0.000	0.000												
6	Temperature, In/Out	(Deg C)	126.00	96.79	60.52	75.00												
7	Temperature, Average/Skin	(Deg C)	111.40	82.56	67.76	73.65												
8	Wall temperature, Min/Max	(Deg C)	69.77	84.90	69.50	84.36												
9	Pressure, In/Average	(kPa)	984.014	969.662	831.682	806.768												
10	Pressure drop, Total/Allowed	(kPa)	28.704	250.000	49.827	225.000												
11	Velocity, Mid/Max allow	(m/s)	0.34		1.11													
12	Mole fraction inert	(--)																
13	Average film coef.	(W/m2-K)		372.60		2227.21												
14	Heat transfer safety factor	(--)		1.000		1.000												
15	Fouling resistance	(m2-K/W)		0.000616		0.000180												
16	Overall Performance Data																	
17	Overall coef., Req'd/Clean/Actual	(W/m2-K)	170.89	/	306.46	/	244.21											
18	Heat duty, Calculated/Specified	(kW)	5902.	/														
19	Effective overall temperature difference	(Deg C)	41.4															
20	EMTD = (MTD) * (DELTA) * (F/G/H)	(Deg C)	41.72	*	0.9920	*	1.0000											
21																		
22																		
23										See Runtime Messages Report for warnings.								
24																		
25																		
26	Exchanger Fluid Volumes																	
27	Approximate shellside (L)		5023.9															
28	Approximate tubeside (L)		4515.8															
29	Shell Construction information																	
30	TEMA shell type	BEU	Shell ID	(mm)	1143.00													
31	Shells Series	1 Parallel 2	Total area	(m2)	1125.71													
32	Passes Shell	1 Tube 4	Eff. area	(m2/shell)	556.411													
33	Shell orientation angle (deg)	0.00																
34	Impingement present	Circular plate	Impingement diameter/nozzle	1.1														
35	Pairs seal strips	0	Passlane seal rods (mm)	25.400	No. 20													
36	Shell expansion joint	No	Full support at U-Bend	No														
37	Weight estimation Wet/Dry/Bundle	26895.6 /	17362.4 /	10095.9	(kg/shell)													
38																		
39	Baffle Information																	
40	Type	Perpend. Single-Seg.	Baffle cut (% dia)	24.50														
41	Crosspasses/shellpass	17	No. (Pct Area)	(mm) to C.L														
42	Central spacing	(mm)	486.000	1 20.45	291.465													
43	Inlet spacing	(mm)	1088.00	2 0.00	0.000													
44	Outlet spacing	(mm)	932.000															
45	Baffle thickness	(mm)	12.700															
46																		
47																		
48	Tube Information																	
49	Tube type	Plain	Tubecount per shell	792														
50	Length to tangent	(mm)	8534.	Pct tubes removed (both)	4.42													
51	Effective length	(mm)	8804.	Outside diameter	(mm)	25.400												
52	Total tubesheet	(mm)	102.000	Wall thickness	(mm)	2.110												
53	Area ratio	(out/in)	1.1982	Pitch (mm)	31.7500	Ratio	1.2500											
54	Tube metal	Carbon steel	Tube pattern (deg)	45														
55																		
56																		
57																		
58																		
59																		
60																		
61																		
62																		
63																		
64																		
65																		
66																		
67																		
68																		
69																		
70																		
71																		
72																		
73																		
74																		
75																		
76																		
77																		
78																		
79																		
80																		
81																		
82																		
83																		
84																		
85																		
86																		
87																		
88																		
89																		
90																		
91																		
92																		
93																		
94																		
95																		
96																		
97																		
98																		
99																		
100																		

32/44

Final Results									
Released to the following HTRI Member Company:									
sewon									
M.K.Park									
Xist Ver. 6.00 SP3 2013/08/16 10:00 SN: 1500213869					MEG Energy Units				
Max.Duty Case : Shell 2									
Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles									
1	Process Data			Hot Shellside		Cold Tubeside		Shellside Performance	
2	Fluid name	BP Frac Dilbit			TEG/Water (60%/40% wt)		Nom vel, X-flow/window 0.42 / 0.56		
3	Fluid condition	Sens. Liquid			Sens. Liquid		Flow fractions for heat transfer 0.659		
4	Total flow rate	(kg/hr)	457483		589132		A=0.0023 B=0.6014 C=0.0394 E=0.1976 F=0.1593		
5	Weight fraction vapor, In/Out	(-)	0.000	0.000	0.000	0.000			
6	Temperature, In/Out	(Deg C)	96.80	76.43	50.87	60.52			
7	Temperature, Average/Skin	(Deg C)	86.61	66.14	55.70	60.34			
8	Wall temperature, Min/Max	(Deg C)	55.47	66.49	55.28	66.13			
9	Pressure, In/Average	(kPa)	955.324	937.613	883.918	857.799			
10	Pressure drop, Total/Allowed	(kPa)	35.422	250.000	52.239	225.000			
11	Velocity, Mid/Max allow	(m/s)	0.33		1.10				
12	Mole fraction inert	(-)							
13	Average film coef.	(W/m2-K)		340.90		1811.83			
14	Heat transfer safety factor	(-)		1.000		1.000			
15	Fouling resistance	(m2-K/W)		0.000616		0.000180			
16	Overall Performance Data								
17	Overall coef., Req'd/Clean/Actual	(W/m2-K)	158.66	/	275.09	/	223.86		
18	Heat duty, Calculated/Specified	(kW)	3884.	/					
19	Effective overall temperature difference	(Deg C)	29.3						
20	EMTD = (MTD) * (DELTA) * (F/G/H)	(Deg C)	29.60	*	0.9911	*	1.0000		
21									
22									
23	See Runtime Messages Report for								
24	warnings.								
25									
26	Exchanger Fluid Volumes								
27	Approximate shellside (L)	5023.9							
28	Approximate tubeside (L)	4515.8							
29	Shell Construction Information								
30	TEMA shell type	BEU	Shell ID (mm)		1143.00				
31	Shells Series	1 Parallel	2	Total area	(m2)	1125.71			
32	Passes Shell	1 Tube	4	Eff. area	(m2/shell)	556.411			
33	Shell orientation angle (deg)	0.00							
34	Impingement present	No							
35	Pairs seal strips	0	Passlane seal rods (mm)		25.400	No. 20			
36	Shell expansion joint	No		Full support at U-Bend		No			
37	Weight estimation Wet/Dry/Bundle	26906.9	/	17373.7	/	10107.2	(kg/shell)		
38									
39	Baffle Information								
40	Type	Perpend. Single-Seg.	Baffle cut (% dia)		24.50				
41	Crosspasses/shellpass	17		No. (Pct Area)	(mm) to C.L.				
42	Central spacing	(mm)	486.000	1	20.35	291.465			
43	Inlet spacing	(mm)	932.000	2	0.00	0.000			
44	Outlet spacing	(mm)	1088.00						
45	Baffle thickness	(mm)	12.700						
46									
47									
48	Tube Information								
49	Tube type	Plain	Tubecount per shell		792				
50	Length to tangent	(mm)	8534.	Pct tubes removed (both)		3.91			
51	Effective length	(mm)	8804.	Outside diameter		(mm)	25.400		
52	Total tubesheet	(mm)	102.000	Wall thickness		(mm)	2.110		
53	Area ratio	(out/in)	1.1992	Pitch (mm)		31.7500	Ratio	1.2500	
54	Tube metal	Carbon steel	Tube pattern (deg)		45				
							Liquid Outlet		
Shell Nozzles							Inlet	Outlet	
Inlet at channel end-No									
Number at each position							1	1	0
Diameter							(mm)	242.875	242.875
Velocity							(m/s)	1.54	1.52
Pressure drop							(kPa)	1.057	2.066
Height under nozzle							(mm)	1143.00	61.187
Nozzle R-V-SQ							(kg/m-s2)	2113.49	2081.05
Shell ent.							(kg/m-s2)	0.00	1487.86
							Liquid Outlet		
Tube Nozzle							Inlet	Outlet	
Diameter							(mm)	193.675	193.675
Velocity							(m/s)	2.60	2.61
Pressure drop							(kPa)	3.966	2.541
Nozzle R-V-SQ							(kg/m-s2)	7209.84	7258.48
							Liquid Outlet		
Annular Distributor							Inlet	Outlet	
Length							(mm)		
Height							(mm)		
Slot area							(mm2)		
							Liquid Outlet		
Diametral Clearances (mm)									
Baffle-to-shell							Bundle-to-shell	Tube-to-baffle	
6.3500							21.7000	0.3969	




33/47

Final Results									
Released to the following HTRI Member Company:									
sewon									
M.K.Park									
Xist Ver. 6.00 SP3 2013/08/16 10:00 SN: 1500213869					MEG Energy Units				
Max.Duty Case : Shell 3									
Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles									
<div><div><div><div>1</div><div>Process Data</div></div><div><div>2</div><div>Fluid name</div><div>BP Frac Dilbit</div></div><div><div>3</div><div>Fluid condition</div><div>Sens. Liquid</div></div><div><div>4</div><div>Total flow rate</div><div>(kg/hr)</div><div>457483</div></div><div><div>5</div><div>Weight fraction vapor, In/Out</div><div>(--)</div><div>0.000</div><div>0.000</div><div>0.000</div><div>0.000</div></div><div><div>6</div><div>Temperature, In/Out</div><div>(Deg C)</div><div>76.44</div><div>62.57</div><div>44.46</div><div>50.87</div></div><div><div>7</div><div>Temperature, Average/Skin</div><div>(Deg C)</div><div>69.50</div><div>55.16</div><div>47.66</div><div>51.30</div></div><div><div>8</div><div>Wall temperature, Min/Max</div><div>(Deg C)</div><div>49.46</div><div>56.43</div><div>49.34</div><div>56.21</div></div><div><div>9</div><div>Pressure, In/Average</div><div>(kPa)</div><div>919.915</div><div>895.732</div><div>938.108</div><div>911.011</div></div><div><div>10</div><div>Pressure drop, Total/Allowed</div><div>(kPa)</div><div>48.367</div><div>250.000</div><div>54.193</div><div>225.000</div></div><div><div>11</div><div>Velocity, Mid/Max allow</div><div>(m/s)</div><div>0.33</div><div></div><div>1.09</div><div></div></div><div><div>12</div><div>Mole fraction inert</div><div>(--)</div><div></div><div></div><div></div><div></div></div><div><div>13</div><div>Average film coef.</div><div>(W/m2-K)</div><div></div><div>323.31</div><div></div><div>1519.09</div></div><div><div>14</div><div>Heat transfer safety factor</div><div>(--)</div><div></div><div>1.000</div><div></div><div>1.000</div></div><div><div>15</div><div>Fouling resistance</div><div>(m2-K/W)</div><div></div><div>0.000616</div><div></div><div>0.000180</div></div></div><div><div>16</div><div>Overall Performance Data</div><div><div>17</div><div>Overall coef., Req'd/Clean/Actual</div><div>(W/m2-K)</div><div>147.58</div><div>/</div><div>254.99</div><div>/</div><div>210.36</div></div><div><div>18</div><div>Heat duty, Calculated/Specified</div><div>(kW)</div><div>2559.</div><div>/</div><div></div></div><div><div>19</div><div>Effective overall temperature difference</div><div>(Deg C)</div><div>20.8</div></div><div><div>20</div><div>EMTD = (MTD) * (DELTA) * (F/G/H)</div><div>(Deg C)</div><div>20.98</div><div>*</div><div>0.9901</div><div>*</div><div>1.0000</div></div></div></div> <div><div>21</div><div></div></div> <div><div>22</div><div></div></div> <div><div>23</div><div>See Runtime Messages Report for</div></div> <div><div>24</div><div>warnings.</div></div> <div><div>25</div><div></div></div> <div><div>26</div><div>Exchanger Fluid Volumes</div><div><div>27</div><div>Approximate shellside (L)</div><div>5023.9</div></div><div><div>28</div><div>Approximate tubeside (L)</div><div>4515.8</div></div></div> <div><div>29</div><div>Shell Construction Information</div><div><div>30</div><div>TEMA shell type</div><div>BEU</div><div>Shell ID</div><div>(mm)</div><div>1143.00</div></div><div><div>31</div><div>Shells Series</div><div>1 Parallel 2</div><div>Total area</div><div>(m2)</div><div>1125.71</div></div><div><div>32</div><div>Passes Shell</div><div>1 Tube 4</div><div>Eff. area</div><div>(m2/shell)</div><div>556.411</div></div><div><div>33</div><div>Shell orientation angle (deg)</div><div>0.00</div></div><div><div>34</div><div>Impingement present</div><div>Circular plate</div><div>Impingement diameter/nozzle</div><div>1.1</div></div><div><div>35</div><div>Pairs seal strips</div><div>0</div><div>Passlane seal rods (mm)</div><div>25.400</div><div>No. 20</div></div><div><div>36</div><div>Shell expansion joint</div><div>No</div><div>Full support at U-Bend</div><div>No</div></div><div><div>37</div><div>Weight estimation Wet/Dry/Bundle</div><div>26914.6</div><div>/</div><div>17381.4</div><div>/</div><div>10114.9</div><div>(kg/shell)</div></div></div> <div><div>38</div><div></div></div> <div><div>39</div><div>Baffle Information</div><div><div>40</div><div>Type</div><div>Perpend. Single-Seg.</div><div>Baffle cut (% dia)</div><div>24.50</div></div><div><div>41</div><div>Crosspasses/shellpass</div><div>17</div><div>No. (Pct Area)</div><div>(mm) to C.L</div></div><div><div>42</div><div>Central spacing</div><div>(mm)</div><div>486.000</div><div>1</div><div>20.45</div><div>291.465</div></div><div><div>43</div><div>Inlet spacing</div><div>(mm)</div><div>1088.00</div><div>2</div><div>0.00</div><div>0.000</div></div><div><div>44</div><div>Outlet spacing</div><div>(mm)</div><div>932.000</div></div><div><div>45</div><div>Baffle thickness</div><div>(mm)</div><div>12.700</div></div></div> <div><div>46</div><div></div></div> <div><div>47</div><div></div></div> <div><div>48</div><div>Tube Information</div><div><div>49</div><div>Tube type</div><div>Plain</div><div>Tube count per shell</div><div>792</div></div><div><div>50</div><div>Length to tangent</div><div>(mm)</div><div>8534.</div><div>Pct tubes removed (both)</div><div>4.42</div></div><div><div>51</div><div>Effective length</div><div>(mm)</div><div>8804.</div><div>Outside diameter</div><div>(mm)</div><div>25.400</div></div><div><div>52</div><div>Total tubesheet</div><div>(mm)</div><div>102.000</div><div>Wall thickness</div><div>(mm)</div><div>2.110</div></div><div><div>53</div><div>Area ratio</div><div>(out/in)</div><div>1.1992</div><div>Pitch (mm)</div><div>31.7500</div><div>Ratio</div><div>1.2500</div></div><div><div>54</div><div>Tube metal</div><div>Carbon steel</div><div>Tube pattern (deg)</div><div>45</div></div></div> <div><div>55</div><div></div></div> <div><div>56</div><div></div></div> <div><div>57</div><div></div></div> <div><div>58</div><div></div></div> <div><div>59</div><div></div></div> <div><div>60</div><div></div></div> <div><div>61</div><div></div></div> <div><div>62</div><div></div></div> <div><div>63</div><div></div></div> <div><div>64</div><div></div></div> <div><div>65</div><div></div></div> <div><div>66</div><div></div></div> <div><div>67</div><div></div></div> <div><div>68</div><div></div></div> <div><div>69</div><div></div></div> <div><div>70</div><div></div></div> <div><div>71</div><div></div></div> <div><div>72</div><div></div></div> <div><div>73</div><div></div></div> <div><div>74</div><div></div></div> <div><div>75</div><div></div></div> <div><div>76</div><div></div></div> <div><div>77</div><div></div></div> <div><div>78</div><div></div></div> <div><div>79</div><div></div></div> <div><div>80</div><div></div></div> <div><div>81</div><div></div></div> <div><div>82</div><div></div></div> <div><div>83</div><div></div></div> <div><div>84</div><div></div></div> <div><div>85</div><div></div></div> <div><div>86</div><div></div></div> <div><div>87</div><div></div></div> <div><div>88</div><div></div></div> <div><div>89</div><div></div></div> <div><div>90</div><div></div></div> <div><div>91</div><div></div></div> <div><div>92</div><div></div></div> <div><div>93</div><div></div></div> <div><div>94</div><div></div></div> <div><div>95</div><div></div></div> <div><div>96</div><div></div></div> <div><div>97</div><div></div></div> <div><div>98</div><div></div></div> <div><div>99</div><div></div></div> <div><div>100</div><div></div></div> <div><div>Shellside Performance</div><div><div>Nom vel, X-flow/window</div><div>0.42 / 0.55</div></div><div><div>Flow fractions for heat transfer</div><div>0.661</div></div><div><div>A=0.0017</div><div>B=0.6065</div><div>C=0.0315</div><div>E=0.2058</div><div>F=0.1545</div></div></div> <div><div>Shellside Heat Transfer Corrections</div><div><div>Total</div><div>Beta</div><div>Gamma</div><div>End</div><div>Fin</div></div><div><div>0.920</div><div>0.920</div><div>1.000</div><div>0.962</div><div>1.000</div></div></div> <div><div>Pressure Drops (Percent of Total)</div><div><div>Cross</div><div>Window</div><div>Ends</div><div>Nozzle</div><div>Shell</div><div>Tube</div></div><div><div>68.49</div><div>15.32</div><div>6.71</div><div>Inlet</div><div>8.41</div><div>7.29</div></div><div><div>MOMENTUM</div><div></div><div>0.00</div><div>Outlet</div><div>1.06</div><div>4.66</div></div></div> <div><div>Two-Phase Parameters</div><div><div>Method</div><div>Inlet</div><div>Center</div><div>Outlet</div><div>Mix F</div></div></div> <div><div>H. T. Parameters</div><div><div>Shell</div><div>Tube</div></div><div><div>Overall wall correction</div><div>0.895</div><div>1.011</div></div><div><div>Midpoint</div><div>Prandtl no.</div><div>1038.17</div><div>37.86</div></div><div><div>Midpoint</div><div>Reynolds no.</div><div>131</div><div>6466</div></div><div><div>Bundle inlet</div><div>Reynolds no.</div><div>81</div><div>5979</div></div><div><div>Bundle outlet</div><div>Reynolds no.</div><div>53</div><div>6947</div></div><div><div>Fouling layer</div><div>(mm)</div></div></div> <div><div>Thermal Resistance</div><div><div>Shell</div><div>Tube</div><div>Fouling</div><div>Metal</div><div>Over Des</div></div><div><div>65.07</div><div>16.61</div><div>17.50</div><div>0.83</div><div>42.54</div></div><div><div>Total fouling resistance</div><div>8.313e-4</div></div><div><div>Differential resistance</div><div>0.00202</div></div></div> <div><div>Shell Nozzles</div><div><div>Inlet</div><div>Outlet</div><div>Liquid Outlet</div></div><div><div>Inlet at channel end-Yes</div><div></div><div>1</div><div>1</div><div>0</div></div><div><div>Number at each position</div><div></div><div>1</div><div>1</div><div>0</div></div><div><div>Diameter</div><div>(mm)</div><div>242.875</div><div>242.875</div></div><div><div>Velocity</div><div>(m/s)</div><div>1.52</div><div>1.50</div></div><div><div>Pressure drop</div><div>(kPa)</div><div>4.068</div><div>0.515</div></div><div><div>Height under nozzle</div><div>(mm)</div><div>61.187</div><div>1143.00</div></div><div><div>Nozzle R-V-SQ</div><div>(kg/m-s2)</div><div>2081.05</div><div>2059.43</div></div><div><div>Shell ent.</div><div>(kg/m-s2)</div><div>2570.48</div><div>0.00</div></div></div> <div><div>Tube Nozzle</div><div><div>Inlet</div><div>Outlet</div><div>Liquid Outlet</div></div><div><div>RADIAL</div><div>RADIAL</div><div></div></div><div><div>Diameter</div><div>(mm)</div><div>193.675</div><div>193.675</div></div><div><div>Velocity</div><div>(m/s)</div><div>2.58</div><div>2.60</div></div><div><div>Pressure drop</div><div>(kPa)</div><div>3.948</div><div>2.524</div></div><div><div>Nozzle R-V-SQ</div><div>(kg/m-s2)</div><div>7177.87</div><div>7209.84</div></div></div> <div><div>Annular Distributor</div><div><div>Inlet</div><div>Outlet</div></div><div><div>Length</div><div>(mm)</div></div><div><div>Height</div><div>(mm)</div></div><div><div>Slot area</div><div>(mm2)</div></div><div><div>Diametral Clearances (mm)</div><div><div>Baffle-to-shell</div><div>Bundle-to-shell</div><div>Tube-to-baffle</div></div><div><div>6.3500</div><div>21.7000</div><div>0.3969</div></div></div></div>									



34/49

Final Results									
Released to the following HTRI Member Company:									
sewon									
M.K Park									
Xist Ver. 6.00 SP3 2013/08/16 10:00 SN: 1500213869					MEG Energy Units				
Max.Duty Case : Shell 4									
Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles									
Process Data		Hot Shellside		Cold Tubeside		Shellside Performance			
Fluid name		BP Frac Dilbit		TEG/Water (60%/40% wt)		Nom vel, X-flow/window 0.41 / 0.54			
Fluid condition		Sens. Liquid		Sens. Liquid		Flow fractions for heat transfer 0.650			
Total flow rate (kg/hr)		457483		589132		A=0.0014 B=0.5937 C=0.0262 E=0.2177 F=0.1609			
Weight fraction vapor, In/Out (-)		0.000		0.000					
Temperature, In/Cut (Deg C)		62.57		40.00					
Temperature, Average/Skin (Deg C)		57.63		42.23					
Wall temperature, Min/Max (Deg C)		42.83		42.74					
Pressure, In/Average (kPa)		871.561		994.015					
Pressure drop, Total/Allowed (kPa)		63.212		55.906					
Velocity, Mid/Max allow (m/s)		0.32		1.09					
Mole fraction inert (-)									
Average film coef. (W/m2-K)		322.00		1326.70					
Heat transfer safety factor (-)		1.000		1.000					
Fouling resistance (m2-K/W)		0.000816		0.000180					
Overall Performance Data									
Overall coef., Req'd/Clean/Actual (W/m2-K)		144.64 /		247.00 /		204.90			
Heat duty, Calculated/Specified (kW)		1767. /							
Effective overall temperature difference (Deg C)		14.6							
EMTD = (MTD) * (DELTA) * (F/G/H) (Deg C)		14.82 *		0.9870 *		1.0000			
See Runtime Messages Report for warnings.									
Exchanger Fluid Volumes									
Approximate shellside (L)		5023.9							
Approximate tubeside (L)		4515.8							
Shell Construction Information									
TEMA shell type		BEU		Shell ID (mm)		1143.00			
Shells Series		1 Parallel 2		Total area (m2)		1125.71			
Passes Shell		1 Tube 4		Eff. area (m2/shell)		556.411			
Shell orientation angle (deg)		0.00							
Impingement present		No							
Pairs seal strips		0		Passlane seal rods (mm)		25.400		No. 20	
Shell expansion joint		No		Full support at U-Bend		No			
Weight estimation Wet/Dry/Bundle		28919.7 /		17386.6 /		10120.0 (kg/shell)			
Baffle Information									
Type		Perpend. Single-Seg.		Baffle cut (% dia)		24.50			
Crosspasses/shellpass		17		No. (Pct Area)		(mm) to C.L			
Central spacing (mm)		486.000		1		20.35		291.465	
Inlet spacing (mm)		932.000		2		0.00		0.000	
Outlet spacing (mm)		1088.00							
Baffle thickness (mm)		12.700							
Tube Information									
Tube type		Plain		Tubecount per shell		792			
Length to tangent (mm)		8534.		Pct tubes removed (both)		3.91			
Effective length (mm)		8804.		Outside diameter (mm)		25.400			
Total tubesheet (mm)		102.000		Wall thickness (mm)		2.110			
Area ratio (out/in)		1.1992		Pitch (mm)		31.7500		Ratio 1.2500	
Tube metal		Carbon steel		Tube pattern (deg)		45			
Annular Distributor						Inlet		Outlet	
Length (mm)									
Height (mm)									
Slot area (mm2)									
Diametral Clearances (mm)									
Baffle-to-shell						Bundle-to-shell		Tube-to-baffle	
6.3500						21.7000		0.3969	

## 3A-E-111 A to H (Min Duty Case)

The Thermal/Hydraulic/Vibration calculations are performed by using HTRI Xist Ver. 6.00 SP3.

The process condition and the physical properties are based on Buyer data sheet.

For the design result ( the geometry data), please refer to the Equipment data sheet and Fabrication drawing.

### 1. Thermal and Hydraulic performance

- Thermal performance : 140.24 % Over - Design Case ----- O.K.

- Pressure drop :

Shell-side 106.688 < 250.000 kPa ----- O.K

tube-side 145.876 < 275.000 kPa ----- O.K

### 2. Vibration Analysis

- Fluidelastic instability : characteristic values << criteria ----- O.K.

- Acoustic vibration : characteristic values << criteria ----- O.K.

- Tube vibration check: characteristic values << criteria ----- O.K.

- Bundle Entrance/Exit : characteristic values << criteria ----- O.K.

- Shell Entrance /Exit: characteristic values << criteria ----- O.K.

36/44

### 3A-E-111 A to H (Min Duty Case) - Shell 1

Used Program : HTRI Xist Ver.6.00 SP.3 Vibration Analysis

VALUE TO BE CHECKED	Inlet	Center	U-Bend	RECOMMEND LIMIT	CONCLUSION
Unsupported span (mm)	1574.	972.	1401.	1881 (By TEMA)	O.K
Length / TEMA maximum span	0.837	0.517	0.579	< 1.0 TEMA	O.K
Fluidelastic Instability Check					
Baffle tip cross velocity ratio	0.0707	0.0615	0.0816	< 0.8	O.K
Ave. crossflow velocity ratio	0.0644	0.0561	0.0744	< 0.8	O.K
Acoustic Vibration Check					
Vortex shedding ratio	-	-	-	-	-
Tubulent buffeting ratio	-	-	-	-	-
Tube Vibration Check					
Vortex shedding ratio	0.057	0.131	0.126	< 0.5	O.K
Tubulent buffeting ratio	-	-	-	-	-
Bundle Entrance / Exit		Entrance	Exit		
Fluidelastic Instability ratio		0.098	0.195	< 0.8	O.K.
Vortex shedding ratio		0.281	0.265	< 0.5	O.K
Shell Entrance / Exit					
Velocity (m/sec)		1.53	0.96	< If velocity is exceed 2.05 / 2.04	O.K.
pv2 (kg/m-s2)		2057.22	0.00	< 5953 by TEMA	O.K.



30/47

Vibration Analysis				
Released to the following HTRI Member Company:				
sewon M.K.Park				
Xist Ver. 6.00 SP3 2013/08/16 10:01 SN: 1500213869			MEG Energy Units	
Min.Duty Case : Shell 1				
Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles				
1	Shellside condition	Sens. Liquid	(Level 2.3)	
2	Axial stress loading (MPa)	0.000	Added mass factor	1.517
3	Beta	3.745		
4	Position In The Bundle	Inlet	Center	U-Bend
5	Length for natural frequency (mm)	1574.	972.	1401.
6	Length/TEMA maximum span (--)	0.837 *	0.517	0.579
7	Number of spans (--)	9	9	2
8	Tube natural frequency (Hz)	34.3	52.3	18.0 +
9	Shell acoustic frequency (Hz)			
10	Flow Velocities	Inlet	Center	U-Bend
11	Window parallel velocity (m/s)	0.50	0.49	0.49
12	Bundle crossflow velocity (m/s)	8.623e-2	0.20	9.897e-2
13	Bundle/shell velocity (m/s)	0.11	0.26	0.13
14	Fluidelastic instability Check	Inlet	Center	U-Bend
15	Log decrement HTRI	0.100	0.100	0.100
16	Critical velocity (m/s)	2.05	5.37	2.04
17	Baffle tip cross velocity ratio (--)	0.0707	0.0615	0.0816
18	Average crossflow velocity ratio (--)	0.0644	0.0561	0.0744
19	Acoustic Vibration Check	Inlet	Center	U-Bend
20	Vortex shedding ratio (--)			
21	Chen number (--)			
22	Turbulent buffeting ratio (--)			
23	Tube Vibration Check	Inlet	Center	U-Bend
24	Vortex shedding ratio (--)	0.057	0.131	0.126
25	Parallel flow amplitude (mm)	0.001	0.001	0.004
26	Crossflow amplitude (mm)	0.003	0.002	0.003
27	Tube gap (mm)	6.350	6.350	6.350
28	Crossflow RHO-V-SQ (kg/m-s2)	15.48	81.01	20.75
29	Bundle Entrance/Exit			
30	(analysis at first tube row)		Entrance	Exit
31	Fluidelastic instability ratio (--)		0.098	0.195
32	Vortex shedding ratio (--)		0.281	0.265
33	Crossflow amplitude (mm)		0.01906	0.04669
34	Crossflow velocity (m/s)		0.42	0.40
35	Tubesheet to inlet/outlet support (mm)		None	None
36	Shell Entrance/Exit Parameters		Entrance	Exit
37	Impingement plate		Yes	
38	Flow area (m2)		0.042	0.065
39	Velocity (m/s)		1.53	0.96
40	RHO-V-SQ (kg/m-s2)		2057.22	0.00
41	Shell type BEU	Baffle type	Single-Seg.	
42	Tube type Plain	Baffle layout	Perpend.	
43	Pitch ratio 1.2500	Tube diameter, (mm)	25.400	
44	Layout angle 45	Tube material	Carbon steel	
45	Number U-Bend supports 1	Supports/baffle space		
46	Program Messages			
47	+ Frequency ratios are based upon lowest natural or acoustic frequency			
48	* Items with asterisk exceed a conservative lower limit for vibration-free design. Review your case			
49	using the procedure described in Online Help; You may find that a vibration problem is unlikely.			
50				
51				
52				
53				

## 3A-E-111 A to H (Min Duty Case) - Shell 2

Used Program : HTRI Xist Ver.6.00 SP.3 Vibration Analysis

VALUE TO BE CHECKED	U-Bend	Center	Outlet	RECOMMEND LIMIT	CONCLUSION
Unsupported span (mm)	1401.	972.	1574.	2420 (By TEMA)	O.K
Length / TEMA maximum span	0.579	0.517	0.837	< 1.0 TEMA	O.K
<b>Fluidelastic Instability Check</b>					
Baffle tip cross velocity ratio	0.0797	0.0596	0.0677	< 0.8	O.K
Ave. crossflow velocity ratio	0.0726	0.0543	0.0617	< 0.8	O.K
<b>Acoustic Vibration Check</b>					
Vortex shedding ratio	-	-	-	-	-
Tubulent buffeting ratio	-	-	-	-	-
<b>Tube Vibration Check</b>					
Vortex shedding ratio	0.122	0.126	0.055	< 0.5	O.K
Tubulent buffeting ratio	-	-	-	-	-
Bundle Entrance / Exit		Entrance	Exit		
Fluidelastic Instability ratio		0.000	0.087	< 0.8	O.K.
Vortex shedding ratio		0.504	0.248	> 0.5	Check Below
				Tube OD = 25.400	
				Tube gap = 6.350	
Crossflow amplitude (mm)		0.04640	0.01476	< 0.1 X Tube gap = 0.635 < 0.02 X Tube OD = 0.508	O.K.
Crossflow RHO-V-SQ (kg/m-s2)		19.73	14.29	< 5953 by TEMA	O.K.
Shell Entrance / Exit					
Velocity (m/sec)		6.094e-2	1.13	< If velocity is exceed 2.04 / 2.03	O.K.
pv2 (kg/m-s2)		0.00	1155.68	< 5953 by TEMA	O.K.

39/40

**Vibration Analysis**

Released to the following HTRI Member Company:

sewon  
M.K.Park

Xist Ver. 6.00 SP3 2013/08/16 10:01 SN: 1500213869

MEG Energy Units

Min.Duty Case : Shell 2

Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles

1	Shellside condition		Sens. Liquid	(Level 2.3)	
2	Axial stress loading	(MPa)	0.000	Added mass factor	1.517
3	Beta		3.745		
4	Position In The Bundle		U-Bend	Center	Outlet
5	Length for natural frequency	(mm)	1401.	972.	1574.
6	Length/TEMA maximum span	(--)	0.579	0.517	0.837 *
7	Number of spans	(--)	2	9	9
8	Tube natural frequency	(Hz)	18.0 +	52.4	34.2
9	Shell acoustic frequency	(Hz)			
10	Flow Velocities		U-Bend	Center	Outlet
11	Window parallel velocity	(m/s)	0.49	0.49	0.48
12	Bundle crossflow velocity	(m/s)	9.653e-2	0.19	8.162e-2
13	Bundle/shell velocity	(m/s)	0.12	0.24	0.11
14	Fluidelastic Instability Check		U-Bend	Center	Outlet
15	Log decrement	HTRI	0.100	0.100	0.100
16	Critical velocity	(m/s)	2.04	5.34	2.03
17	Baffle tip cross velocity ratio	(--)	0.0797	0.0596	0.0677
18	Average crossflow velocity ratio	(--)	0.0726	0.0543	0.0617
19	Acoustic Vibration Check		U-Bend	Center	Outlet
20	Vortex shedding ratio	(--)			
21	Chen number	(--)			
22	Turbulent buffeting ratio	(--)			
23	Tube Vibration Check		U-Bend	Center	Outlet
24	Vortex shedding ratio	(--)	0.122	0.126	0.055
25	Parallel flow amplitude	(mm)	0.004	0.001	0.001
26	Crossflow amplitude	(mm)	0.003	0.002	0.003
27	Tube gap	(mm)	6.350	6.350	6.350
28	Crossflow RHO-V-SQ	(kg/m-s2)	19.73	76.00	14.29
29	Bundle Entrance/Exit			Entrance	Exit
30	(analysis at first tube row)				
31	Fluidelastic instability ratio	(--)		0.000	0.087
32	Vortex shedding ratio	(--)		0.504	0.248
33	Crossflow amplitude	(mm)		0.04640	0.01476
34	Crossflow velocity	(m/s)		0.40	0.37
35	Tubesheet to inlet/outlet support	(mm)		None	None
36	Shell Entrance/Exit Parameters			Entrance	Exit
37	Impingement plate			No	
38	Flow area	(m2)		1.026	0.055
39	Velocity	(m/s)		6.094e-2	1.13
40	RHO-V-SQ	(kg/m-s2)		0.00	1155.68
41	Shell type	BEU	Baffle type	Single-Seg.	
42	Tube type	Plain	Baffle layout	Perpend.	
43	Pitch ratio	1.2500	Tube diameter, (mm)	25.400	
44	Layout angle	45	Tube material	Carbon steel	
45	Number U-Bend supports	1	Supports/baffle space		

**Program Messages**

- 47 + Frequency ratios are based upon lowest natural or acoustic frequency
- 48 \* Items with asterisk exceed a conservative lower limit for vibration-free design. Review your case
- 49 using the procedure described in Online Help; You may find that a vibration problem is unlikely.

50

51

52

53



### 3A-E-111 A to H (Min Duty Case) - Shell 3

Used Program : HTRI Xist Ver.6.00 SP.3 Vibration Analysis

VALUE TO BE CHECKED	Inlet	Center	U-Bend	RECOMMEND LIMIT	CONCLUSION
Unsupported span (mm)	1574.	972.	1401.	1881 (By TEMA)	O.K
Length / TEMA maximum span	0.837	0.517	0.579	< 1.0 TEMA	O.K
Fluidelastic Instability Check					
Baffle tip cross velocity ratio	0.0672	0.0587	0.0779	< 0.8	O.K
Ave. crossflow velocity ratio	0.0613	0.0535	0.0711	< 0.8	O.K
Acoustic Vibration Check					
Vortex shedding ratio	-	-	-	-	-
Tubulent buffeting ratio	-	-	-	-	-
Tube Vibration Check					
Vortex shedding ratio	0.054	0.124	0.119	< 0.5	O.K
Tubulent buffeting ratio	-	-	-	-	-
Bundle Entrance / Exit		Entrance	Exit		
Fluidelastic Instability ratio		0.096	0.191	< 0.8	O.K.
Vortex shedding ratio		0.273	0.259	< 0.5	O.K
Shell Entrance / Exit					
Velocity (m/sec)		1.48	0.94	< If velocity is exceed 2.04 / 2.03	O.K.
pv2 (kg/m-s <sup>2</sup> )		1996.60	0.00	< 5953 by TEMA	O.K.

41/47

**Vibration Analysis**

Released to the following HTRI Member Company:

sewon  
M.K.Park

Xist Ver. 6.00 SP3 2013/08/16 10:01 SN: 1500213869

MEG Energy Units

Min.Duty Case : Shell 3

Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles

1	Shellside condition		Sens. Liquid	(Level 2.3)	
2	Axial stress loading	(MPa)	0.000	Added mass factor	1.517
3	Beta		3.745		
4	Position In The Bundle		Inlet	Center	U-Bend
5	Length for natural frequency	(mm)	1574.	972.	1401.
6	Length/TEMA maximum span	(--)	0.837 *	0.517	0.579
7	Number of spans	(--)	9	9	2
8	Tube natural frequency	(Hz)	34.3	52.4	18.0 +
9	Shell acoustic frequency	(Hz)			
10	Flow Velocities		Inlet	Center	U-Bend
11	Window parallel velocity	(m/s)	0.48	0.48	0.48
12	Bundle crossflow velocity	(m/s)	8.126e-2	0.19	9.391e-2
13	Bundle/shell velocity	(m/s)	0.10	0.23	0.12
14	Fluidelastic Instability Check		Inlet	Center	U-Bend
15	Log decrement	HTRI	0.100	0.100	0.100
16	Critical velocity	(m/s)	2.04	5.33	2.03
17	Baffle tip cross velocity ratio	(--)	0.0672	0.0587	0.0779
18	Average crossflow velocity ratio	(--)	0.0613	0.0535	0.0711
19	Acoustic Vibration Check		Inlet	Center	U-Bend
20	Vortex shedding ratio	(--)			
21	Chen number	(--)			
22	Turbulent buffeting ratio	(--)			
23	Tube Vibration Check		Inlet	Center	U-Bend
24	Vortex shedding ratio	(--)	0.054	0.124	0.119
25	Parallel flow amplitude	(mm)	0.001	0.001	0.004
26	Crossflow amplitude	(mm)	0.003	0.002	0.002
27	Tube gap	(mm)	6.350	6.350	6.350
28	Crossflow RHO-V-SQ	(kg/m-s2)	14.17	74.43	19.12
29	Bundle Entrance/Exit				
30	(analysis at first tube row)			Entrance	Exit
31	Fluidelastic instability ratio	(--)		0.096	0.191
32	Vortex shedding ratio	(--)		0.273	0.259
33	Crossflow amplitude	(mm)		0.01819	0.04495
34	Crossflow velocity	(m/s)		0.41	0.39
35	Tubesheet to inlet/outlet support	(mm)		None	None
36	Shell Entrance/Exit Parameters			Entrance	Exit
37	Impingement plate			Yes	
38	Flow area	(m2)		0.042	0.065
39	Velocity	(m/s)		1.48	0.94
40	RHO-V-SQ	(kg/m-s2)		1996.60	0.00
41	Shell type	BEU	Baffle type	Single-Seg.	
42	Tube type	Plain	Baffle layout	Perpend.	
43	Pitch ratio	1.2500	Tube diameter, (mm)	25.400	
44	Layout angle	45	Tube material	Carbon steel	
45	Number U-Bend supports	1	Supports/baffle space		
46	Program Messages				
47	+ Frequency ratios are based upon lowest natural or acoustic frequency				
48	* Items with asterisk exceed a conservative lower limit for vibration-free design. Review your case				
49	using the procedure described in Online Help; You may find that a vibration problem is unlikely.				
50					
51					
52					
53					

42/44

### 3A-E-111 A to H (Min Duty Case) - Shell 4

Used Program : HTRI Xist Ver.6.00 SP.3 Vibration Analysis

VALUE TO BE CHECKED	U-Bend	Center	Outlet	RECOMMEND LIMIT	CONCLUSION
Unsupported span (mm)	1401.	972.	1574.	2420 (By TEMA)	O.K
Length / TEMA maximum span	0.579	0.517	0.837	< 1.0 TEMA	O.K
Fluidelastic Instability Check					
Baffle tip cross velocity ratio	0.0785	0.0588	0.0669	< 0.8	O.K
Ave. crossflow velocity ratio	0.0716	0.0536	0.0610	< 0.8	O.K
Acoustic Vibration Check					
Vortex shedding ratio	-	-	-	-	-
Tubulent buffeting ratio	-	-	-	-	-
Tube Vibration Check					
Vortex shedding ratio	0.120	0.124	0.054	< 0.5	O.K
Tubulent buffeting ratio	-	-	-	-	-
Bundle Entrance / Exit		Entrance	Exit		
Fluidelastic Instability ratio		0.000	0.086	< 0.8	O.K.
Vortex shedding ratio		0.492	0.243	> 0.5	Check Below
				Tube OD = 25.400	
				Tube gap = 6.350	
Crossflow amplitude (mm)		0.04478	0.01433	< 0.1 X Tube gap = 0.635 < 0.02 X Tube OD = 0.508	O.K.
Crossflow RHO-V-SQ (kg/m-s2)		19.38	14.11	< 5953 by TEMA	O.K.
Shell Entrance / Exit					
Velocity (m/sec)		5.956e-2	1.11	< If velocity is exceed 2.03 / 2.02	O.K.
pv2 (kg/m-s2)		0.00	1135.17	< 5953 by TEMA	O.K.



43/47

# Vibration Analysis

Released to the following HTRI Member Company:

sewon  
M.K.Park

Xist Ver. 6.00 SP3 2013/08/16 10:01 SN: 1500213869

MEG Energy Units

Min.Duty Case : Shell 4

Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles

1	Shellside condition		Sens. Liquid	(Level 2.3)	
2	Axial stress loading	(MPa)	0.000	Added mass factor	1.517
3	Beta		3.745		
4	Position In The Bundle		U-Bend	Center	Outlet
5	Length for natural frequency	(mm)	1401.	972.	1574.
6	Length/TEMA maximum span	(--)	0.579	0.517	0.837 *
7	Number of spans	(--)	2	9	9
8	Tube natural frequency	(Hz)	18.0 +	52.4	34.3
9	Shell acoustic frequency	(Hz)			
10	Flow Velocities		U-Bend	Center	Outlet
11	Window parallel velocity	(m/s)	0.48	0.48	0.48
12	Bundle crossflow velocity	(m/s)	9.457e-2	0.19	8.038e-2
13	Bundle/shell velocity	(m/s)	9.900e-2	0.19	8.414e-2
14	Fluidelastic Instability Check		U-Bend	Center	Outlet
15	Log decrement	HTRI	0.100	0.100	0.100
16	Critical velocity	(m/s)	2.03	5.31	2.02
17	Baffle tip cross velocity ratio	(--)	0.0785	0.0588	0.0669
18	Average crossflow velocity ratio	(--)	0.0716	0.0536	0.0610
19	Acoustic Vibration Check		U-Bend	Center	Outlet
20	Vortex shedding ratio	(--)			
21	Chen number	(--)			
22	Turbulent buffeting ratio	(--)			
23	Tube Vibration Check		U-Bend	Center	Outlet
24	Vortex shedding ratio	(--)	0.120	0.124	0.054
25	Parallel flow amplitude	(mm)	0.004	0.001	0.001
26	Crossflow amplitude	(mm)	0.002	0.002	0.003
27	Tube gap	(mm)	6.350	6.350	6.350
28	Crossflow RHO-V-SQ	(kg/m-s2)	19.38	74.85	14.11
29	Bundle Entrance/Exit			Entrance	Exit
30	(analysis at first tube row)				
31	Fluidelastic instability ratio	(--)		0.000	0.086
32	Vortex shedding ratio	(--)		0.492	0.243
33	Crossflow amplitude	(mm)		0.04478	0.01433
34	Crossflow velocity	(m/s)		0.39	0.36
35	Tubesheet to inlet/outlet support	(mm)		None	None
36	Shell Entrance/Exit Parameters			Entrance	Exit
37	Impingement plate			No	
38	Flow area	(m2)		1.026	0.055
39	Velocity	(m/s)		5.956e-2	1.11
40	RHO-V-SQ	(kg/m-s2)		0.00	1135.17
41	Shell type	BEU	Baffle type	Single-Seg.	
42	Tube type	Plain	Baffle layout	Perpend.	
43	Pitch ratio	1.2500	Tube diameter, (mm)	25.400	
44	Layout angle	45	Tube material	Carbon steel	
45	Number U-Bend supports	1	Supports/baffle space		

## Program Messages

- 47 + Frequency ratios are based upon lowest natural or acoustic frequency  
 48 \* Items with asterisk exceed a conservative lower limit for vibration-free design. Review your case  
 49 using the procedure described in Online Help; You may find that a vibration problem is unlikely.


50  
51  
52  
53

444/07

Final Results										
Released to the following HTRI Member Company:										
sewon										
M.K.Park										
Xist Ver. 6.00 SP3 2013/08/16 10:01 SN: 1500213869					MEG Energy Units					
Min.Duty Case : Shell 1										
Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles										
1	Process Data		Hot Shellside		Cold Tubeside		Shellside Performance			
2	Fluid name	BP Frac Dilbit		TEG/Water (60%/40% wt)		Nom vel, X-flow/window 0.38 / 0.49				
3	Fluid condition	Sens. Liquid		Sens. Liquid		Flow fractions for heat transfer 0.675				
4	Total flow rate	(kg/hr)	404707	478370		A=0.0042 B=0.6193 C=0.0424 E=0.1821 F=0.1520				
5	Weight fraction vapor, In/Out	(-)	0.000	0.000						
6	Temperature, In/Out	(Deg C)	131.10	62.40						
7	Temperature, Average/Skin	(Deg C)	119.57	68.70						
8	Wall temperature, Min/Max	(Deg C)	73.88	73.54						
9	Pressure, In/Average	(kPa)	984.014	882.096						
10	Pressure drop, Total/Allowed	(kPa)	20.644	33.948						
11	Velocity, Mid/Max allow	(m/s)	0.30	0.90						
12	Mole fraction inert	(-)								
13	Average film coef.	(W/m2-K)	388.83	1809.68						
14	Heat transfer safety factor	(-)	1.000	1.000						
15	Fouling resistance	(m2-K/W)	0.000616	0.000180						
16	Overall Performance Data									
17	Overall coef., Req'd/Clean/Actual	(W/m2-K)	100.83 /	305.31 /	243.47					
18	Heat duty, Calculated/Specified	(kW)	4176. /							
19	Effective overall temperature difference	(Deg C)	49.6							
20	EMTD = (MTD) * (DELTA) * (F/G/H)	(Deg C)	49.87 *	0.9953 *	1.0000					
21										
22										
23	See Runtime Messages Report for warnings.									
24										
25										
26	Exchanger Fluid Volumes									
27	Approximate shellside (L)	5023.9								
28	Approximate tubeside (L)	4515.8								
29	Shell Construction Information									
30	TEMA shell type	BEU	Shell ID	(mm)	1143.00					
31	Shells Series	1 Parallel 2	Total area	(m2)	1125.71					
32	Passes Shell	1 Tube 4	Eff. area	(m2/shell)	556.411					
33	Shell orientation angle (deg)	0.00								
34	Impingement present	Circular plate	Impingement diameter/nozzle	1.1						
35	Pairs seal strips	0	Passlane seal rods (mm)	25.400	No. 20					
36	Shell expansion joint	No	Full support at U-Bend	No						
37	Weight estimation Wet/Dry/Bundle	26893.6 /	17360.4 /	10093.9 (kg/shell)						
38										
39	Baffle Information									
40	Type	Perpend. Single-Seg.	Baffle cut (% dia)	24.50						
41	Crosspasses/shellpass	17	No. (Pct Area)	(mm) to C.L.						
42	Central spacing	(mm)	486.000	1 20.45	291.465					
43	Inlet spacing	(mm)	1088.00	2 0.00	0.000					
44	Outlet spacing	(mm)	932.000							
45	Baffle thickness	(mm)	12.700							
46										
47										
48	Tube information									
49	Tube type	Plain	Tubecount per shell	792						
50	Length to tangent	(mm)	8534.	Pct tubes removed (both)	4.42					
51	Effective length	(mm)	8804.	Outside diameter	(mm)	25.400				
52	Total tubesheet	(mm)	102.000	Wall thickness	(mm)	2.110				
53	Area ratio	(out/in)	1.1992	Pitch (mm)	31 7500 Ratio	1.2500				
54	Tube metal	Carbon steel	Tube pattern (deg)	45						
						Shell Nozzles				
						Inlet	Outlet	Liquid Outlet		
						Number at each position	1	1	0	
						Diameter	(mm)	242.875	242.875	
						Velocity	(m/s)	1.37	1.35	
						Pressure drop	(kPa)	2.549	0.409	
						Height under nozzle	(mm)	61.187	1143.00	
						Nozzle R-V-SQ	(kg/m-s2)	1665.51	1637.60	
						Shell ent.	(kg/m-s2)	2057.22	0.00	
						Thermal Resistance				
						Shell	Tube	Fouling	Metal	Over Des
						62.62	16.13	20.25	1.00	141.48
						Total fouling resistance 8.313e-4				
						Differential resistance 0.00581				
						Tube Nozzle				
						Inlet	Outlet	Liquid Outlet		
						Diameter	(mm)	193.675	193.675	
						Velocity	(m/s)	2.12	2.14	
						Pressure drop	(kPa)	2.636	1.692	
						Nozzle R-V-SQ	(kg/m-s2)	4792.02	4834.66	
						Annular Distributor				
						Inlet	Outlet			
						Length	(mm)			
						Height	(mm)			
						Slot area	(mm2)			
						Diametral Clearances (mm)				
						Baffle-to-shell	Bundle-to-shell	Tube-to-baffle		
						6.3500	21.7000	0.3969		



45/09

Final Results									
Released to the following HTRI Member Company:									
sewon									
M.K.Park									
Xist Ver. 6.00 SP3 2013/08/16 10:01 SN: 1500213869					MEG Energy Units				
Min.Duty Case : Shell 2									
Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles									
Process Data		Hot Shellside		Cold Tubeside		Shellside Performance			
Fluid name		BP Frac Dilbit		TEG/Water (60%/40% wt)		Nom vel, X-flow/window		0.37 / 0.49	
Fluid condition		Sens. Liquid		Sens. Liquid		Flow fractions for heat transfer 0.663			
Total flow rate		404707		478370		A=0.0029 B=0.6040 C=0.0404 E=0.1894 F=0.1632			
Weight fraction vapor, In/Out		0.000		0.000					
Temperature, In/Out		108.03		52.86					
Temperature, Average/Skin		73.11		65.22					
Wall temperature, Min/Max		60.54		71.40					
Pressure, In/Average		951.943		899.822					
Pressure drop, Total/Allowed		250.000		275.000					
Velocity, Mid/Max allow		0.29		0.89					
Mole fraction inert									
Average film coef.		356.01		1458.12					
Heat transfer safety factor		1.000		1.000					
Fouling resistance		0.000616		0.000180					
Overall Performance Data									
Overall coef., Req'd/Clean/Actual		92.80 /		272.36 /		222.05			
Heat duty, Calculated/Specified		3122. /							
Effective overall temperature difference		40.4							
EMTD = (MTD) * (DELTA) * (F/G/H)		40.60 *		0.9952 *		1.0000			
See Runtime Messages Report for warnings.									
Exchanger Fluid Volumes									
Approximate shellside (L)		5023.9							
Approximate tubeside (L)		4515.8							
Shell Construction Information									
TEMA shell type		BEU		Shell ID		(mm)		1143.00	
Shells Series		1 Parallel 2		Total area		(m2)		1125.71	
Passes Shell		1 Tube 4		Eff. area		(m2/shell)		556.411	
Shell orientation angle (deg)		0.00							
Impingement present		No							
Pairs seal strips		0		Passlane seal rods (mm)		25.400		No. 20	
Shell expansion joint		No							
Weight estimation Wet/Dry/Bundle		26902.6 /		17369.4 /		10102.8 (kg/shell)			
Baffle Information									
Type		Perpend. Single-Seg.		Baffle cut (% dia)		24.50			
Crosspasses/shellpass		17		No. (Pct Area)		(mm) to C.L.			
Central spacing		(mm) 486.000		1		20.35		291.465	
Inlet spacing		(mm) 932.000		2		0.00		0.000	
Outlet spacing		(mm) 1088.00							
Baffle thickness		(mm) 12.700							
Tube Information									
Tube type		Plain		Tubecount per shell		792			
Length to tangent		(mm) 8534.		Pct tubes removed (both)		3.91			
Effective length		(mm) 8804.		Outside diameter		(mm)		25.400	
Total tubesheet		(mm) 102.000		Wall thickness		(mm)		2.110	
Area ratio		(out/in) 1.1992		Pitch (mm)		31.7500		Ratio 1.2500	
Tube metal		Carbon steel		Tube pattern (deg)		45			
Shellside Heat Transfer Corrections									
Total						Beta		Gamma	
0.919						0.919		1.000	
End						Fin			
0.952						1.000			
Pressure Drops (Percent of Total)									
Cross						Window		Ends	
66.37						17.44		5.91	
Inlet						Shell		Tube	
3.58						7.38			
MOMENTUM						0.00		Outlet	
6.71						4.73			
Two-Phase Parameters									
Method						Inlet		Center	
Outlet						Mix F			
H. T. Parameters						Shell		Tube	
Overall wall correction						0.852		1.012	
Midpoint						Prandtl no.		304.37	
30.02						Midpoint		Reynolds no.	
421						6643			
Bundle inlet						Reynolds no.		283	
5945						Bundle outlet		Reynolds no.	
7357						Fouling layer		(mm)	
Thermal Resistance									
Shell						Tube		Fouling	
62.37						18.26		18.47	
0.89						Over Des			
139.79						Total fouling resistance		8.313e-4	
Differential resistance						0.0063			
Shell Nozzles									
Inlet at channel end-No						Inlet		Outlet	
Number at each position						1		1	
0						Diameter		(mm)	
242.875						242.875			
Velocity						(m/s)		1.35	
1.33						Pressure drop		(kPa)	
1.535						Height under nozzle		(mm)	
1143.00						61.187			
Nozzle R-V-SQ						(kg/m-s2)		1637.60	
1616.44						Shell ent.		(kg/m-s2)	
1155.68									
Tube Nozzle						Inlet		Outlet	
RADIAL						RADIAL		Liquid	
Diameter						(mm)		193.675	
193.675						Velocity		(m/s)	
2.11						2.12			
Pressure drop						(kPa)		2.618	
1.677						Nozzle R-V-SQ		(kg/m-s2)	
4760.25						4792.02			
Annular Distributor						Inlet		Outlet	
Length						(mm)			
Height						(mm)			
Slot area						(mm2)			
Diametral Clearances (mm)									
Baffle-to-shell						Bundle-to-shell		Tube-to-baffle	
6.3500						21.7000		0.3969	



46/49

Final Results												
Released to the following HTRI Member Company:												
<div>sewon</div> <div>M.K.Park</div>												
Xist Ver. 6.00 SP3 2013/08/16 10:01 SN: 1500213969					MEG Energy Units							
Min.Duty Case : Shell 3												
Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles												
1	Process Data		Hot Shellside		Cold Tubeside		Shellside Performance					
2	Fluid name	BP Frac Dilbit	TEG/Water (60%/40% wt)		Sens. Liquid		Norm vel, X-flow/window 0.37 / 0.48					
3	Fluid condition	Sens. Liquid	Sens. Liquid				Flow fractions for heat transfer 0.659					
4	Total flow rate	(kg/hr)	404707		478370		A=0.0022 B=0.6014 C=0.0392 E=0.1987 F=0.1585					
5	Weight fraction vapor, In/Out	(--)	0.000	0.000	0.000	0.000						
6	Temperature, In/Out	(Deg C)	89.90	75.83	45.61	52.87						
7	Temperature, Average/Skin	(Deg C)	82.87	62.09	49.24	56.15						
8	Wall temperature, Min/Max	(Deg C)	53.76	62.29	53.57	61.97						
9	Pressure, In/Average	(kPa)	940.516	926.016	954.973	936.266						
10	Pressure drop, Total/Allowed	(kPa)	29.000	250.000	37.424	275.000						
11	Velocity, Mid/Max allow	(m/s)	0.29		0.89							
12	Mole fraction inert	(--)										
13	Average film coef.	(W/m2-K)		333.44		1200.68						
14	Heat transfer safety factor	(--)		1.000		1.000						
15	Fouling resistance	(m2-K/W)		0.000616		0.000180						
16	Overall Performance Data											
17	Overall coef., Req'd/Clean/Actual	(W/m2-K)	85.60	/	247.67	/	205.36					
18	Heat duty, Calculated/Specified	(kW)	2353.	/								
19	Effective overall temperature difference	(Deg C)	33.0									
20	EMTD = (MTD) * (DELTA) * (F/G/H)	(Deg C)	33.12	*	0.9950	*	1.0000					
21												
22												
23	See Runtime Messages Report for											
24	warnings.											
25												
26	Exchanger Fluid Volumes											
27	Approximate shellside (L)	5023.9										
28	Approximate tubeside (L)	4515.8										
29	Shell Construction Information											
30	TEMA shell type	BEU	Shell ID	(mm)	1143.00							
31	Shells Series	1 Parallel 2	Total area	(m2)	1125.71							
32	Passes Shell	1 Tube 4	Eff. area	(m2/shell)	556.411							
33	Shell orientation angle (deg)	0.00										
34	Impingement present	Circular plate	Impingement diameter/nozzle	1.1								
35	Pairs seal strips	0	Passlane seal rods (mm)	25.400	No. 20							
36	Shell expansion joint	No	Full support at U-Bend	No								
37	Weight estimation Wet/Dry/Bundle	26909.5	/	17376.4	/	10109.8	(kg/shell)					
38												
39	Baffle Information											
40	Type	Perpend. Single-Seg.	Baffle cut (% dia)	24.50								
41	Crosspasses/shellpass	17	No. (Pct Area)	(mm) to C.L.								
42	Central spacing	(mm)	486.000	1	20.45	291.465						
43	Inlet spacing	(mm)	1088.00	2	0.00	0.000						
44	Outlet spacing	(mm)	932.000									
45	Baffle thickness	(mm)	12.700									
46												
47												
48	Tube Information											
49	Tube type	Plain	Tube count per shell	792								
50	Length to tangent	(mm)	8534.	Pct tubes removed (both)	4.42							
51	Effective length	(mm)	8804.	Outside diameter	(mm)	25.400						
52	Total tubesheet	(mm)	102.000	Wall thickness	(mm)	2.110						
53	Area ratio	(out/in)	1.1992	Pitch (mm)	31.7500	Ratio	1.2500					
54	Tube metal	Carbon steel	Tube pattern (deg)	45								
							Shell Nozzles					
							Inlet	Outlet	Liquid			
							1	1	0			
							Diameter	(mm)	242.875	242.875		
							Velocity	(m/s)	1.33	1.32		
							Pressure drop	(kPa)	2.880	0.400		
							Height under nozzle	(mm)	61.187	1143.00		
							Nozzle R-V-SQ	(kg/m-s2)	1616.44	1600.28		
							Shell ent.	(kg/m-s2)	1996.60	0.00		
							Thermal Resistance					
							Shell	Tube	Fouling	Metal	Over Des	
							61.59	20.51	17.08	0.82	139.91	
							Total fouling resistance			8.313e-4		
							Differential resistance			0.00681		
							Shell Nozzles			Liquid		
							Inlet	Outlet	Outlet			
							1	1	0			
							Diameter	(mm)	242.875	242.875		
							Velocity	(m/s)	1.33	1.32		
							Pressure drop	(kPa)	2.880	0.400		
							Height under nozzle	(mm)	61.187	1143.00		
							Nozzle R-V-SQ	(kg/m-s2)	1616.44	1600.28		
							Shell ent.	(kg/m-s2)	1996.60	0.00		
							Tube Nozzle			Inlet	Outlet	Liquid
							RADIAL	RADIAL	Outlet			
							Diameter	(mm)	193.675	193.675		
							Velocity	(m/s)	2.10	2.11		
							Pressure drop	(kPa)	2.605	1.866		
							Nozzle R-V-SQ	(kg/m-s2)	4736.37	4760.26		
							Annular Distributor			Inlet	Outlet	
							Length	(mm)				
							Height	(mm)				
							Slot area	(mm2)				
							Diametral Clearances (mm)					
							Baffle-to-shell	Bundle-to-shell	Tube-to-baffle			
							6.3500	21.7000	0.3969			

49/49

Final Results									
Released to the following HTRI Member Company:									
sewon									
M.K.Park									
Xist Ver. 6.00 SP3 2013/08/16 10:01 SN: 1500213869					MEG Energy Units				
Min.Duty Case : Shell 4									
Rating - Horizontal Multipass Flow TEMA BEU Shell With Single-Segmental Baffles									
1 Process Data		Hot Shellside		Cold Tubeside		Shellside Performance			
2 Fluid name	BP Frac Dilbit		TEG/Water (60%/40% wt)		Nom vel, X-flow/window 0.36 / 0.48				
3 Fluid condition	Sens. Liquid		Sens. Liquid		Flow fractions for heat transfer 0.661				
4 Total flow rate	(kg/hr)	404707	478370		A=0.0017 B=0.6056 C=0.0328 E=0.2048 F=0.1551				
5 Weight fraction vapor, In/Out	(--)	0.000	0.000						
6 Temperature, In/Out	(Deg C)	75.84	40.00						
7 Temperature, Average/Skin	(Deg C)	70.27	42.81						
8 Wall temperature, Min/Max	(Deg C)	46.18	46.02						
9 Pressure, In/Average	(kPa)	911.529	994.015						
10 Pressure drop, Total/Allowed	(kPa)	34.162	39.037						
11 Velocity, Mid/Max allow	(m/s)	0.28	0.89						
12 Mole fraction inert	(--)								
13 Average film coef.	(W/m <sup>2</sup> -K)	320.27	1008.41						
14 Heat transfer safety factor	(--)	1.000	1.000						
15 Fouling resistance	(m <sup>2</sup> -K/W)	0.000616	0.000180						
16 Overall Performance Data									
17 Overall coef., Req'd/Clean/Actual	(W/m <sup>2</sup> -K)	80.55 /	229.83 /		192.94				
18 Heat duty, Calculated/Specified	(kW)	1808. /							
19 Effective overall temperature difference	(Deg C)	26.9							
20 EMTD = (MTD) * (DELTA) * (F/G/H)	(Deg C)	27.03 *	0.9946 *		1.0000				
23 See Runtime Messages Report for warnings.									
25 Exchanger Fluid Volumes									
27 Approximate shellside (L)		5023.9							
28 Approximate tubeside (L)		4515.8							
29 Shell Construction Information									
30 TEMA shell type	BEU	Shell ID	(mm)	1143.00					
31 Shells Series	1 Parallel 2	Total area	(m <sup>2</sup> )	1125.71					
32 Passes Shell	1 Tube 4	Eff. area	(m <sup>2</sup> /shell)	556.411					
33 Shell orientation angle (deg)	0.00								
34 Impingement present	No								
35 Pairs seal strips	0	Passlane seal rods (mm)	25.400	No. 20					
36 Shell expansion joint	No	Full support at U-Bend	No						
37 Weight estimation Wet/Dry/Bundle	26914.8 /	17381.7 /	10115.1 (kg/shell)						
39 Baffle Information									
40 Type	Perpend. Single-Seg.	Baffle cut (% dia)	24.50						
41 Crosspasses/shellpass	17	No. (Pct Area)	(mm) to C.L.						
42 Central spacing	(mm)	486.000	1	20.35	291.465				
43 Inlet spacing	(mm)	932.000	2	0.00	0.000				
44 Outlet spacing	(mm)	1088.00							
45 Baffle thickness	(mm)	12.700							
48 Tube Information									
49 Tube type	Plain	Tubecount per shell	792						
50 Length to tangent	(mm)	8534.	Pct tubes removed (both)	3.91					
51 Effective length	(mm)	8804.	Outside diameter	(mm)	25.400				
52 Total tubesheet	(mm)	102.000	Wall thickness	(mm)	2.110				
53 Area ratio	(out/in)	1.1992	Pitch (mm)	31.7500	Ratio 1.2500				
54 Tube metal	Carbon steel	Tube pattern (deg)	45						
Shellside Heat Transfer Corrections									
Total	Beta	Gamma	End	Fin					
0.920	0.920	1.000	0.959	1.000					
Pressure Drops (Percent of Total)									
Cross	Window	Ends	Nozzle	Shell	Tube				
70.18	16.02	6.64	Inlet	2.34	6.65				
MOMENTUM			0.00	Outlet	4.81	4.25			
Two-Phase Parameters									
Method	Inlet	Center	Outlet	Mix F					
H. T. Parameters									
Overall wall correction	Shell	Tube							
Midpoint	Prandtl no.	778.52	42.67						
Midpoint	Reynolds no.	151	4652						
Bundle inlet	Reynolds no.	98	4334						
Bundle outlet	Reynolds no.	52	4972						
Fouling layer	(mm)								
Thermal Resistance									
Shell	Tube	Fouling	Metal	Over Des					
60.24	22.95	16.05	0.76	139.55					
Total fouling resistance				8.313e-4					
Differential resistance				0.00723					
Shell Nozzles									
Inlet at channel end-No	Inlet	Outlet	Liquid						
Number at each position	1	1	0						
Diameter	(mm)	242.875	242.875						
Velocity	(m/s)	1.32	1.31						
Pressure drop	(kPa)	0.800	1.645						
Height under nozzle	(mm)	1143.00	61.187						
Nozzle R-V-SQ	(kg/m-s <sup>2</sup> )	1600.28	1587.74						
Shell ent.	(kg/m-s <sup>2</sup> )	0.00	1135.17						
Tube Nozzle									
Diameter	(mm)	193.675	193.675						
Velocity	(m/s)	2.09	2.10						
Pressure drop	(kPa)	2.595	1.858						
Nozzle R-V-SQ	(kg/m-s <sup>2</sup> )	4718.06	4736.37						
Annular Distributor									
Length	(mm)								
Height	(mm)								
Slot area	(mm <sup>2</sup> )								
Diametral Clearances (mm)									
Baffle-to-shell	Bundle-to-shell	Tube-to-baffle							
6.3500	21.7000	0.3969							