



 MEG ENERGY	CHRISTINA LAKE REGIONAL PROJECT Phase 3A EPC for Central Plant Facilities SLI Project No. 511036	 SNC-LAVALIN

 SNC-LAVALIN	<input type="checkbox"/> A1 Not suitable to initiate fabrication. modify as noted. resubmit for review
	<input type="checkbox"/> B1 Suitable to initiate fabrication as noted. modify as noted. resubmit for review
Vendor's drawing review for conformity with specifications and design drawing.	<input type="checkbox"/> C1 Suitable to fabricate to completion as noted. submit final documents including as-builts as required
This review does not relieve the vendor of his responsibility for errors in design and detailing as detailed in his contract.	<input type="checkbox"/> D1 Suitable to fabricate to completion. submit final documents including as-built documents as required
	<input type="checkbox"/> E1 Not suitable as final documents as noted. modify as noted and resubmit.
	<input checked="" type="checkbox"/> F1 Suitable as final documents. no further resubmittal required (unless revised by vendor)
Vendor: Sewon Cellontech Co. Ltd. - P00007 No.: E0351-3AE324-P-02 Rev: 1 Date Rec'd 2013/09/04	
Doc. Title: L53.51, L53.53 - THERMAL DESIGN CALCULATION - Tag:3A-E-324A/B	
Client Code:	Project: MEG Phase 3A EPC
Reviewed by: <i>SS</i>	Document No
Date: <i>11-Sept-2013</i>	P-5310-01-0038
	Submittal 02

 SEWON CELLONTECH	DOCUMENT FOR EQUIPMENT	SWC JOB NO	E-0351
		ITEM NO.	3A-E-324A/B
		SWC DOC. NO.	E0351-3AE324-P-02



FOR APPROVAL


 MEG Energy Corp.		 SNC-LAVALIN	
P.O NO.		P-5310-01	
PROJECT NAME	CLRP Phase 3A Central Plant Facility: EPC		
PROJECT NO.	511036		
DOCUMENT TITLE	THERMAL DESIGN CALCULATION		
ITEM NO.	ITEM DESCRIPTION		
3A-E-324A/B	MP BLOWDOWN / GLYCOL EXCHANGER		



- Total Sheet : 2 Sheet (Including This Cover)

1	M. K. Park 8/16/2013	T.W.KIM 8/19/13	Y.S.JI 8/21/2013	SECOND ISSUE
0	M.K.PARK	T.W.KIM	Y.S.JI	FIRST ISSUED
REV	PREPARED BY	REVIEWED BY	APPROVED BY	DESCRIPTION

SEWON CELLONTECH CO.,LTD.

 SEWON CELLONTECH				TUBULAR HEAT EXCHANGER			
				SHEET 2 OF 21			
CUSTOMER	MEG Energy Corp.			REV	MADE BY	CHECKED BY	APPROVED BY
LOCATION	CANADA			0	-	-	-
JOB NO.	511036			1	-	-	-
SERVICE	MP Blowdown / Glycol Exchanger						
ITEM NO.	3A-E-324A/B (Max Duty Case)						
Total	2	Shells, Connected in	1 Parallel 2 Series Shells	Install	<input checked="" type="checkbox"/> Hor. <input type="checkbox"/> Vert.	Size	850.0 ID - 4,877.0 L
Code	ASME Sec.VIII Div.1 (STAMP), TEMA, API660 TEMA Type AET			TEMA Class	R	Effective Area	129.43 m ² /Shell
PERFORMANCE OF ONE BATTERY							
				SHELL SIDE		TUBE SIDE	
				INLET		OUTLET	
Fluid Circulated				TEG/Water (60/40 wt%)		MP Blowdown	
Total Fluid kg/hr				433727		207611	
Vapor kg/hr MW							
Liquid kg/hr MW				433727		207611	
Steam kg/hr							
Water kg/hr						207611	
Noncondensable kg/hr MW						207611	
Operating Temperature °C				40.00		200.00	
Operating Pressure kPa				994.015		1555.02	
Density kg/m ³ L / v				1078.0		864.65	
Viscosity cP L / v				4.6640		0.1343	
Thermal Conductivity W/m·°C L / v				0.3281		0.6635	
Specific Heat kJ/kg·°C L / v				3.2231		4.4941	
Latent Heat kJ/kg							
Bubble / Dew Point °C				/		/	
Critical Press. / Temp. kPa / °C				/		/	
Velocity m/sec				1.07		2.01	
Pressure Drop kPa				Allow. 100.000		Calc. 86.141	
Fouling Resistance m ² ·°C/kW				0.088		0.176	
Film Coefficient W/m ² ·K				4,194.01		13,243.20	
Overall Coefficient W/m ² ·K				Clean 2704.25		Design 1458.15	
Heat Duty KW				26,147.00		LMTD °C MTD 69.3 °C	
CONSTRUCTION							
Design Pressure		Design Temperature		1500.0 / FV kPa.G -29 / 214 °C		1950.0 / FV kPa.G -29 / 214 °C	
No. of Passes				1		4	
Tubes No.		352 / Shell, Size 25.40 mm, Thickness 2.11 (Min.) mm (BWG: 14)		Length		4,877.0 mm	
Shell		850 mm ID		Tube Pitch		31.75 mm	
Baffles		Cross Baffle 8+1S (Note 9) ea / Shell, Type Single Seg. (Hor.), Cut 25.0 % Dia., Spacing c/c 450.0 mm, End - mm		Layout angle		90 °	
pV ²		Inlet Nozzle 2,870.52, Entrance 3,098.62, Outlet Nozzle 3,016.01 kg/m·sec ²		Impingement plate		Circular Plate	
Material		Tube SA 179 Seamless, Tube Sheet SA 266 Gr.2		Shell & Cover SA 516 GR. 70N		Channel & Cover SA 516 GR. 70N	
Estimated Weight		Empty Weight kg, Bundle Weight kg		Full Water Weight		kg	
Corrosion Allowance		Shell side 3.2 mm, Tube side 3.2 mm		Tube Joints:		Rolled (two grooves) and Expanded	
Insulation		Shell side 64 mm, Tube side 64 mm					
MEAN METAL		Temperature, °C		Pressure, kPa.G			
TEMPERATURE		Shell Tube		Shell Tube			
Normal Operating		-		-			
Startup		-		-			
NOZZLE		SHELL SIDE		TUBE SIDE			
		Tag No NPS Remarks		Tag No NPS Remarks			
Inlet		S1 1 12		T1 1 8			
Outlet		S2 1 12		T2 1 8			
Vent		(Note 8)		(Note 8)			
Drain		(Note 8)		(Note 8)			
Thermowell							
Util. Con.							
RATING		RFWN 300#		RFWN 300#			
Remarks							
1) Seller shall verify and guarantee thermal rating of the unit. 2) Ribbon flow pass arrangement shall be used. 3) Unit shell side inlet nozzle is located near the channel head. 4) Exchanger is to be designed for future field hydrotest in the fully corroded condition. 5) Exchangers to be designed for liquid full condition at S.G. = 1.079.							



SEWON CELLONTECH

TUBULAR HEAT EXCHANGER

SHEET 3 OF 21

CUSTOMER	MEG Energy Corp.	REV	MADE BY	CHECKED BY	APPROVED BY	DATE
LOCATION	CANADA	0	-	-	-	07-01-2013
JOB NO.	511036	1	-	-	-	08-14-2013
SERVICE	MP Blowdown / Glycol Exchanger					
ITEM NO.	3A-E-324A/B (Min Duty Case)					

Total	2	Shells, Connected in	1	Parallel	2	Series Shells	Install	<input checked="" type="checkbox"/> Hor. <input type="checkbox"/> Vert.	Size	850.0 ID - 4,877.0 L
Code	ASME Sec.VIII Div.1 (STAMP), TEMA, API660	TEMA Type	AET	TEMA Class	R	Effective Area	129.43	m ² /Shell		

PERFORMANCE OF ONE BATTERY

			SHELL SIDE				TUBE SIDE			
			INLET		OUTLET		INLET		OUTLET	
Fluid Circulated			TEG/Water (60/40 wt%)				MP Blowdown			
Total Fluid kg/hr			322586				154412			
Vapor	kg/hr	MW								
Liquid	kg/hr	MW	322586		322586		154412		154412	
Steam	kg/hr									
Water	kg/hr					154412		154412		
Noncondensable	kg/hr	MW								
Operating Temperature °C			40.00		105.00		200.00		95.00	
Operating Pressure kPaa			994.015				1555.02			
Density	kg/m3	L / v	1078.0		1026.0		864.65		962.54	
Viscosity	cP	L / v	4.6610		1.3460		0.1343		0.2976	
Thermal Conductivity	W/m·°C	L / v	0.3281		0.3401		0.6635		0.6765	
Specific Heat	kJ/kg·°C	L / v	3.2231		3.4561		4.4941		4.2074	
Latent Heat	kJ/kg									
Bubble / Dew Point	°C	/		/		/		/		
Critical Press. / Temp.	kPaa / °C	/		/		/		/		
Velocity	m/sec			0.81				1.50		
Pressure Drop	kPa	Allow.		100.000		Calc.		49.135		
Fouling Resistance	m2·°C/kW			0.088				0.176		
Film Coefficient	W/m2·K			3,458.90				10,464.30		
Overall Coefficient	W/m2·K	Clean		2251.73		Calc.		1342.45		
Heat Duty	KW			19,447.00				Design		
						LMTD °C		MTD °C		
								1084.37		
								69.3 °C		

CONSTRUCTION

Design Pressure	Design Temperature	/	kPa.G	/	°C	/	kPa.G	/	°C	
No. of Passes										
Tubes No.	/ Shell	Size	mm	Thickness	(Min.) mm	(BWG :)	Length	mm		
Shell		mm ID		Tube Pitch	mm	Layout angle °	Leffective	- mm		
Baffles	Cross Baffle	ea / Shell	Type	Cut	- % Dia.	Spacing c/c	mm	End	- mm	
pv²	Inlet Nozzle	1,587.89	Entrance	1,713.76	Outlet Nozzle	1,668.36	kg/m-sec2	Impingement plate		
Material	Tube	Shell & Cover				Channel & Cover				
	Tube Sheet	Baffle				Expansion Joint				
Estimated Weight	Empty Weight	kg	Bundle Weight			kg	Full Water Weight			kg
Corrosion Allowance	Shell side	mm	Tube side	mm	Tube Joints :					
Insulation	Shell side	mm	Tube side	mm						

MEAN METAL	Temperature, °C		Pressure, kPa.G	
	Shell	Tube	Shell	Tube
Normal Operating	-	-	-	-
Startup	-	-	-	-

Blowdown Water Analysis

Water Analysis (mg/l as ion unless noted)			Normal	Max.
Ca ⁺⁺	0.36	0.44		
Mg ⁺⁺	0.36	0.44		
Na ⁺	3707	10709		
K ⁺	6.92	36.12		
Fe ⁺⁺	4.47	8.29		
Mn ⁺⁺	0.22	0.75		
Ba ⁺⁺	0.31	3.04		
Sr ⁺⁺	0.89	8.22		
HCO ₃ ⁻	0.0	0.0		
CO ₃ ⁻	127	333		
OH ⁻	305	775		
SO ₄ ⁻	18.81	39.60		
Cl ⁻	4929	14529		
Silica ppm as SiO ₂	214.1	262.1		
Sulphides ppm as S ⁻	0.0	0.0		
TOC ppm as TOC	0.46	4.63		
TDS ppm as ion	9314	26706		
TSS ppm TSS	0.0	0.0		
Oil & Grease ppm oil in water	0.0	0.0		
Total Hardness ppm as CaCO ₃	2.36	2.88		
P-Alk (ppm as CaCO ₃)	1004	2559		
M-Alk (ppm as CaCO ₃)	1111	2837		
Dissolved O ₂	-	-		
Estimated pH	12.16	12.61		

NOZZLE	SHELL SIDE				TUBE SIDE			
	Tag	No	NPS	Remarks	Tag	No	NPS	Remarks
Inlet								
Outlet								
Vent								
Drain								
Liquid Outlet								
Thermowell								
Util. Con.								
RATING								




TUBULAR HEAT EXCHANGER

SHEET 4 OF 21

CUSTOMER	MEG Energy Corp.	REV	MADE BY	CHECKED BY	APPROVED BY	DATE
LOCATION	CANADA	0	-	-	-	07-01-2013
JOB NO.	511036	1	-	-	-	08-14-2013
SERVICE	MP Blowdown / Glycol Exchanger					
ITEM NO.	3A-E-324A/B					

Shell 1





SHEET 5 OF 21


CUSTOMER	MEG Energy Corp.	REV	MADE BY	CHECKED BY	APPROVED BY	DATE
LOCATION	CANADA	0	-	-	-	07-01-2013
JOB NO.	511036	1	-	-	-	08-14-2013
SERVICE	MP Blowdown / Glycol Exchanger					
ITEM NO.	3A-E-324A/B					

[illegible]

**SEWON CELLONTECH****TUBULAR HEAT EXCHANGER**

SHEET 6 OF 21

CUSTOMER	MEG Energy Corp.	REV	MADE BY	CHECKED BY	APPROVED BY	DATE
LOCATION	CANADA	0	-	-	-	07-01-2013
JOB NO.	511036	1	-	-	-	08-14-2013
SERVICE	MP Blowdown / Glycol Exchanger					
ITEM NO.	3A-E-324A/B					

3A-E-324

1/4

I.D.-SHELL	850.0 ID	(AET)
ALLOWABLE O.T.L	725.3	mm
ACTUAL O.T.L	725.3	mm
SEAL STRIP	2.0	Pairs
SEAL Rod	N/A	ea

TOTAL 352 HOLES FOR 25.4 OD TUBES ON 31.75 SQUARE PITCH.
4 PASSES. BAFFLE CUT SINGLE SEGM. 25% DIA.

Remarks

Thermal/Hydraulic/ Vibration **Verification Report**

(Rev.1)

3A-E-324A/B

Client : MEG Energy Corp.
Project : MEG Energy Christina Lake Regional Project
Phase 3A-Central Plant Facilities
Date : 08-14-2013

3A-E-324A/B (Max Duty Case)

The Thermal/Hydraulic/Vibration calculations are performed by using HTRI Xist Ver. 6.00 SP3.

The process condition and the physical properties are based on Buyer data sheet.

For the design result (the geometry data), please refer to the Equipment data sheet and Fabrication drawing.

1. Thermal and Hydraulic performance

- Thermal performance :	<u>2.33</u>	% Over - Design Case	-----	O.K.
- Pressure drop :				
Shell-side	<u>86.142</u>	<	100.000 kPa	----- O.K
tube-side	<u>109.825</u>	<	120.000 kPa	----- O.K

2. Vibration Analysis

- Fluidelastic instability :	characteristic values	<<	criteria	-----	O.K.
- Acoustic vibration :	characteristic values	<<	criteria	-----	O.K.
- Tube vibration check:	characteristic values	<<	criteria	-----	O.K.
- Bundle Entrance/Exit :	characteristic values	<<	criteria	-----	O.K.
- Shell Entrance /Exit:	characteristic values	<<	criteria	-----	O.K.

9/24

3A-E-324A/B (Max Duty Case) - Shell 1

Used Program : HTRI Xist Ver.6.00 SP.3 Vibration Analysis

VALUE TO BE CHECKED	Inlet	Center	Outlet	RECOMMEND LIMIT	CONCLUSION
Unsupported span (mm)	1178.	900.	1180.	1879 (By TEMA)	O.K
Length / TEMA maximum span	0.627	0.479	0.628	< 1.0 TEMA	O.K
Fluidelastic Instability Check					
Baffle tip cross velocity ratio	0.3531	0.3481	0.3784	< 0.8	O.K
Ave. crossflow velocity ratio	0.3164	0.3119	0.3391	< 0.8	O.K
Acoustic Vibration Check					
Vortex shedding ratio	-	-	-	-	-
Tubulent buffeting ratio	-	-	-	-	-
Tube Vibration Check					
Vortex shedding ratio	0.181	0.303	0.186	< 0.5	O.K
Tubulent buffeting ratio	-	-	-	-	-
Bundle Entrance / Exit		Entrance	Exit		
Fluidelastic Instability ratio		0.183	0.172	< 0.8	O.K
Vortex shedding ratio		0.275	0.247	< 0.5	O.K
Shell Entrance / Exit					
Velocity (m/sec)		1.71	1.34	< If velocity is exceed 2.03 / 1.94	O.K.
pv2 (kg/m-s2)		3098.66	1851.54	< 5953 by TEMA	O.K.

10/21

Vibration Analysis

Released to the following HTRI Member Company:

sewon
M.K.Park

Xist Ver. 6.00 SP3 2013/08/19 12:45 SN: 1500213869

MEG Energy Units

Max.Duty Case : Shell 1

Rating - Horizontal Multipass Flow TEMA AET Shell With Single-Segmental Baffles

1	Shellside condition		Sens. Liquid	(Level 2.3)	
2	Axial stress loading	(MPa)	0.000	Added mass factor	1.517
3	Beta		2.570		
4	Position In The Bundle		Inlet	Center	Outlet
5	Length for natural frequency	(mm)	1178.	900.	1180.
6	Length/TEMA maximum span	(--)	0.627	0.479	0.628
7	Number of spans	(--)	5	5	5
8	Tube natural frequency	(Hz)	57.9 +	63.2	58.0
9	Shell acoustic frequency	(Hz)			
10	Flow Velocities		Inlet	Center	Outlet
11	Window parallel velocity	(m/s)	1.15	1.17	1.18
12	Bundle crossflow velocity	(m/s)	0.64	1.07	0.66
13	Bundle/shell velocity	(m/s)	0.30	0.50	0.31
14	Fluidelastic Instability Check		Inlet	Center	Outlet
15	Log decrement	HTRI	0.084	0.081	0.076
16	Critical velocity	(m/s)	2.03	3.44	1.94
17	Baffle tip cross velocity ratio	(--)	0.3531	0.3481	0.3784
18	Average crossflow velocity ratio	(--)	0.3164	0.3119	0.3391
19	Acoustic Vibration Check		Inlet	Center	Outlet
20	Vortex shedding ratio	(--)			
21	Chen number	(--)			
22	Turbulent buffeting ratio	(--)			
23	Tube Vibration Check		Inlet	Center	Outlet
24	Vortex shedding ratio	(--)	0.181	0.303	0.186
25	Parallel flow amplitude	(mm)	0.004	0.005	0.004
26	Crossflow amplitude	(mm)	0.070	0.070	0.073
27	Tube gap	(mm)	6.350	6.350	6.350
28	Crossflow RHO-V-SQ	(kg/m-s ²)	434.81	1197.37	445.15
29	Bundle Entrance/Exit				
30	(analysis at first tube row)			Entrance	Exit
31	Fluidelastic instability ratio	(--)		0.183	0.172
32	Vortex shedding ratio	(--)		0.275	0.247
33	Crossflow amplitude	(mm)		0.02472	0.01934
34	Crossflow velocity	(m/s)		0.97	0.88
35	Tubesheet to inlet/outlet support	(mm)		None	None
36	Shell Entrance/Exit Parameters			Entrance	Exit
37	Impingement plate			Yes	
38	Flow area	(m ²)		0.067	0.087
39	Velocity	(m/s)		1.71	1.34
40	RHO-V-SQ	(kg/m-s ²)		3098.66	1851.54
41	Shell type	AET	Baffle type	Single-Seg.	
42	Tube type	Plain	Baffle layout	Perpend.	
43	Pitch ratio	1.2500	Tube diameter, (mm)	25.400	
44	Layout angle	90	Tube material	Carbon steel	
45			Supports/baffle space		

Program Messages

- 47 + Frequency ratios are based upon lowest natural or acoustic frequency
- 48 * Items with asterisk exceed a conservative lower limit for vibration-free design. Review your case
- 49 using the procedure described in Online Help; You may find that a vibration problem is unlikely.

50
51
52
53

11/21

3A-E-324A/B (Max Duty Case) - Shell 2

Used Program : HTRI Xist Ver.6.00 SP.3 Vibration Analysis

VALUE TO BE CHECKED	Inlet	Center	Outlet	RECOMMEND LIMIT	CONCLUSION
Unsupported span (mm)	1180.	900.	1178.	1879 (By TEMA)	O.K
Length / TEMA maximum span	0.628	0.479	0.627	< 1.0 TEMA	O.K
Fluidelastic Instability Check					
Baffle tip cross velocity ratio	0.3386	0.3336	0.3612	< 0.8	O.K
Ave. crossflow velocity ratio	0.3034	0.2990	0.3237	< 0.8	O.K
Acoustic Vibration Check					
Vortex shedding ratio	-	-	-	-	-
Tubulent buffeting ratio	-	-	-	-	-
Tube Vibration Check					
Vortex shedding ratio	0.181	0.301	0.185	< 0.5	O.K
Tubulent buffeting ratio	-	-	-	-	-
Bundle Entrance / Exit		Entrance	Exit		
Fluidelastic Instability ratio		0.173	0.161	< 0.8	O.K
Vortex shedding ratio		0.269	0.241	< 0.5	O.K
Shell Entrance / Exit					
Velocity (m/sec)		1.68	1.31	< If velocity is exceed 2.11 / 2.02	O.K.
pv2 (kg/m-s ²)		3035.89	1798.67	< 5953 by TEMA	O.K.

Vibration Analysis

Released to the following HTRI Member Company:

sewon

M.K.Park

Xist Ver. 6.00 SP3 2013/08/19 12:45 SN: 1500213869

MEG Energy Units

Max.Duty Case : Shell 2

Rating - Horizontal Multipass Flow TEMA AET Shell With Single-Segmental Baffles

1	Shellside condition		Sens. Liquid	(Level 2.3)	
2	Axial stress loading	(MPa)	0.000	Added mass factor	1.517
3	Beta		2.570		
4	Position In The Bundle		Inlet	Center	Outlet
5	Length for natural frequency	(mm)	1180.	900.	1178.
6	Length/TEMA maximum span	(--)	0.628	0.479	0.627
7	Number of spans	(--)	5	5	5
8	Tube natural frequency	(Hz)	57.8 +	63.3	58.2
9	Shell acoustic frequency	(Hz)			
10	Flow Velocities		Inlet	Center	Outlet
11	Window parallel velocity	(m/s)	1.15	1.16	1.17
12	Bundle crossflow velocity	(m/s)	0.64	1.07	0.65
13	Bundle/shell velocity	(m/s)	0.30	0.49	0.30
14	Fluidelastic Instability Check		Inlet	Center	Outlet
15	Log decrement	HTRI	0.091	0.088	0.083
16	Critical velocity	(m/s)	2.11	3.57	2.02
17	Baffle tip cross velocity ratio	(--)	0.3386	0.3336	0.3612
18	Average crossflow velocity ratio	(--)	0.3034	0.2990	0.3237
19	Acoustic Vibration Check		Inlet	Center	Outlet
20	Vortex shedding ratio	(--)			
21	Chen number	(--)			
22	Turbulent buffeting ratio	(--)			
23	Tube Vibration Check		Inlet	Center	Outlet
24	Vortex shedding ratio	(--)	0.181	0.301	0.185
25	Parallel flow amplitude	(mm)	0.004	0.005	0.004
26	Crossflow amplitude	(mm)	0.070	0.070	0.072
27	Tube gap	(mm)	6.350	6.350	6.350
28	Crossflow RHO-V-SQ	(kg/m-s2)	440.31	1213.53	451.89
29	Bundle Entrance/Exit				
30	(analysis at first tube row)			Entrance	Exit
31	Fluidelastic instability ratio	(--)		0.173	0.161
32	Vortex shedding ratio	(--)		0.269	0.241
33	Crossflow amplitude	(mm)		0.02377	0.01826
34	Crossflow velocity	(m/s)		0.95	0.85
35	Tubesheet to inlet/outlet support	(mm)		None	None
36	Shell Entrance/Exit Parameters			Entrance	Exit
37	Impingement plate			Yes	
38	Flow area	(m2)		0.067	0.087
39	Velocity	(m/s)		1.68	1.31
40	RHO-V-SQ	(kg/m-s2)		3035.89	1798.67
41	Shell type	AET	Baffle type	Single-Seg.	
42	Tube type	Plain	Baffle layout	Perpend.	
43	Pitch ratio	1.2500	Tube diameter, (mm)	25.400	
44	Layout angle	90	Tube material	Carbon steel	
45			Supports/baffle space		

Program Messages

+ Frequency ratios are based upon lowest natural or acoustic frequency

* Items with asterisk exceed a conservative lower limit for vibration-free design. Review your case using the procedure described in Online Help; You may find that a vibration problem is unlikely.

Final Results

Released to the following HTRI Member Company:

sewage


M.K.Park

Xist Ver. 6.00 SP3 2013/08/19 12:45 SN: 1500213869

MEG Energy Units

Max.Duty Case : Shell 1

Rating - Horizontal Multipass Flow TEMA AET Shell With Single-Segmental Baffles

1	Process Data				Cold Shellside		Hot Tubeside		Shellside Performance				
2	Fluid name		TEG/Water (60/40 wt%)				MP Blowdown		Nom vel, X-flow/window		0.99 / 1.33		
3	Fluid condition		Sens. Liquid				Sens. Liquid		Flow fractions for heat transfer		0.804		
4	Total flow rate		(kg/hr)	433727		207611		A=0.1235 B=0.5372 C=0.2368 E=0.1026 F=0.0000					
5	Weight fraction vapor, In/Out		(--)	0.000		0.000							
6	Temperature, In/Out		(Deg C)	67.30		105.00							
7	Temperature, Average/Skin		(Deg C)	86.15		113.85							
8	Wall temperature, Min/Max		(Deg C)	105.16		143.14							
9	Pressure, In/Average		(kPa)	949.975		928.928							
10	Pressure drop, Total/Allowed		(kPa)	42.102		100.000							
11	Velocity, Mid/Max allow		(m/s)	1.07		2.06							
12	Mole fraction inert		(--)										
13	Average film coef.		(W/m2-K)	4699.02		14342.3							
14	Heat transfer safety factor		(--)	1.000		1.000							
15	Fouling resistance		(m2-K/W)	0.000088		0.000176							
16	Overall Performance Data												
17	Overall coef., Req'd/Clean/Actual		(W/m2-K)	1522.79 /		2945.84 /		1566.09					
18	Heat duty, Calculated/Specified		(kW)	15388. /									
19	Effective overall temperature difference		(Deg C)	78.1									
20	EMTD = (MTD) * (DELTA) * (F/G/H)		(Deg C)	78.29 *		0.9973 *		1.0000					
21													
22													
23													
24													
25													
26	Exchanger Fluid Volumes												
27	Approximate shellside (L)		1855.0										
28	Approximate tubeside (L)		1231.6										
29	Shell Construction Information												
30	TEMA shell type		AET		Shell ID		(mm)		850.000				
31	Shells Series		1 Parallel 1		Total area		(m2)		136.985				
32	Passes Shell		1 Tube 4		Eff. area		(m2/shell)		129.430				
33	Shell orientation angle (deg)		0.00										
34	Impingement present		Circular plate		Impingement diameter/nozzle		1.1						
35	Pairs seal strips		2		Passlane seal rods (mm)		0.000		No. 0				
36	Shell expansion joint		No		Head to support distance (mm)		113.000						
37	Weight estimation Wet/Dry/Bundle		9874.76 /		6790.28 /		2768.55 (kg/shell)						
38	Baffle Information												
39	Type		Perpend. Single-Seg.		Baffle cut (% dia)		25.00						
40	Crosspasses/shellpass		9		No. (Pct Area)		(mm) to C.L						
41	Central spacing		(mm)	450.000		1 22.33		212.500					
42	Inlet spacing		(mm)	727.975		2 0.00		0.000					
43	Outlet spacing		(mm)	729.975									
44	Baffle thickness		(mm)	7.938									
45													
46													
47													
48	Tube Information												
49	Tube type		Plain		Tubecount per shell		352						
50	Overall length		(mm)	4877.		Pct tubes removed (both)		2.27					
51	Effective length		(mm)	4608.		Outside diameter		(mm)	25.400				
52	Total tubesheet		(mm)	156.000		Wall thickness		(mm)	2.110				
53	Area ratio		(out/in)	1.1992		Pitch (mm)		31.7500		Ratio		1.2500	
54	Tube metal		Carbon steel		Tube pattern (deg)		90						
55													
56													
57													
58													
59													
60													
61													
62													
63													
64													
65													
66													
67													
68													
69													
70													
71													
72													
73													
74													
75													
76													
77													
78													
79													
80													
81													
82													
83													
84													
85													
86													
87													
88													
89													
90													
91													
92													
93													
94													
95													
96													
97													
98													
99													
100													

Final Results									
Released to the following HTRI Member Company:									
sawon									
M.K.Park									
Xist Ver. 6.00 SP3 2013/08/19 12:45 SN: 1500213869					MEG Energy Units				
Max.Duty Case : Shell 2									
Rating - Horizontal Multipass Flow TEMA AET Shell With Single-Segmental Baffles									
1	Process Data		Cold Shellside		Hot Tubeside		Shellside Performance		
2	Fluid name	TEG/Water (60/40 wt%)		MP Blowdown		Nom vel, X-flow/window 0.97 / 1.30			
3	Fluid condition	Sens. Liquid		Sens. Liquid		Flow fractions for heat transfer 0.814			
4	Total flow rate	(kg/hr)	433727			A=0.1055 B=0.5476 C=0.2409 E=0.1060 F=0.0000			
5	Weight fraction vapor, In/Out	(-)	0.000	0.000	0.000				
6	Temperature, In/Out	(Deg C)	40.00	67.30	138.99				
7	Temperature, Average/Skin	(Deg C)	53.65	77.32	117.00				
8	Wall temperature, Min/Max	(Deg C)	71.56	105.55	74.82				
9	Pressure, In/Average	(kPa)	994.015	971.995	1499.70				
10	Pressure drop, Total/Allowed	(kPa)	44.040	100.000	54.486				
11	Velocity, Mid/Max allow	(m/s)	1.07		1.96				
12	Mole fraction inert	(-)							
13	Average film coef.	(W/m2-K)		3749.26	12209.9				
14	Heat transfer safety factor	(-)		1.000	1.000				
15	Fouling resistance	(m2-K/W)		0.000088	0.000176				
16	Overall Performance Data								
17	Overall coef., Req'd/Clean/Actual	(W/m2-K)	1393.52	/	2462.80	/	1418.21		
18	Heat duty, Calculated/Specified	(kW)	10759.	/					
19	Effective overall temperature difference	(Deg C)	59.7						
20	EMTD = (MTD) * (DELTA) * (F/G/H)	(Deg C)	59.82	*	0.9974	*	1.0000		
21									
22									
23									
24									
25									
26	Exchanger Fluid Volumes								
27	Approximate shellside (L)		1855.0						
28	Approximate tubeside (L)		1231.6						
29	Shell Construction Information								
30	TEMA shell type	AET	Shell ID	(mm)	850.000				
31	Shells Series	1 Parallel	1	Total area	(m2)	136.985			
32	Passes Shell	1 Tube	4	Eff. area	(m2/shell)	129.430			
33	Shell orientation angle (deg)	0.00							
34	Impingement present	Circular plate	Impingement diameter/nozzle	1.1					
35	Pairs seal strips	2	Passlane seal rods (mm)	0.000	No. 0				
36	Shell expansion joint	No	Head to support distance (mm)	113.000					
37	Weight estimation Wet/Dry/Bundle	9881.56 / 6797.08 / 2775.36	(kg/shell)						
38									
39	Baffle Information								
40	Type	Perpend. Single-Seg.	Baffle cut (% dia)	25.00					
41	Crosspasses/shellpass	9	No. (Pct Area)	(mm) to C.L.					
42	Central spacing	(mm)	450.000	1	22.33	212.500			
43	Inlet spacing	(mm)	729.975	2	0.00	0.000			
44	Outlet spacing	(mm)	727.975						
45	Baffle thickness	(mm)	7.938						
46									
47									
48	Tube Information								
49	Tube type	Plain	Tube count per shell	352					
50	Overall length	(mm)	4877.	Pct tubes removed (both)	2.27				
51	Effective length	(mm)	4608.	Outside diameter	(mm)	25.400			
52	Total tubesheet	(mm)	156.000	Wall thickness	(mm)	2.110			
53	Area ratio	(out/in)	1.1992	Pitch (mm)	31.7500	Ratio	1.2500		
54	Tube metal	Carbon steel	Tube pattern (deg)	90					
Two-Phase Parameters									
Method		Inlet	Center	Outlet	Mix F				
H. T. Parameters									
Overall wall correction		Shell	1.068	Tube	0.992				
Midpoint		Prandtl no.	33.39	1.53					
Midpoint		Reynolds no.	11678	160129					
Bundle inlet		Reynolds no.	5638	197031					
Bundle outlet		Reynolds no.	10094	132903					
Fouling layer		(mm)							
Thermal Resistance									
Shell		Tube	Fouling	Metal	Over Des				
37.83		13.93	42.41	5.83	1.77				
Total fouling resistance					2.989e-4				
Differential resistance					1.249e-5				
Shell Nozzles									
Inlet at channel end-No		Inlet	Outlet	Liquid					
Number at each position		1	1	0					
Diameter		(mm)	295.301	295.301					
Velocity		(m/s)	1.63	1.67					
Pressure drop		(kPa)	3.426	2.375					
Height under nozzle		(mm)	76.350	91.700					
Nozzle R-V-SQ		(kg/m-s2)	2870.52	2929.88					
Shell ent.		(kg/m-s2)	3035.89	1798.67					
Tube Nozzle									
Inlet		Outlet	Liquid						
Diameter		(mm)	193.675	193.675					
Velocity		(m/s)	2.11	2.03					
Pressure drop		(kPa)	2.272	1.394					
Nozzle R-V-SQ		(kg/m-s2)	4130.80	3981.05					
Annular Distributor									
Inlet		Outlet							
Length		(mm)							
Height		(mm)							
Slot area		(mm2)							
Diametral Clearances (mm)									
Baffle-to-shell		Bundle-to-shell	Tube-to-baffle						
4.7625		124.700	0.7938						

3A-E-324A/B (Min Duty Case)

The Thermal/Hydraulic/Vibration calculations are performed by using HTRI Xist Ver. 6.00 SP3.

The process condition and the physical properties are based on Buyer DATA SHEET (2).

For the design result (the geometry data), please refer to the Equipment DATA SHEET (2) and Fabrication drawing.

1. Thermal and Hydraulic performance

- Thermal performance :	<u>23.80</u>	% Over - Design Case	-----	O.K.
- Pressure drop :				
Shell-side	<u>49.135</u>	<	100.000 kPa	----- O.K
tube-side	<u>62.423</u>	<	120.000 kPa	----- O.K

2. Vibration Analysis

- Fluidelastid instability :	characteristic values	<<	criteria	-----	O.K.
- Acoustic vibration :	characteristic values	<<	criteria	-----	O.K.
- Tube vibration check:	characteristic values	<<	criteria	-----	O.K.
- Bundle Entrance/Exit :	characteristic values	<<	criteria	-----	O.K.
- Shell Entrance /Exit:	characteristic values	<<	criteria	-----	O.K.

16/21

3A-E-324A/B (Min Duty Case) - Shell 1

Used Program : HTRI Xist Ver.6.00 SP.3 Vibration Analysis

VALUE TO BE CHECKED	Inlet	Center	Outlet	RECOMMEND LIMIT	CONCLUSION
Unsupported span (mm)	1178.	900.	1180.	1879 (By TEMA)	O.K
Length / TEMA maximum span	0.627	0.479	0.628	< 1.0 TEMA	O.K
Fluidelastic Instability Check					
Baffle tip cross velocity ratio	0.2640	0.2602	0.2830	< 0.8	O.K
Ave. crossflow velocity ratio	0.2365	0.2332	0.2536	< 0.8	O.K
Acoustic Vibration Check					
Vortex shedding ratio	-	-	-	-	-
Tubulent buffeting ratio	-	-	-	-	-
Tube Vibration Check					
Vortex shedding ratio	0.135	0.227	0.139	< 0.5	O.K
Tubulent buffeting ratio	-	-	-	-	-
Bundle Entrance / Exit		Entrance	Exit		
Fluidelastic Instability ratio		0.136	0.128	< 0.8	O.K
Vortex shedding ratio		0.204	0.184	< 0.5	O.K
Shell Entrance / Exit					
Velocity (m/sec)		1.27	1.00	< If velocity is exceed 2.03 / 1.94	O.K.
pv2 (kg/m-s2)		1713.76	1024.22	< 5953 by TEMA	O.K.

17/24

Vibration Analysis				
Released to the following HTRI Member Company:				
sewon M.K.Park				
Xist Ver. 6.00 SP3 2013/08/19 12:47 SN: 1500213869			MEG Energy Units	
Min.Duty Case : Shell 1				
Rating - Horizontal Multipass Flow TEMA AET Shell With Single-Segmental Baffles				
1	Shellside condition	Sens. Liquid	(Level 2.3)	
2	Axial stress loading (MPa)	0.000	Added mass factor	1.517
3	Beta	2.570		
4	Position In The Bundle	Inlet	Center	Outlet
5	Length for natural frequency (mm)	1178.	900.	1180.
6	Length/TEMA maximum span (---)	0.627	0.479	0.628
7	Number of spans (---)	5	5	5
8	Tube natural frequency (Hz)	57.9 +	63.2	58.0
9	Shell acoustic frequency (Hz)			
10	Flow Velocities	Inlet	Center	Outlet
11	Window parallel velocity (m/s)	0.86	0.88	0.89
12	Bundle crossflow velocity (m/s)	0.48	0.80	0.49
13	Bundle/shell velocity (m/s)	0.22	0.37	0.23
14	Fluidelastic instability Check	Inlet	Center	Outlet
15	Log decrement HTRI	0.084	0.081	0.076
16	Critical velocity (m/s)	2.03	3.44	1.94
17	Baffle tip cross velocity ratio (---)	0.2640	0.2602	0.2830
18	Average crossflow velocity ratio (---)	0.2365	0.2332	0.2536
19	Acoustic Vibration Check	Inlet	Center	Outlet
20	Vortex shedding ratio (---)			
21	Chen number (---)			
22	Turbulent buffeting ratio (---)			
23	Tube Vibration Check	Inlet	Center	Outlet
24	Vortex shedding ratio (---)	0.135	0.227	0.139
25	Parallel flow amplitude (mm)	0.002	0.003	0.002
26	Crossflow amplitude (mm)	0.039	0.038	0.040
27	Tube gap (mm)	6.350	6.350	6.350
28	Crossflow RHO-V-SQ (kg/m-s2)	243.19	669.67	249.01
29	Bundle Entrance/Exit		Entrance	Exit
30	(analysis at first tube row)			
31	Fluidelastic instability ratio (---)		0.136	0.128
32	Vortex shedding ratio (---)		0.204	0.184
33	Crossflow amplitude (mm)		0.01319	0.01040
34	Crossflow velocity (m/s)		0.72	0.65
35	Tubesheet to inlet/outlet support (mm)		None	None
36	Shell Entrance/Exit Parameters		Entrance	Exit
37	Impingement plate		Yes	
38	Flow area (m2)		0.067	0.087
39	Velocity (m/s)		1.27	1.00
40	RHO-V-SQ (kg/m-s2)		1713.76	1024.22
41	Shell type AET	Baffle type	Single-Seg.	
42	Tube type Plain	Baffle layout	Perpend.	
43	Pitch ratio 1.2500	Tube diameter, (mm)	25.400	
44	Layout angle 90	Tube material	Carbon steel	
45		Supports/baffle space		
46	Program Messages			
47	+ Frequency ratios are based upon lowest natural or acoustic frequency			
48	* Items with asterisk exceed a conservative lower limit for vibration-free design. Review your case			
49	using the procedure described in Online Help; You may find that a vibration problem is unlikely.			
50				
51				
52				
53				

18/21

3A-E-324A/B (Min Duty Case) - Shell 2


Used Program : HTRI Xist Ver.6.00 SP.3 Vibration Analysis

VALUE TO BE CHECKED	Inlet	Center	Outlet	RECOMMEND LIMIT	CONCLUSION
Unsupported span (mm)	1180.	900.	1178.	1879 (By TEMA)	O.K
Length / TEMA maximum span	0.628	0.479	0.627	< 1.0 TEMA	O.K
Fluidelastic Instability Check					
Baffle tip cross velocity ratio	0.2569	0.2530	0.2739	< 0.8	O.K
Ave. crossflow velocity ratio	0.2302	0.2267	0.2454	< 0.8	O.K
Acoustic Vibration Check					
Vortex shedding ratio	-	-	-	-	-
Tubulent buffeting ratio	-	-	-	-	-
Tube Vibration Check					
Vortex shedding ratio	0.137	0.229	0.140	< 0.5	O.K
Tubulent buffeting ratio	-	-	-	-	-
Bundle Entrance / Exit		Entrance	Exit		
Fluidelastic Instability ratio		0.128	0.120	< 0.8	O.K
Vortex shedding ratio		0.200	0.179	< 0.5	O.K
Shell Entrance / Exit					
Velocity (m/sec)		1.25	0.97	< If velocity is exceed 2.11 / 2.02	O.K.
pv2 (kg/m-s2)		1679.36	994.78	< 5953 by TEMA	O.K.


19/21

Vibration Analysis				
Released to the following HTRI Member Company:				
sewon M.K.Park				
Xist Ver. 6.00 SP3 2013/08/19 12:47 SN: 1500213869			MEG Energy Units	
Min.Duty Case : Shell 2				
Rating - Horizontal Multipass Flow TEMA AET Shell With Single-Segmental Baffles				
1	Shellside condition	Sens. Liquid	(Level 2.3)	
2	Axial stress loading (MPa)	0.000	Added mass factor	1.517
3	Beta	2.570		
4	Position In The Bundle	Inlet	Center	Outlet
5	Length for natural frequency (mm)	1180.	900.	1178.
6	Length/TEMA maximum span (mm)	0.628	0.479	0.627
7	Number of spans (mm)	5	5	5
8	Tube natural frequency (Hz)	57.8 +	63.3	58.2
9	Shell acoustic frequency (Hz)			
10	Flow Velocities	Inlet	Center	Outlet
11	Window parallel velocity (m/s)	0.87	0.88	0.88
12	Bundle crossflow velocity (m/s)	0.48	0.81	0.50
13	Bundle/shell velocity (m/s)	0.22	0.37	0.22
14	Fluidelastic Instability Check	Inlet	Center	Outlet
15	Log decrement HTRI	0.091	0.088	0.083
16	Critical velocity (m/s)	2.11	3.57	2.02
17	Baffle tip cross velocity ratio (mm)	0.2569	0.2530	0.2739
18	Average crossflow velocity ratio (mm)	0.2302	0.2267	0.2454
19	Acoustic Vibration Check	Inlet	Center	Outlet
20	Vortex shedding ratio (mm)			
21	Chen number (mm)			
22	Turbulent buffeting ratio (mm)			
23	Tube Vibration Check	Inlet	Center	Outlet
24	Vortex shedding ratio (mm)	0.137	0.229	0.140
25	Parallel flow amplitude (mm)	0.002	0.003	0.002
26	Crossflow amplitude (mm)	0.040	0.039	0.041
27	Tube gap (mm)	6.350	6.350	6.350
28	Crossflow RHO-V-SQ (kg/m-s2)	253.46	698.42	260.07
29	Bundle Entrance/Exit			
30	(analysis at first tube row)		Entrance	Exit
31	Fluidelastic instability ratio (mm)	--	0.128	0.120
32	Vortex shedding ratio (mm)	--	0.200	0.179
33	Crossflow amplitude (mm)		0.01271	0.00983
34	Crossflow velocity (m/s)		0.71	0.63
35	Tubesheet to inlet/outlet support (mm)		None	None
36	Shell Entrance/Exit Parameters		Entrance	Exit
37	Impingement plate		Yes	
38	Flow area (m2)		0.067	0.087
39	Velocity (m/s)		1.25	0.97
40	RHO-V-SQ (kg/m-s2)		1679.36	994.78
41	Shell type AET	Baffle type	Single-Seg.	
42	Tube type Plain	Baffle layout	Perpend.	
43	Pitch ratio 1.2500	Tube diameter, (mm)	25.400	
44	Layout angle 90	Tube material	Carbon steel	
45		Supports/baffle space		
46	Program Messages			
47	+ Frequency ratios are based upon lowest natural or acoustic frequency			
48	* Items with asterisk exceed a conservative lower limit for vibration-free design. Review your case			
49	using the procedure described in Online Help; You may find that a vibration problem is unlikely.			
50				
51				
52				
53				

20/21

Final Results												
Released to the following HTRI Member Company:												
sewon												
M.K.Park												
Xist Ver. 6.00 SP3 2013/08/19 12:47 SN: 1500213869					MEG Energy Units							
Min.Duty Case : Shell 1												
Rating - Horizontal Multipass Flow TEMA AET Shell With Single-Segmental Baffles												
1	Process Data		Cold Shellside		Hot Tubeside		Shellside Performance					
2	Fluid name	TEG/Water (60/40 wt%)		MP Blowdown		Nom vel, X-flow/window 0.74 / 0.99						
3	Fluid condition	Sens. Liquid		Sens. Liquid		Flow fractions for heat transfer 0.808						
4	Total flow rate	(kg/hr)	322586	154412		A=0.1162 B=0.5402 C=0.2393 E=0.1044 F=0.0000						
5	Weight fraction vapor, In/Out	(--)	0.000	0.000								
6	Temperature, In/Out	(Deg C)	67.05	200.00								
7	Temperature, Average/Skin	(Deg C)	86.02	169.29								
8	Wall temperature, Min/Max	(Deg C)	105.53	109.64								
9	Pressure, In/Average	(kPa)	968.938	1555.02								
10	Pressure drop, Total/Allowed	(kPa)	24.059	31.397								
11	Velocity, Mid/Max allow	(m/s)	0.80	1.53								
12	Mole fraction inert	(--)										
13	Average film coef.	(W/m2-K)	3915.43	11324.3								
14	Heat transfer safety factor	(--)	1.000	1.000								
15	Fouling resistance	(m2-K/W)	0.000088	0.000176								
16	Overall Performance Data											
17	Overall coef., Req'd/Clean/Actual	(W/m2-K)	1141.45 /	2473.20 /		1421.65						
18	Heat duty, Calculated/Specified	(kW)	11520. /									
19	Effective overall temperature difference	(Deg C)	78.0									
20	EMTD = (MTD) * (DELTA) * (F/G/H)	(Deg C)	78.20 *	0.9973 *		1.0000						
21												
22												
23												
24												
25												
26	Exchanger Fluid Volumes											
27	Approximate shellside (L)	1855.0										
28	Approximate tubeside (L)	1231.6										
29	Shell Construction Information											
30	TEMA shell type	AET	Shell ID	(mm)	850.000							
31	Shells Series	1 Parallel 1	Total area	(m2)	136.985							
32	Passes Shell	1 Tube 4	Eff. area	(m2/shell)	129.430							
33	Shell orientation angle (deg)	0.00										
34	Impingement present	Circular plate	Impingement diameter/nozzle	1.1								
35	Pairs seal strips	2	Passlane seal rods (mm)	0.000	No. 0							
36	Shell expansion joint	No	Head to support distance (mm)	113.000								
37	Weight estimation Wet/Dry/Bundle	9874.76 /	6790.28 /	2768.55 (kg/shell)								
38												
39	Baffle Information											
40	Type	Perpend. Single-Seg.	Baffle cut (% dia)	25.00								
41	Crosspasses/shellpass	9	No. (Pct Area)	(mm) to C.L								
42	Central spacing	(mm) 450.000	1	22.33	212.500							
43	Inlet spacing	(mm) 727.975	2	0.00	0.000							
44	Outlet spacing	(mm) 729.975										
45	Baffle thickness	(mm) 7.938										
46												
47												
48	Tube Information											
49	Tube type	Plain	Tubecount per shell	352								
50	Overall length	(mm) 4877.	Pct tubes removed (both)	2.27								
51	Effective length	(mm) 4608.	Outside diameter	(mm)	25.400							
52	Total tubesheet	(mm) 156.000	Wall thickness	(mm)	2.110							
53	Area ratio	(out/in) 1.1992	Pitch (mm)	31.7500	Ratio	1.2500						
54	Tube metal	Carbon steel	Tube pattern (deg)	90								
							Shellside Heat Transfer Corrections					
							Total	Beta	Gamma	End	Fin	
							0.981	0.919	1.067	0.916	1.000	
							Pressure Drops (Percent of Total)					
							Cross	Window	Ends	Nozzle	Shell	Tube
							49.36	24.89	12.27	Inlet	7.90	4.29
							MOMENTUM		0.00	Outlet	5.57	2.55
							Two-Phase Parameters					
							Method	Inlet	Center	Outlet	Mix F	
							H. T. Parameters					
									Shell	Tube		
							Overall wall correction		1.070	0.988		
							Midpoint	Prandtl no.	18.08	1.05		
							Midpoint	Reynolds no.	16193	177705		
							Bundle inlet	Reynolds no.	7414	216168		
							Bundle outlet	Reynolds no.	14414	148231		
							Fouling layer	(mm)				
							Thermal Resistance					
							Shell	Tube	Fouling	Metal	Over Des	
							36.31	15.06	42.52	6.12	24.55	
							Total fouling resistance	2.989e-4				
							Differential resistance	1.727e-4				
							Shell Nozzles					
							Inlet at channel end-Yes		Inlet	Outlet	Liquid	
							Number at each position		1	1	0	
							Diameter	(mm)	295.301	295.301		
							Velocity	(m/s)	1.24	1.28		
							Pressure drop	(kPa)	1.902	1.340		
							Height under nozzle	(mm)	76.350	91.700		
							Nozzle R-V-SQ	(kg/m-s2)	1620.41	1668.36		
							Shell ent.	(kg/m-s2)	1713.76	1024.22		
							Tube Nozzle					
									Inlet	Outlet	Liquid	
							Diameter	(mm)	193.675	193.675	Outlet	
							Velocity	(m/s)	1.68	1.57		
							Pressure drop	(kPa)	1.348	0.800		
							Nozzle R-V-SQ	(kg/m-s2)	2451.49	2284.07		
							Annular Distributor					
									Inlet	Outlet		
							Length	(mm)				
							Height	(mm)				
							Slot area	(mm2)				
							Diametral Clearances (mm)					
							Baffle-to-shell	Bundle-to-shell	Tube-to-baffle			
							4.7625	124.700	0.7938			

21/21

Final Results									
Released to the following HTRI Member Company:									
sewon									
M.K.Park									
Xist Ver. 6.00 SP3 2013/08/19 12:47 SN: 1500213869					MEG Energy Units				
Min.Duty Case : Shell 2									
Rating - Horizontal Multipass Flow TEMA AET Shell With Single-Segmental Baffles									
1	Process Data		Cold Shellside		Hot Tubeside		Shellside Performance		
2	Fluid name	TEG/Water (60/40 wt%)		MP Blowdown		Nom vel, X-flow/window 0.72 / 0.97			
3	Fluid condition	Sens. Liquid		Sens. Liquid		Flow fractions for heat transfer 0.822			
4	Total flow rate	(kg/hr)	322586	154412		A=0.0941 B=0.5586 C=0.2400 E=0.1072 F=0.0000			
5	Weight fraction vapor, In/Out	(--)	0.000	0.000	0.000				
6	Temperature, In/Out	(Deg C)	40.00	67.05	138.58				
7	Temperature, Average/Skin	(Deg C)	53.52	79.26	116.79				
8	Wall temperature, Min/Max	(Deg C)	72.80	106.95	75.69				
9	Pressure, In/Average	(kPa)	994.015	981.476	1523.65				
10	Pressure drop, Total/Allowed	(kPa)	25.076	100.000	31.026				
11	Velocity, Mid/Max allow	(m/s)	0.81		1.46				
12	Mole fraction inert	(--)							
13	Average film coef.	(W/m2-K)		3057.91	9640.41				
14	Heat transfer safety factor	(--)		1.000	1.000				
15	Fouling resistance	(m2-K/W)		0.000088	0.000176				
16	Overall Performance Data								
17	Overall coef., Req'd/Clean/Actual	(W/m2-K)	1027.30 /	2030.42 /	1263.29				
18	Heat duty, Calculated/Specified	(kW)	7927. /						
19	Effective overall temperature difference	(Deg C)	59.6						
20	EMTD = (MTD) * (DELTA) * (F/G/H)	(Deg C)	59.78 *	0.9974 *	1.0000				
21									
22									
23									
24									
25									
26	Exchanger Fluid Volumes								
27	Approximate shellside (L)	1855.0							
28	Approximate tubeside (L)	1231.6							
29	Shell Construction Information								
30	TEMA shell type	AET	Shell ID	(mm)	850.000				
31	Shells Series	1 Parallel 1	Total area	(m2)	136.985				
32	Passes Shell	1 Tube 4	Eff. area	(m2/shell)	129.430				
33	Shell orientation angle (deg)	0.00							
34	Impingement present	Circular plate	Impingement diameter/nozzle	1.1					
35	Pairs seal strips	2	Passplane seal rods (mm)	0.000	No. 0				
36	Shell expansion joint	No	Head to support distance (mm)	113.000					
37	Weight estimation Wet/Dry/Bundle	9881.61 /	6797.13 /	2775.40	(kg/shell)				
38									
39	Baffle Information								
40	Type	Perpend. Single-Seg.	Baffle cut (% dia)	25.00					
41	Crosspasses/shellpass	9	No. (Pct Area)	(mm) to C.L					
42	Central spacing	(mm)	450.000	1	22.33	212.500			
43	Inlet spacing	(mm)	729.975	2	0.00	0.000			
44	Outlet spacing	(mm)	727.975						
45	Baffle thickness	(mm)	7.938						
46									
47									
48	Tube Information								
49	Tube type	Plain	Tube count per shell	352					
50	Overall length	(mm)	4877.	Pct tubes removed (both)	2.27				
51	Effective length	(mm)	4608.	Outside diameter	(mm)	25.400			
52	Total tubesheet	(mm)	156.000	Wall thickness	(mm)	2.110			
53	Area ratio	(out/in)	1.1992	Pitch (mm)	31.7500	Ratio	1.2500		
54	Tube metal	Carbon steel	Tube pattern (deg)	90					
						Shellside Heat Transfer Corrections			
						Total	Beta	Gamma	End Fin
						0.981	0.919	1.067	0.904 1.000
						Pressure Drops (Percent of Total)			
						Cross	Window	Ends	Nozzle Shell Tube
						50.43	24.80	11.78	Inlet 7.71 4.05
						MOMENTUM		0.00	Outlet 5.28 2.48
						Two-Phase Parameters			
						Method	Inlet	Center	Outlet Mix F
						H. T. Parameters			
						Overall wall correction		Shell	Tube
								1.073	0.991
						Midpoint	Prandtl no.	33.55	1.53
						Midpoint	Reynolds no.	8724	118899
						Bundle inlet	Reynolds no.	4234	146086
						Bundle outlet	Reynolds no.	7541	98837
						Fouling layer	(mm)		
						Thermal Resistance			
						Shell	Tube	Fouling	Metal Over Des
						41.31	15.72	37.78	5.19 22.97
						Total fouling resistance			2.989e-4
						Differential resistance			1.818e-4
						Shell Nozzles			
						Inlet at channel end-No		Inlet	Outlet Liquid
						Number at each position		1	1 0
						Diameter	(mm)	295.301	295.301
						Velocity	(m/s)	1.21	1.24
						Pressure drop	(kPa)	1.932	1.325
						Height under nozzle	(mm)	76.350	91.700
						Nozzle R-V-SQ	(kg/m-s2)	1587.89	1620.41
						Shell ent.	(kg/m-s2)	1679.36	994.78
						Tube Nozzle			
								Inlet	Outlet Liquid
						Diameter	(mm)	RADIAL 193.675	RADIAL 193.675
						Velocity	(m/s)	1.57	1.51
						Pressure drop	(kPa)	1.256	0.771
						Nozzle R-V-SQ	(kg/m-s2)	2284.12	2202.18
						Annular Distributor			
								Inlet	Outlet
						Length	(mm)		
						Height	(mm)		
						Slot area	(mm2)		
						Diametral Clearances (mm)			
						Baffle-to-shell	Bundle-to-shell	Tube-to-baffle	
						4.7625	124.700	0.7938	

